



VASUDHA

enviro labs Pvt. Ltd

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-65243910 Fax: +91-40-42009193
e-mail: vasudha.enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT


CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR – 1787 – 0219
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	28 th February 2019
		REGISTRATION NO.	VEL/120
		REGISTRATION DATE	13 th February 2019
		CUSTOMER REFERENCE	--
SAMPLE DESCRIPTION	STP - Inlet water	REFERENCE DATE	--
		ANALYSIS STARTING DATE	14 th February 2019
SAMPLE SITE	Aparna, Lakebreeze	ANALYSIS COMPLETION DATE	20 th February 2019
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000ml	
Sample Collected		By client	

TEST RESULTS

S. No.	TEST PARAMETERS	UNITS	RESULTS
1.	pH	--	7.0
2.	Total Dissolved Solids	mg/l	582.7
3.	Total Suspended Solids	mg/l	165.3
4.	Chemical Oxygen Demand	mg/l	550
5.	Biological Oxygen Demand (3 Days @ 27°C)	mg/l	134
6.	Chlorides as Cl	mg/l	321.6
7.	Sulphates as SO ₄	mg/l	43.5
8.	Oil & grease	mg/l	2.9
9.	Total Hardness as CaCO ₃	mg/l	416.8
10.	Calcium as Ca	mg/l	103.4
11.	Total Alkalinity as CaCO ₃	mg/l	105.0
12.	Nitrates as NO ₃	mg/l	19.7
13.	Color	--	3.12
14.	Odour	--	Disagreeable
15.	Turbidity	NTU	82.1

Note: The results relate to the sample tested only. TEST METHOD: APHA




Authorized Signatory