

Westside STP Not working Data	
Category	Raw Sewage Pumps
S.No	2
Description of Issue	Raw sewage pump Not working
Root Cause	Auto coupling broken
Action Required / Planned	Under warranty. Informed to M/s. Revolve Engineers
Pending from days	30
Responsibility	M/s. Revolve Engineers
Estimated Date of Completion	10-09-2019
Notified to the concerned	APMS