

Elixir - STP Equipment Status					
Category	S.No	Description	Capacity - 90		Total Downtime (Hrs/days) of all Equipment
			Total	Not Working	
Electro-Mechanical Equipment	1	Bar Screen Chamber	1	0	
	2	Raw Sewage Pumps	2	0	
	3	Air Blowers	2	0	
	4	Return Sludge Pumps	2	0	
	5	Filter Feed Pumps	2	0	
	6	Screw / Centrifuge Feed Pumps	1	0	
	7	Centrifuge / Filter Press	NA	-	
	8	De-watering Pump	2	0	
	9	Air Handling Unit	NA	-	
	10	Chlorine Dosing Pump	1	0	
	11	UV System	NA	-	
	12	Hydro Pneumatic Pumps	1	0	
Electrical Panels	13	Pneumatic System Panel	1	0	
	14	STP MCC Panel	1	0	
Filtration	15	Pressure Sand Filter	1	0	
	16	Activated Carbon Filter	1	0	
Flow details in Kilo Liters(KL)/Day					
Flow Details	17	Average Inflow	40		
	18	Average Outflow to garden / fire / flush	110	70 Kl received from Cyber life	
	19	Surplus Treated Water Outlet	0		
	20	Average Outflow to other sites	0		
	21	Sludge Extracted(Kgs)	0		
Next filter media replacement date			Oct - 20		