

LakeBreeze STP Not working Data	
<b>Category</b>	<b>Air Blowers</b>
<b>S.No</b>	3
<b>Description of Issue</b>	One of the Air blowers is not working
<b>Root Cause</b>	Due to gears of the blower were damaged
<b>Action Required / Planned</b>	Work order issued to M/s Revolve Engineers Pvt Ltd. to carry out the repair work ( WO\192\00035)
<b>Pending from days</b>	57
<b>Responsibility</b>	M/s, Revolve Engineers Pvt Ltd
<b>Estimated Date of Completion</b>	31.04.2019 (Work inprogress)
<b>Notified to the concerned</b>	APMS and Revolve