



VASUDHA

enviro labs Pvt. Ltd

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-65243910 Fax: +91-40-42009193
e-mail: vasudha.enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in


TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR - 1104 - 0419
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	25 th April 2019
		REGISTRATION NO.	VEL/350
		REGISTRATION DATE	12 th April 2019
		CUSTOMER REFERENCE	--
SAMPLE DESCRIPTION	WTP water - Inlet	REFERENCE DATE	--
		ANALYSIS STARTING DATE	13 th April 2019
SAMPLE SITE	Aparna, Hillpark Boulevard	ANALYSIS COMPLETION DATE	18 th April 2019
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000 ml	
SAMPLE COLLECTED OR SUBMITTED		By client	

TEST RESULTS

S.NO.	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
Physical & Chemical Parameters					
1	pH	--	IS 3025 P-11	7.1	6.50 – 8.50
2	Conductivity	µs/cm	APHA	1070	Not Specified
3	Colour	Hazen	IS 3025 P-4	0.1	<5
4	Turbidity	NTU	IS 3025 P-10	0.2	<1
5	Total Dissolved Solids	mg/l	IS 3025 P-16	534.7	<500
6	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	IS 3025 P-23	Nil	Not specified
7	Alkalinity to methyl orange as CaCO ₃	mg/l	IS 3025 P-23	135.4	<200
8	Total Hardness as CaCO ₃	mg/l	IS 3025 P-21	275.0	<200
9	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P-21	139.6	Not specified
10	Calcium as Ca	mg/l	IS 3025 P-40	58.1	<75
11	Magnesium as Mg	mg/l	IS 3025 P-46	24.3	<30
12	Sodium as Na	mg/l	IS 3025 P-45	7.2	Not Specified
13	Potassium as K	mg/l	IS 3025 P-45	1.3	Not Specified
14	Iron as Fe	mg/l	IS 3025 P-53	0.1	<0.3
15	Silica as SiO ₂	mg/l	APHA	6.7	Not Specified
16	Fluoride as F	mg/l	APHA	0.1	<1.0
17	Chlorides as Cl	mg/l	IS 3025 P-32	76.2	<250
18	Sulphates as SO ₄	mg/l	IS 3025 P-24	16.3	<200
19	Nitrates as NO ₃	mg/l	IS 3025 P-34	8.1	<45
20	Chlorine demand	mg/l	APHA	0.5	<1.0

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water specification.



Authorized Signatory