

Sarovar - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	1	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	1	0				
Electrical Distribution System(LT)	5	Transformers	4	0				
	6	Main Pcc Panel	8	0				
	7	APFCR	4	0				
	8	Common Supply Panel	7	0				
	9	Bus Duct	28	0				
	10	Distribution Board	25	0				
	11	VCB	13	1(1)				542 days
	12	ACB	4	0				
	13	Landscape Lighting Panel	7	0				
	14	Club House Panel	2	0				
	15	Lighting Arrestor	7	0				
	16	Total No. Of Lights	3393	16(16)				79 days
Elevators & Backup Power	17	Lifts	43	0				
	18	DG Sets	16	0				
	19	ARD Batteries	43 Sets	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	13	9(10)				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	784	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	14	2(2)				171 days
	28	Irrigation Pump Panels	7	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	5	1(1)				5 days
	31	Fountain	1	1(1)				1162 days
De-watering System	32	Storm Water Pump	12	0	12	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	1	0	1	0	0	
	35	Rain Water Harvesting Pits	18	0				
Swimming Pool	36	Indoor Pool Pumps	2	0				
	37	Outdoor Pool Pumps	3	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	6	3(3)				552 days
	40	Solar Fencing	4	0				
	41	CCTV	40	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	7 & 4	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	1	0				

Sarovar - Equipment Not Working Data

Category	VCB	Total No. Of Lights	Borewells	Irrigation Pumps	Water Body Pumps	Fountain	Boom Barrier
S.No	11	16	21	27	30	31	39
Description of Issue	VCB not working	Lights are not working	Borewells not working	Irrigation pumps not working	L block water body motor not working	Mist Fountain not working	Boom barriers not working
Root Cause	VCB breaker pole not functioning due to moisture enter into the breaker	Due to bulbs problem	Due to low groundwater and motors burnt	Due to aging	Due to Bearings problem and abnormal sound coming from motor	Due to pipeline damage	Due to communication problem
Action Required / Planned	VCB breaker pole to be replaced with new one, informed to Society	Informed to society for procuring of new bulbs	Informed to Society	Informed to society for procuring new pumps	Sent for repair	Informed to society for procuring new pipe and accessories	Informed to society
Pending from days	542	79	-	171	5	1162	552
Estimation Date	Working from 18.04.2019	-	-	-	-	Society not willing to run the mist fountain - Abended	Society not willing to repair the boom barriers - Abended
Responsibility	Society	Society	Society	Society	APMS	Society	Society
Notified to the concerned	Society	Society	Society	Society	APMS	Society	Society

LakeBreeze - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	1	0				
	3	CTPT	1	0				
	4	5 Panel	1	0				
Electrical Distribution System(LT)	5	Transformers	2	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	2	0				
	8	Common Supply Panel	11	0				
	9	Bus Duct	23	0				
	10	Distribution Board	12	0				
	11	VCB	5	0				
	12	ACB	5	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	22	0				
	16	Total No. Of Lights	3135	34(32)				90 days
Elevators & Backup Power	17	Lifts	23	0				
	18	DG Sets	2	0				
	19	ARD Batteries	23 Sets	-				
	20	Partial / Full Backup	500W	-				
Ground Water Source	21	Borewells	3	2(2)				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	1070	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	2	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	0	0	0	0	0	
	33	Oozing Pumps	4	0	4	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	35	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	6	2				15 days
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	6	0				
	40	Solar Fencing	1	0				
	41	CCTV	123	2(2)				3 days
Reticulated Piped Gas	42	Gas Bank & Chambers	6 & 12	-				
Air Handling Unit(AHU)	43	Fresh Air	1	0				
	44	STP AHU	1	0				

LakeBreeze - Equipment Not Working Data				
Category	Total No. Of Lights	Borewells	Outdoor Pool Pumps	CCTV
S.No	16	21	37	41
Description of Issue	Lights not working	Borewell not working	Pumps are not working	Cameras are not working
Root Cause	Due to drivers/bulbs Problem	Due to low ground water and bore well abended	Due to winding failure, mechanical seal and impeller damaged	G - block passenger & Entry/Exit view camera cable problem
Action Required / Planned	Informed to society for procuring new lights	Informed to society	Sent for repair to vendor M/s. Clear water pools	Informed to society for replacement of cables
Pending from days	90	-	15	3
Estimation Date	30.04.2019	-	30.04.2019	05.05.2019
Responsibility	Society	Society	APMS	Society
Notified to the concerned	Society	Society	APMS	Society

Sarovar Grande - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	1	0				
	3	CTPT	1	0				
	4	5 Panel	1	0				
Electrical Distribution System(LT)	5	Transformers	3	0				
	6	Main Pcc Panel	3	0				
	7	APFCR	3	0				
	8	Common Supply Panel	9	0				
	9	Bus Duct	18	0				
	10	Distribution Board	18	0				
	11	VCB	7	0				
	12	ACB	15	0				
	13	Landscape Lighting Panel	0	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	20	0				
	16	Total No. Of Lights	5834	55				15 days
Elevators & Backup Power	17	Lifts	29	0				
	18	DG Sets	6	0				
	19	ARD Batteries	29 Sets	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	6	0				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	735	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	5	0				
	28	Irrigation Pump Panels	5	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	4	0				
	31	Fountain	7	1(2)				158 days
De-watering System	32	Storm Water Pump	8	0	8	0	0	
	33	Oozing Pumps	8	0	8	0	0	
Rain Water System	34	Excess Rain Water Pump	6	0	6	0	0	
	35	Rain Water Harvesting Pits	34	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	11	1(2)				138 days
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	4	0				
	40	Solar Fencing	2	0				
	41	CCTV	91	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	5&9	-				
Air Handling Unit(AHU)	43	Fresh Air	2	0				
	44	STP AHU	1	0				

Sarovar Grande - Equipment Not Working Data			
Category	Total No. Of Lights	Fountain	Outdoor Pool Pumps
S.No	16	31	37
Description of Issue	Lights not working	Pump not working	Pump not working
Root Cause	Due to drivers & LED problem	Due to winding, bearings and impeller damaged	Due to rotor shaft jammed and bearings damaged
Action Required / Planned	Sent for repair	Sent for repair, M/s. Clear water pools replaced one new pump	Sent for repair, M/s. Clear water pools replaced one new pump
Pending from days	15	158	138
Estimation Date	30.04.2019	10.05.2019	10.05.2019
Responsibility	Society	APMS & M/s. Clear water pools	APMS & M/s. Clear water pools
Notified to the concerned	Society	Society	Society

Boulevard - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	1	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	1	0				
	8	Common Supply Panel	1	0				
	9	Bus Duct	1	0				
	10	Distribution Board	10	0				
	11	VCB	0	0				
	12	ACB	4	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	2	0				
	16	Total No. Of Lights	159	25(25)				334 days
Elevators & Backup Power	17	Lifts	0	0				
	18	DG Sets	2	0				
	19	ARD Batteries	0	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	5	3(3)				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	0	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Manual	-				
Water Features	30	Water Body Pumps	3	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	0	0	0	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	2	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	5	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	4	2(2)				281 days
	40	Solar Fencing	2	0				
	41	CCTV	18	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	2	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	0	0				

Boulevard - Equipment Not Working Data			
Category	Total No. Of Lights	Borewells	Boom Barrier
S.No	16	21	39
Description of Issue	Bollard lights problem	Borewell not working	Boom Barriers not working
Root Cause	Due to fixtures problem	Due to low ground water	Due to PCB board problem
Action Required / Planned	Informed to society for procuring new fixtures	Informed to society	Informed to society
Pending from days	334	-	281
Estimation Date	-	-	Society not willing to repair the Boom Barriers - Abended
Responsibility	Society	Society	Society
Notified to the concerned	Society	Society	Society

Gardenia - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	1	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	1	0				
	8	Common Supply Panel	1	0				
	9	Bus Duct	0	0				
	10	Distribution Board	12	0				
	11	VCB	0	0				
	12	ACB	5	0				
	13	Landscape Lighting Panel	0	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	0	0				
	16	Total No. Of Lights	212	5(5)				150 days
Elevators & Backup Power	17	Lifts	0	0				
	18	DG Sets	2	0				
	19	ARD Batteries	0	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	5	1(1)				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	No	-				
	25	PRV's	0	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	2	0				
	28	Irrigation Pump Panels	1	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	0	0				
	31	Fountain	1	0				
De-watering System	32	Storm Water Pump	0	0	0	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	0	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	3	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	4	2				30 days
	40	Solar Fencing	3	0				
	41	CCTV	16	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	1 & 2	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	0	0				

Gardenia - Equipment Not Working Data			
Category	Total No. Of Lights	Borewells	Boom Barrier
S.No	16	21	39
Description of Issue	Lights not working	Borewell not working	Boom Barrier not working
Root Cause	Drivers problem	Borewell abended	Due to sensor problem
Action Required / Planned	Need to replace the drivers. Informed to society for procuring new drivers	-	Inform to vendor & quote received. IOM to be raised
Pending from days	150	-	30
Estimation Date	-	-	-
Responsibility	Society	Society	APMS
Notified to the concerned	Society	Society	APMS

Aura - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	1	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	1	0				
	8	Common Supply Panel	1	0				
	9	Bus Duct	3	0				
	10	Distribution Board	7	0				
	11	VCB	1	0				
	12	ACB	1	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	1	0				
	16	Total No. Of Lights	733	46(46)				106 days
Elevators & Backup Power	17	Lifts	4	0				
	18	DG Sets	2	0				
	19	ARD Batteries	4 Sets	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	3	0				
Metro Water Supply	22	HMWS & SB Meter	1	1(1)				50 days
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	559	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	2	0				
	28	Irrigation Pump Panels	1	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	2	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	1	0	1	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	9	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	3	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	4	0				
	40	Solar Fencing	1	0				
	41	CCTV	20	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	1	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	1	0				

Aura - Equipment Not Working Data		
Category	Total No. Of Lights	HMWS&SB Meter
S.No	16	22
Description of Issue	Lights not working	HMWSSB meter not working
Root Cause	Due to drivers and lights problem	Due to Meter problem
Action Required / Planned	Informed to society for procuring new lights	Informed to HMWSSB (Token no:3032)
Pending from days	106	50
Estimation Date	-	-
Responsibility	Society	Society
Notified to the concerned	Society	Society

Kanopy Tulip - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	0	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	3	0				
	6	Main Pcc Panel	3	0				
	7	APFCR	0	0				
	8	Common Supply Panel	3	0				
	9	Bus Duct	6	0				
	10	Distribution Board	3	0				
	11	VCB	1	0				
	12	ACB	0	0				
	13	Landscape Lighting Panel	2	0				
	14	Club House Panel	2	0				
	15	Lighting Arrestor	2	0				
	16	Total No. Of Lights	605	0				
Elevators & Backup Power	17	Lifts	13	0				
	18	DG Sets	1	0				
	19	ARD Batteries	13 Sets	-				
	20	Partial / Full Backup	500W	-				
Ground Water Source	21	Borewells	4	0				
Metro Water Supply	22	HMWS & SB Meter	0	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	0	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Manual	-				
Water Features	30	Water Body Pumps	0	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	0	0	0	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	0	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	3	2(2)				40 days
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	0	0				
	40	Solar Fencing	1	0				
	41	CCTV	0	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	6	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	0	0				

Kanopy Tulip - Equipment Not Working Data	
Category	Outdoor Pool Pumps
S.No	37
Description of Issue	Outdoor pool pumps not working
Root Cause	Winding problem
Action Required / Planned	Sent for repair
Pending from days	40
Estimation Date	-
Responsibility	Society
Notified to the concerned	Society

County - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	1	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	1	0				
	8	Common Supply Panel	1	0				
	9	Bus Duct	1	0				
	10	Distribution Board	1	0				
	11	VCB	1	0				
	12	ACB	1	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	1	0				
	16	Total No. Of Lights	146	0				
Elevators & Backup Power	17	Lifts	-	0				
	18	DG Sets	2	0				
	19	ARD Batteries	0	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	7	1(1)				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	No	-				
	24	FWS	No	-				
	25	PRV's	0	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	3	0				
	28	Irrigation Pump Panels	1	0				
	29	Irrigation Sprinkler Automation System	Manual	-				
Water Features	30	Water Body Pumps	0	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	0	0	0	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	1	0	1	0	0	
	35	Rain Water Harvesting Pits	60	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	4	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	0	0				
	40	Solar Fencing	1	0				
	41	CCTV	2	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	0	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	0	0				

County - Equipment Not Working Data	
Category	Borewells
S.No	21
Description of Issue	Borewell not working
Root Cause	Due to low ground water
Action Required / Planned	Informed to society
Pending from days	-
Estimation Date	-
Responsibility	Society
Notified to the concerned	Society

Towers - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	1	0				
Electrical Distribution System(LT)	5	Transformers	2	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	2	0				
	8	Common Supply Panel	5	0				
	9	Bus Duct	24	0				
	10	Distribution Board	11	0				
	11	VCB	2	0				
	12	ACB	6	0				
	13	Landscape Lighting Panel	0	0				
	14	Club House Panel	0	0				
	15	Lighting Arrestor	1	0				
	16	Total No. Of Lights	372	0				
Elevators & Backup Power	17	Lifts	19	0				
	18	DG Sets	2	0				
	19	ARD Batteries	0	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	7	7(7)				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	176	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Manual	-				
Water Features	30	Water Body Pumps	0	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	2	0	2	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	4	0				
Swimming Pool	36	Indoor Pool Pumps	No	0				
	37	Outdoor Pool Pumps	Yes	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	2	0				
	40	Solar Fencing	1	0				
	41	CCTV	28	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	3	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	0	0				

Towers - Equipment Not Working Data	
Category	Borewells
S.No	21
Description of Issue	Borewell not working
Root Cause	Due to low ground water
Action Required / Planned	Informed to society
Pending from days	-
Estimation Date	-
Responsibility	Society
Notified to the concerned	Society

Cyber Life - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	1	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	2	0				
	6	Main Pcc Panel	2	0				
	7	APFCR	2	0				
	8	Common Supply Panel	10	0				
	9	Bus Duct	20	0				
	10	Distribution Board	1	0				
	11	VCB	4	0				
	12	ACB	10	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	10	0				
	16	Total No. Of Lights	4055	23(28)				100 days
Elevators & Backup Power	17	Lifts	23	0				
	18	DG Sets	2	0				
	19	ARD Batteries	23 sets	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	4	0				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	432	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	6	0				
	28	Irrigation Pump Panels	6	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	6	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	6	0	6	0	0	
	33	Oozing Pumps	11	0	11	0	0	
Rain Water System	34	Excess Rain Water Pump	2	0	2	0	0	
	35	Rain Water Harvesting Pits	25	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	Yes	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	6	0				
	40	Solar Fencing	2	0				
	41	CCTV	118	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	6 & 12	-				
Air Handling Unit(AHU)	43	Fresh Air	3	0				
	44	STP AHU	1	0				

Cyber Life - Equipment Not Working Data	
Category	Total No. Of Lights
S.No	16
Description of Issue	Lights not working
Root Cause	Due to LED/ Drive failure
Action Required / Planned	Lights to be replaced. Informed to M/s. Syska
Pending from days	100
Estimation Date	30.04.2019 (Work inprogress)
Responsibility	APMS
Notified to the concerned	M/s. Syska

Elixir - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	1	0				
	6	Main Pcc Panel	1	0				
	7	APFCR	1	0				
	8	Common Supply Panel	1	0				
	9	Bus Duct	0	0				
	10	Distribution Board	6	0				
	11	VCB	2	0				
	12	ACB	0	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	0	0				
	16	Total No. Of Lights	68	0				
Elevators & Backup Power	17	Lifts	1	0				
	18	DG Sets	1	0				
	19	ARD Batteries	0	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	6	3				30 Days
Metro Water Supply	22	HMWS & SB Meter	0	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	0	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	0	0				
	31	Fountain	1	0				
De-watering System	32	Storm Water Pump	2	0	2	0	0	
	33	Oozing Pumps	6	0	6	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	0	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	1	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	4	0				
	40	Solar Fencing	2	0				
	41	CCTV	58	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	1	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	0	0				

Elixir - Equipment Not Working Data	
Category	Borewells
S.No	21
Description of Issue	Borewell not working
Root Cause	Due to low ground water
Action Required / Planned	Informed to projects team
Pending from days	30
Estimation Date	-
Responsibility	APMS/ACEPL
Notified to the concerned	ACEPL

Elina - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	2	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	2	0				
	6	Main Pcc Panel	0	0				
	7	APFCR	0	0				
	8	Common Supply Panel	2	0				
	9	Bus Duct	0	0				
	10	Distribution Board	5	0				
	11	VCB	2	0				
	12	ACB	4	0				
	13	Landscape Lighting Panel	1	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	1	0				
	16	Total No. Of Lights	1090	0				
Elevators & Backup Power	17	Lifts	6	0				
	18	DG Sets	1	0				
	19	ARD Batteries	6 sets	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	4	0				
Metro Water Supply	22	HMWS & SB Meter	1	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	1175	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	2	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	2	0	2	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	1	0	1	0	0	
	35	Rain Water Harvesting Pits	5	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	3	0				
	38	Baby Pool	No	-				
Security	39	Boom Barrier	0	0				
	40	Solar Fencing	1	0				
	41	CCTV	30	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	1	-				
Air Handling Unit(AHU)	43	Fresh Air	1	0				
	44	STP AHU	1	0				

Oosman's Everest - Equipment Status as on 31-3-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	0	0				
	2	4 Panel	0	0				
	3	CTPT	1	0				
	4	5 Panel	0	0				
Electrical Distribution System(LT)	5	Transformers	1	0				
	6	Main Pcc Panel	0	0				
	7	APFCR	0	0				
	8	Common Supply Panel	1	0				
	9	Bus Duct	2	0				
	10	Distribution Board	2	0				
	11	VCB	0	0				
	12	ACB	0	0				
	13	Landscape Lighting Panel	0	0				
	14	Club House Panel	1	0				
	15	Lighting Arrestor	3	0				
	16	Total No. Of Lights	414	0				
Elevators & Backup Power	17	Lifts	4	0				
	18	DG Sets	2	0				
	19	ARD Batteries	4 Sets	-				
	20	Partial / Full Backup	100%	-				
Ground Water Source	21	Borewells	2	0				
Metro Water Supply	22	HMWS & SB Meter	0	0				
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	107	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	0	0				
	28	Irrigation Pump Panels	0	0				
	29	Irrigation Sprinkler Automation System	Auto	-				
Water Features	30	Water Body Pumps	0	0				
	31	Fountain	0	0				
De-watering System	32	Storm Water Pump	2	0	2	0	0	
	33	Oozing Pumps	0	0	0	0	0	
Rain Water System	34	Excess Rain Water Pump	0	0	0	0	0	
	35	Rain Water Harvesting Pits	11	0				
Swimming Pool	36	Indoor Pool Pumps	0	0				
	37	Outdoor Pool Pumps	2	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	0	0				
	40	Solar Fencing	1	0				
	41	CCTV	14	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	1	-				
Air Handling Unit(AHU)	43	Fresh Air	0	0				
	44	STP AHU	1	0				