

Towers STP Not working Data		
Category	Raw Sewage Pumps	Air Blowers
S.No	2	3
Description of Issue	One of the Raw sewage pump not working	One of the Air blower not working
Root Cause	Oil seal damaged	Due to the mechanical wear and tear motor winding got damaged
Action Required / Planned	Sent for repair	Third party Price quotation submitted to the Society
Pending from days	120	150
Responsibility	Society	Society
Estimated Date of Completion	-	-
Notified to the concerned	Society	Society