

### Sarovar - Equipment Status as on 31-8-2019

Category	S.No	Description	Total	Not Working	Pumps Status			Total Downtime (Hrs). of Equipment
					Auto	Manual	Off	
Electrical Distribution System (HT)	1	3 Panel	1	0				
	2	4 Panel	NA	-				
	3	CTPT	1	0				
	4	5 Panel	1	0				
Electrical Distribution System(LT)	5	Transformers	4	0				
	6	Main Pcc Panel	8	0				
	7	APFCR	4	0				
	8	Common Supply Panel	7	0				
	9	Bus Duct	28	0				
	10	Distribution Board	25	0				
	11	VCB	13	0				
	12	ACB	4	0				
	13	Landscape Lighting Panel	7	0				
	14	Club House Panel	2	0				
	15	Lighting Arrestor	7	0				
	16	Total No. Of Lights	3393	16(16)				79 days
Elevators & Backup Power	17	Lifts	43	0				
	18	ARD Batteries	43 Sets	0				
	19	DG Sets	16	0				
	20	Partial / Full Backup	100%	0				
Ground Water Source	21	Borewells	13	10(10)				
Metro Water Supply	22	HMWS & SB Meter	1	1(1)				90 days
Water Distribution System	23	DWS	Yes	-				
	24	FWS	Yes	-				
	25	PRV's	784	0				
	26	Sewerage System	Yes	-				
Landscape Water Distribution	27	Irrigation Pumps	14	3(3)				171 days
	28	Irrigation Pump Panels	7	0				
	29	Irrigation Sprinkler Automation System	Auto	0				
Water Features	30	Water Body Pumps	5	0				
	31	Fountain	1	0				Abandoned
De-watering System	32	Storm Water Pump	12	0	12	0	0	
	33	Oozing Pumps	NA	-	-	-	-	
Rain Water System	34	Excess Rain Water Pump	1	0	1	0	0	
	35	Rain Water Harvesting Pits	18	0				
Swimming Pool	36	Indoor Pool Pumps	2	0				
	37	Outdoor Pool Pumps	3	0				
	38	Baby Pool	Yes	-				
Security	39	Boom Barrier	6	0				Abandoned
	40	Solar Fencing(Zones)	4	0				
	41	CCTV	40	0				
Reticulated Piped Gas	42	Gas Bank & Chambers	7 & 28	0				
Air Handling Unit(AHU)	43	Fresh Air	NA	-				
	44	STP AHU	1	0				