

Gardenia STP Not working Data		
Category	Raw Sewage Pumps	De-watering Pump
S.No	2	8
Description of Issue	One of the Raw sewage pump not working	One of the De-watering pump is not working.
Root Cause	Winding problem	Winding problem
Action Required / Planned	Sent for repair	It is beyond economical repair. Informed to society for procuring a new pump under their scope. Third party price quotations was shared to society.
Pending from days	60	167
Responsibility	APMS	Society
Estimated Date of Completion	30.09.2019	-
Notified to the concerned	Society	Society