

| Westside STP Not working Data | |
|-------------------------------|--|
| Category | Raw Sewage Pumps |
| S.No | 2 |
| Description of Issue | Raw sewage pump Not working |
| Root Cause | Auto coupling broken |
| Action Required / Planned | Under warranty. Informed to M/s. Revolve Engineers |
| Pending from days | 30 |
| Responsibility | M/s. Revolve Engineers |
| Estimated Date of Completion | 10.09.2019 |
| Notified to the concerned | APMS |