



VASUDHA

enviro labs Pvt. Ltd

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-65243910 Fax: +91-40-42009193
e-mail: vasudha_enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR - 1804 - 0319
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	30 th March 2019
		REGISTRATION NO.	VEL/240A
		REGISTRATION DATE	15 th March 2019
		CUSTOMER REFERENCE	---
		REFERENCE DATE	---
SAMPLE DESCRIPTION	WTP water - Inlet	ANALYSIS STARTING DATE	16 th March 2019
SAMPLE SITE	Aparna, Sarovar	ANALYSIS COMPLETION DATE	22 nd March 2019
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000 ml	
SAMPLE COLLECTED OR SUBMITTED		By client	

TEST RESULTS

S.NO.	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
Physical & Chemical Parameters					
1	pH	--	IS 3025 P-11	7.6	6.50 - 8.50
2	Conductivity	µs/cm	APHA	540.0	Not Specified
3	Colour	Hazen	IS 3025 P-4	0.1	<5
4	Turbidity	NTU	IS 3025 P-10	0.3	<1
5	Total Dissolved Solids	mg/l	IS 3025 P-16	270.7	<500
6	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	IS 3025 P-23	Nil	Not specified
7	Alkalinity to methyl orange as CaCO ₃	mg/l	IS 3025 P-23	48.8	<200
8	Total Hardness as CaCO ₃	mg/l	IS 3025 P-21	125.3	<200
9	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P-21	76.5	Not specified
10	Calcium as Ca	mg/l	IS 3025 P-40	34.2	<75
11	Magnesium as Mg	mg/l	IS 3025 P-46	11.3	<30
12	Sodium as Na	mg/l	IS 3025 P-45	5.9	Not Specified
13	Potassium as K	mg/l	IS 3025 P-45	1.4	Not Specified
14	Iron as Fe	mg/l	IS 3025 P-53	0.1	<0.3
15	Silica as SiO ₂	mg/l	APHA	5.8	Not Specified
16	Fluoride as F	mg/l	APHA	0.2	<1.0
17	Chlorides as Cl	mg/l	IS 3025 P-32	59.5	<250
18	Sulphates as SO ₄	mg/l	IS 3025 P-24	9.8	<200
19	Nitrates as NO ₃	mg/l	IS 3025 P-34	4.6	<45
20	Chlorine demand	mg/l	APHA	0.3	<1.0

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water specification.



Authorized Signatory



VASUDHA
enviro labs Pvt. Ltd

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-65243910 Fax: +91-40-42009193
e-mail: vasudha.enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR - 1805 - 0319
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	30 th March 2019
		REGISTRATION NO.	VEL/2408
		REGISTRATION DATE	15 th March 2019
		CUSTOMER REFERENCE	---
		REFERENCE DATE	---
SAMPLE DESCRIPTION	WTP water - Outlet	ANALYSIS STARTING DATE	16 th March 2019
		ANALYSIS COMPLETION DATE	22 nd March 2019
SAMPLE SITE	Aparna, Sarovar	STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
		QUANTITY RECEIVED	1000 ml
SAMPLE COLLECTED OR SUBMITTED		By client	

TEST RESULTS

S.NO.	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
Physical & Chemical Parameters					
1	pH	--	IS 3025 P-11	7.1	6.50 - 8.50
2	Conductivity	µs/cm	APHA	240.0	Not Specified
3	Colour	Hazen	IS 3025 P-4	0.1	<5
4	Turbidity	NTU	IS 3025 P-10	0.2	<1
5	Total Dissolved Solids	mg/l	IS 3025 P-16	144.4	<500
6	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	IS 3025 P-23	Nil	Not specified
7	Alkalinity to methyl orange as CaCO ₃	mg/l	IS 3025 P-23	42.3	<200
8	Total Hardness as CaCO ₃	mg/l	IS 3025 P-21	105.4	<200
9	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P-21	63.1	Not specified
10	Calcium as Ca	mg/l	IS 3025 P-40	23.5	<75
11	Magnesium as Mg	mg/l	IS 3025 P-46	11.0	<30
12	Sodium as Na	mg/l	IS 3025 P-45	1.9	Not Specified
13	Potassium as K	mg/l	IS 3025 P-45	0.5	Not Specified
14	Iron as Fe	mg/l	IS 3025 P-53	0.1	<0.3
15	Silica as SiO ₂	mg/l	APHA	2.4	Not Specified
16	Fluoride as F	mg/l	APHA	0.1	<1.0
17	Chlorides as Cl	mg/l	IS 3025 P-32	42.7	<250
18	Sulphates as SO ₄	mg/l	IS 3025 P-24	4.9	<200
19	Nitrates as NO ₃	mg/l	IS 3025 P-34	1.8	<45
20	Chlorine demand	mg/l	APHA	0.1	<1.0

Note: The result relates to sample tested only. Limits are given as per IS 10500-2012 drinking water specification.



Authorized Signatory



VASUDHA

enviro labs Pvt. Ltd

An ISO 9001:2008 & OHSAS 18001:2007 Certified Organization

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-65243910 Fax: +91-40-42009193
e-mail: vasudha.enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VCR - 1826 - 0319
M/s. Aparna Property Management Services, Hyderabad.		REPORT ISSUE DATE	30 th March 2019
		REGISTRATION NO.	VEL/240C
		REGISTRATION DATE	15 th March 2019
		CUSTOMER REFERENCE	--
		REFERENCE DATE	--
SAMPLE DESCRIPTION	STP - Outlet water	ANALYSIS STARTING DATE	16 th March 2019
		ANALYSIS COMPLETION DATE	22 nd March 2019
SAMPLE SITE	Aparna, Sarovar	STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000ml	
Sample Collected		By client	

TEST RESULTS

S. No.	TEST PARAMETERS	UNITS	RESULTS	CPCB NORMS (land for irrigation)
1.	pH	--	7.3	5.5 - 9.0
2.	Total Dissolved Solids	mg/l	455.4	<2100
3.	Total Suspended Solids	mg/l	42.8	<200
4.	Chemical Oxygen Demand	mg/l	30	<250
5.	Biological Oxygen Demand (3 Days @ 27°C)	mg/l	09	<100
6.	Chlorides as Cl	mg/l	147.5	<600
7.	Sulphates as SO ₄	mg/l	10.2	<1000
8.	Oil & grease	mg/l	0.3	<10
9.	Total Hardness as CaCO ₃	mg/l	188.6	Not specified
10.	Calcium as Ca	mg/l	50.4	Not specified
11.	Total Alkalinity as CaCO ₃	mg/l	45.0	Not specified
12.	Nitrates as NO ₃	mg/l	6.8	Not specified
13.	Color	--	0.3	Not specified
14.	Odour	--	Agreeable	Not specified
15.	Turbidity	NTU	4.5	Not specified

Note: The results relate to the sample tested only. TEST METHOD: APHA



Authorized Signatory