

vitro labr

AN ISO 9001-2008 and OHSAS CERTIFIED COMPANY

2-2-647/A/3, 3rd Floor, Shivam Road, Hyderabad-500 013.

Phone: 040-27421389, Fax: 040-27423532, E-mail: labsvitro@yahoo.com, vitrolabs@gmail.com

Web: www.vitrolabs.net, www.vitrolabsindia.com

(Recognized by the Ministry of Environment & Forest, GOI)

TEST CERTIFICATE

Our Ref:	1461/ENV	Issued To:
Reporting Date:	19.03.2019	
Collected On:	12.03.2019	M/s. APARNA PROPERTY MANAGEMENT SERVICES PVT LTD.,
Sample Particulars:	STP INLET	SAROVAR, KANCHI GACHIBOWLI ROAD, NALLAGANDLA, GOPANAPALLI, HYDERABAD,
	A LAND IN COLUMN	TELANGANA-500019.

TEST RESULTS

SI.No.	Parameters	Units	Dogulf
01	Hq	Oints	Result
02	Total Dissolved Solids	(mag)	6.99
03	Total Suspended Solids	(mg/l)	644
04	Chlorides as Cl	(mg/l)	48
05	Sulphates as SO ₄	(mg/l)	123
06	Chemical Oxygen Demand	(mg/l)	42
07	Bio Chemical Oxygen Demand	(mg/l)	1238
08	Oil & Grease	(mg/l)	342
		(mg/l)	0.9

Note: The above parameters are carried out as per IS: 3025 methods

Authorised Signatory

Environmental Studies like **Compressed Air Quality Testing**, Work Zone, Indoor Air Quality, Gravimetric Dust Sampling, Stack, AAQ Monitoring, Waste Water, Solid & Hazardous Waste Analysis and **Analytical Services** like Water, Ores, Minerals, Alloys, Petroleum Products, Food Materials, Soils, Poultry Feeds Etc.



AN ISO 9001-2008 and OHSAS CERTIFIED COMPANY

2-2-647/A/3, 3rd Floor, Shivam Road, Hyderabad-500 013.

Phone: 040-27421389, Fax: 040-27423532, E-mail: labsvitro@yahoo.com, vitrolabs@gmail.com

Web: www.vitrolabs.net, www.vitrolabsindia.com

(Recognized by the Ministry of Environment & Forest, GOI)

TEST CERTIFICATE

Our Ref:	1462/ENV	Issued To:
Reporting Date:	19.03.2019	M/s. APARNA PROPERTY MANAGEMENT SERVICES PVT LTD.
Collected On:	12.03.2019	SAROVAR,
Sample Particulars:	STP OUTLET	KANCHI GACHIBOWLI ROAD, NALLAGANDLA,
		GOPANAPALLI, HYDERABAD,
	TIN I I I I I I I I I I I I I I I I I I	TELANGANA-500019.

TEST RESULTS

SI.No.	Parameters	Units	Result	Limits
01	pH ,		7.21	5.5-9.0
02	Total Dissolved Solids	(mg/l)	608	2100
03	Total Suspended Solids	(mg/l)	42	200
04	Chlorides as Cl	(mg/l)	107	-
05	Sulphates as SO ₄	(mg/l)	38	
06	Chemical Oxygen Demand	(mg/l)	58	100
07	Bio Chemical Oxygen Demand	(mg/l)	18	
08	Oil & Grease	(mg/l)	0.8	10

Note: The above parameters are carried out as per IS: 3025 methods



Environmental Studies like **Compressed Air Quality Testing**, Work Zone, Indoor Air Quality, Gravimetric Dust Sampling, Stack, AAQ Monitoring, Waste Water, Solid & Hazardous Waste Analysis and **Analytical Services** like Water, Ores, Minerals, Alloys, Petroleum Products, Food Materials, Soils, Poultry Feeds Etc.



AN ISO 9001-2008 and OHSAS CERTIFIED COMPANY

2-2-647/A/3, 3rd Floor, Shivam Road, Hyderabad-500 013.

Phone: 040-27421389, Fax: 040-27423532, E-mail: labsvitro@yahoo.com, vitrolabs@gmail.com

Web: www.vitrolabs.net, www.vitrolabsindia.com

(Recognized by the Ministry of Environment & Forest, GOI)

TEST CERTIFICATE

Our Ref:	1463/ENV	Issued To:
Reporting Date:	19.03.2019	M/s. APARNA PROPERTY MANAGEMENT SERVICES PVT LTD.,
Collected On:	12.03.2019	SAROVAR.
Sample Particulars:	SITE STP PERIPHERAL	KANCHI GACHIBOWLI ROAD, NALLAGANDLA,
	OUTLET	GOPANAPALLI, HYDERABAD, TELANGANA-500019.

TEST RESULTS

SI.No.	Parameters	Units	Result
01	pH	N Marie -	6.8
02	Total Dissolved Solids	(mg/l)	662
03	Total Suspended Solids	(mg/l)	44
04	Chlorides as Cl	(mg/l)	130
05	Sulphates as SO ₄	(mg/l)	46
06	Chemical Oxygen Demand	(mg/l)	198
07	Bio Chemical Oxygen Demand	(mg/l)	56
08	Oil & Grease	(mg/l)	1.1

Note: The above parameters are carried out as per IS: 3025 methods

Authorised Signatory

Environmental Studies like **Compressed Air Quality Testing**, Work Zone, Indoor Air Quality, Gravimetric Dust Sampling, Stack, AAQ Monitoring, Waste Water, Solid & Hazardous Waste Analysis and **Analytical Services** like Water, Ores, Minerals, Alloys, Petroleum Products, Food Materials, Soils, Poultry Feeds Etc.