

Sree Mahendra

ANALYTICAL SERVICES

Genuine Zuality Assurance

TS Govt. Regd. No. 591/12, ISO 9001:2015 certified Laboratory

REGD. Off:

1-7-292, Chaithanyapuri,

Opp: Geetha Hospital, Dilsukhnagar,

Hyderabad-500035

Ph: 9133361333, 9866669596

E mail: mail2smasquality@gmail.com

CERTIFICATE OF ANALYSIS

Test Report

Report Ref: SMAS/W/033.08.029/19

In accordance with the order of M/s. Revolve Engineers Pvt.Ltd, Hyderabad. We carried out the following analysis for the given samp'e.

SAMPLE DETAILS:	T					
Sample lab code	:	11283				
Name of the Site	:	M/s.APARNA COUNTY				
Date of Receipt	:	01.08.2019				
Job Ref No	:	SMAS/W/033.08.029/19				
Date of Issue	:	06.08.2019 (Code No: 3706)				
Sample Particulars	1:	06.08.2019 STP INLET WATER (Code No: 3705), OUT LET WATER (Code No: 3706)				
Sampling	:	By Client				
Tests Required	:	As per mail				
Analysis Started on	1:	01.08.2019				
Analysis Completion Date	:	06.08.2019	SED AS RECEIVED BASIS			
Sample Condition	:	Intact SAMPLE ANALYS	JUD AU RUCH.			

TEST RESULTS

The above sample was analysed by us and the results are as follows:

a grander to			UNITS	RESULTS		APPCB
S.No	TEST PARAMETERS			In let-3705	Out let-3706	STANDARDS
				7.71	8.30	5.50 - 9.0
1.	pH Fotal Dissolved Solids	(@180°C)	ppm	710	610	<2100
2.	Total Suspended Solids	(@ 105°C)	ppm	72	23	<200
3.	Chemical oxygen demand	(10,100,0)	ppm	750	46	<250
4,	Biological oxygen demand	(3day @27°C)	ppm	320	13	<100
5.	Chlorides	as CI	ppm	142.10	150.40	<600
6.	Sulphates	as SO ₄	ppm	82.51	86.0	<1000
7.	Oil & Grease	<u></u>	ppm	7.85	<1.00	<10.0
8. 9.	total hardness	as CaCO ₃	ppm	240.24	202.0	Not Specified
10.	Calcium	as Ca	ppm	80.65	45.28	Not Specified
11.	Fotal Alkalinity	as CaCO ₃	ppm	302.0	323.10	Not Specified
12.	Nitrates	as NO ₃	ppm	35.9	9.10	Not Specified
13.	Color			Turbid	Colorless	Not Specified
14.	Odour			Un agrecable	Agreeable	Not Specified
15.	Turbidity		NTU	100.10	6.10	Not Specified
	ROBIOLOGICAL PARAME	TERS				
16.	Coliform Bacteria	cfu/100ml	72x 10 ¹	05	500MPN/100ml	
17.	E.coli		cfu/100ml	Present	Absent	Not Specified
					1	<u></u>

1. The sample is analyzed as per A

2. The certificate relates only to

Small Scale Industries Certified Laboratory



TESTURG-SERVICES