

Questions and Answers in Response to Solicitation W911QY-26-R-GROUNDWATER

Groundwater Pump and Treatment System Operation Semi-Annual Groundwater Monitoring (FY26)

Question 1: We would like to know if this is a brand new contract OR if there is (was) an incumbent performing these services. If not brand new, could you please provide the current / previous contract number?

Answer 1:

This is not a new requirement. The current order number is W911QY20F0409.

Question 2: With regarding to Solicitation W911QY-26-R-GROUNDWATER, Groundwater Pump and Treatment System Operation Semi-Annual Groundwater Monitoring (FY26), the due date for a response is January 30, 2026. Two weeks after the solicitation was released is too short of a period to review all pertinent information, formulate the strategy of responding, develop questions and consider responses, and provide an accurate response. Please move the due date to at least weeks out from the current date to February 20, 2026.

Answer 2:

No, the due date for proposals will not be extended to 20 FEBRUARY 2026.

Question 3: Would the government please provide the reference documentation cited in Attachment A of the Performance Work Statement (page 26)?

Answer 3:

The solicitation on SAM.gov has been amended to include the reference documentation listed in Attachment A of the PWS. Please note: the following "Referenced Document" has been removed from the list in Attachment A:

- Draft Event 78 (Spring 2019) Semi-Annual Data Transmittal for U.S. Army Soldier Systems Center.

Question 4: Could you provide us with the following documents or information so we can put the bid together?

- Last three monthly reports,
- Last Plan, not just the update, but a specific system plan submitted to DOD, EPA, that was approved,
- Site figures, including the locations of wells NRDEC-05, -11, and -16
- System schematics,
- Process and Instrumentation Diagram (PID),
- Tabulated groundwater data with depth to water, and
- Soil boring logs, especially from the recovery wells identified above.

Answer 4:

Last three monthly reports,	Format of the monthly report is to be proposed by winning bidder and agreed by Army.
Last Plan, not just the update, but a specific system plan submitted to DOD, EPA, that was approved,	Recommend they look at the documents provided. Unclear what plan they are referencing...
Site figures, including the locations of wells NRDEC-05, -11, and -16	NRDEC-05, -11, and -16 are not monitoring wells, but areas of the installation that describe specific releases. NRDEC-05 is the T-25 Area. NRDEC-11 is the Buildings 63, 2 & 45 Area. NRDEC-16 is the Buildings 22 & 36 Area. Map showing these areas can be found in multiple places including Figure 1-2 of Groundwater Monitoring Event 89 and 2024 GWETS Annual Report as well as previous year's reports provided.
System schematics, Process and Instrumentation Diagram (PID),	One version is in Figures 1-4 and 1-5 of Natick Draft O&M Manual. Note however that this version predates the removal from service of the air stripper and air-phase carbon from the treatment train.
Tabulated groundwater data with depth to water, and	See Table 2-1 in Groundwater Monitoring Event 89 and 2024 GWETS Annual Report as well as previous year's reports provided.
Soil boring logs, especially from the recovery wells identified above.	Boring logs are scattered through multiple different reports. One reasonable overview can be found in Figure 4 – Geologic Cross Section on the original Record of Decision for T-25 Are Groundwater (April 2001)