

1240LU26Q0007
Questions & Answers Continued

Q23: Would it be acceptable send a certified EPA environmental tester to conduct lead and asbestos testing into the building? Ans: The Statement of Work instructs interested bidders to assume all three (3) building contain lead-based paint and implement best management practices for worker protection and waste disposal.

Q24: Are past ACM test reports available for these buildings? Residence #3 is supposed to get new vinyl flooring. If floor tiles are confirmed to contain asbestos the area would require an abatement contractor. How would you like us to price this work?

Ans: The Statement of Work states ACM will not be encountered. Tiles and layers of flooring from Residence #3 utility room have been test by the US Forest Service and reports show the flooring was tested with results showing No ACM detected.

Please bid the work depicted in Solicitation # 1240LU26Q0007 as it is presented in the Statement of Work and as shown on drawings and specifications for the solicitation only.

Q25: The Davis-Bacon wage rate decision is dated 2010 & seems to be too low. Should we use that rate?

Ans: Wage rates published in General Decision Number: MT20250063 dated 12/12/2025 apply. the resultant contract will use this same one and be the minimum labor rates required on your certified payrolls. It is not uncommon for workers to be paid more that prevailing wage.