

SITE INSPECTION TOUR/PREBID CONFERENCE RECORD

01/22/2026

1. Solicitation No.: 1240LU26Q0007. 4. Meeting Place: Condon Work Center
 2. Title: Condon Bunkhouse Maintenance Repairs 5. Conducted by Name & Title: Patrick Siers
 3. Date & Time: January 22, 2026 11am

7. Attended By: (Attach Separate Sheet, if Necessary)

Name and Firm	Address (include zip code)	Phone No. (include area code)
Big Sky Health, Redtail,	Warnock, Dalco, Blackhawk, Bernardo, MasterStream,	
Semper Fi, Copper Creek,	406 Maintenance, TMT Custom Construction,	
Mr. Remodel, Red Bear,	Home Town, Allied GSD, Rustic Montana Construction,	
Bold Construction,	Montana Builders	
<u>18 Total Perspective Bidders</u>		

8. Questions asked and responses given: (Use Reverse if necessary)

Q1: Is a Contractor responsible to repair imperfections in existing Dry wall? ANs: Yes, Painting preparation includes repairing the Dry wall damage.
 Q2: Bunkhouse door jambs have damaged Mortises must they be repaired? Ans: No, don't plan to replace door jambs or the modified door trim.
 See questions continued on next page.

9. Was a complete site inspection tour made? ☒ Yes ☐ No (If "No," explain)

By (Name): Patrick K Siers Title: COR Date: 1-22-2026