

SOLICITATION FOR OFFERS

N4425526RP00018

Warehouse Space
Puget Sound Naval Shipyard & Intermediate Maintenance Facility, Washington
Naval Sea Systems Command (NAVSEA)

Warehouse Space consisting of:

Minimum 10,000 Square Feet
Maximum 140,000 Square Feet

January 16, 2026

Prepared By:
Naval Facilities Engineering Systems Command Northwest
1101 Tautog Circle
Silverdale, WA 98315-1101

Anna C. Borer
Real Estate Contracting Officer

Questions about this Solicitation for Offers (SFO) must be addressed via electronic mail to the Real Estate Contracting Officer's (RECO) designated representatives at the emails listed herein, and the Subject line should be marked "SFO N4425526RP00018". Offerors are requested to utilize Attachment L-Pre-Proposal Inquiry (PPI) Form to submit questions, clarifications and other requests for general information to the following:

1. seana.k.mckiernan.civ@us.navy.mil
2. nicole.m.leaptrot-figueras.civ@us.navy.mil

All PPIs submitted and answered by the Department of the Navy (DON) will be made available for all interested parties to review as an Amendment to the SFO and posted on SAM.gov. The deadline to submit PPIs is Friday, February 27, 2026, at 11:59PM Pacific Standard Time.

TABLE OF CONTENTS

1.0	SUMMARY OF MINIMUM REQUIREMENTS	6
1.1	AMOUNT AND TYPE OF SPACE.....	6
1.2	AREA OF CONSIDERATION	7
1.3	SPACE CHARACTERISTICS.....	7
1.4	LEASE TERM	8
1.5	EXECUTION.....	8
1.6	OCCUPANCY DATE.....	9
1.7	MINIMUM REQUIREMENTS.....	9
1.8	AVAILABILITY OF FUNDS.....	9
1.9	SYSTEM FOR AWARD MANAGEMENT REGISTRATION	9
2.0	AWARD PROCESS.....	10
2.1	HOW TO OFFER.....	10
2.2	PREPARATION OF OFFERS	12
2.3	ALTERNATIVE OFFERS	13
2.4	WHO MAY SUBMIT AN OFFER	13
2.5	EXPLANATION TO PROSPECTIVE OFFERORS	13
2.6	MULTIPLE OFFERS	13
2.7	AMENDMENTS TO THE SFO	14
2.8	LIMITATION	14
2.9	NEGOTIATIONS.....	14
2.10	EVALUATION FACTORS	14
2.11	AWARD	15
3.0	MISCELLANEOUS.....	16
3.1	UNIT COSTS FOR ADJUSTMENTS.....	16
3.2	SUBSEQUENT TENANT ALTERATIONS \$100,000 OR LESS.....	16
3.3	SPECIFIED AREAS.....	17
3.4	ANSI/BOMA OFFICE AREA(ABOA) SQUARE FEET.....	17
3.5	COMMON AREA FACTOR	17
3.6	APPURTENANT AREAS.....	17
3.7	LIQUIDATED DAMAGES.....	17
3.8	ADJUSTMENT FOR VACANT PREMISES.....	18
3.9	AFTER AWARD	18
3.10	CONSTRUCTION SCHEDULE	19
3.11	EVIDENCE OF CAPABILITY TO PERFORM – AFTER AWARD	20
3.12	PROGRESS REPORTS	20
3.13	CONSTRUCTION INSPECTIONS	21
3.14	GREEN LEASE COMPLIANCE	21
3.15	WAIVER OF RESTORATION.....	22
4.0	GENERAL ARCHITECTURE.....	22
4.1	QUALITY AND APPEARANCE OF BUILDING EXTERIOR.....	22
4.2	CONSTRUCTION WASTE MANAGEMENT	22
4.3	EXISTING FIT-OUT, SALVAGED, OR RE-USED BUILDING MATERIAL.....	23
4.4	INDOOR AIR QUALITY DURING CONSTRUCTION.....	24
4.5	WORK PERFORMANCE	25
4.6	BUILDING SYSTEMS	25
4.7	SPACE EFFICIENCY	25
4.8	FLOOR PLANS AFTER OCCUPANCY	25
4.9	CAD AS-BUILT FLOOR PLANS.....	25
4.10	FLOORS AND FLOOR LOAD (FOR WAREHOUSE SPACE REQUIREMENTS)	25

4.11	RACKING.....	26
4.12	EXITS AND ACCESS	26
4.13	WINDOWS	26
4.14	ACCESSIBILITY.....	27
5.0	ARCHITECTURAL FINISHES	27
5.1	RECYCLED CONTENT PRODUCTS (COMPREHENSIVE PROCUREMENT GUIDELINES).....	27
5.2	LAYOUT, FINISHES, AND COLORBOARDS	27
5.3	WOOD PRODUCTS	28
5.4	ADHESIVES AND SEALANTS.....	28
5.5	INSULATION: THERMAL, ACOUSTIC, AND HVAC.....	28
5.6	CEILINGS.....	28
5.7	WALL FINISHES	29
5.8	PAINTING	30
5.9	DOORS: EXTERIOR (FOR WAREHOUSE SPACE REQUIREMENTS)	31
5.10	DOORS: SUITE ENTRY	31
5.11	DOORS: INTERIOR	32
5.12	DOORS: HARDWARE	32
5.13	DOORS: IDENTIFICATION.....	32
5.14	PARTITIONS: GENERAL	33
5.15	PARTITIONS: PERMANENT.....	33
5.16	PARTITIONS: SUBDIVIDING	33
5.17	FLOOR COVERING AND PERIMETERS	34
5.18	CARPET TILE.....	35
5.19	ACOUSTICAL REQUIREMENTS	36
5.20	WINDOW COVERINGS	37
6.0	MECHANICAL, ELECTRICAL, PLUMBING.....	37
6.1	MECHANICAL, ELECTRICAL, PLUMBING: GENERAL	37
6.2	ENERGY INDEPENDENCE AND SECURITY ACT (SEPT 2013).....	38
6.3	ENERGY COST SAVINGS	40
6.4	DRINKING FOUNTAIN	40
6.5	TOILET FACILITIES.....	40
6.6	JANITOR CLOSETS	41
6.7	HEATING AND AIR CONDITIONING	42
6.8	VENTILATION	43
6.9	VENTILATION: TOILET ROOMS	44
6.10	ELECTRICAL: GENERAL	44
6.11	ELECTRICAL: DISTRIBUTION.....	44
6.12	TELECOMMUNICATIONS AND DATA WIRING: GENERAL	45
6.13	TELECOMMUNICATIONS: DISTRIBUTION AND EQUIPMENT	45
6.14	TELECOMMUNICATIONS: LOCAL EXCHANGE ACCESS	46
6.15	DATA DISTRIBUTION	47
6.16	ELECTRICAL, TELEPHONE, DATA FOR SYSTEMS FURNITURE	47
6.17	ELEVATORS	48
6.18	LIGHTING: INTERIOR AND PARKING	49
6.19	BREAKROOM	50
7.0	UTILITIES, MAINTENANCE, SERVICES	50
7.1	UTILITIES, MAINTENANCE, SERVICE: GENERAL.....	50
7.2	NORMAL HOURS.....	50
7.3	OVERTIME USAGE	51
7.4	UTILITIES	51
7.5	JANITORIAL SERVICES.....	52

7.6	LANDSCAPE MAINTENANCE	53
7.7	PEST CONTROL	53
7.8	FLAGPOLE.....	53
7.9	TRASH REMOVAL.....	53
7.10	SNOW REMOVAL	53
7.11	MAINTENANCE AND TESTING OF SYSTEMS.....	54
7.12	SERVICE CALLS	54
8.0	SAFETY AND ENVIRONMENTAL MANAGEMENT	55
8.1	CERTIFICATE OF OCCUPANCY	55
8.2	ENVIRONMENTAL CONSIDERATION.....	55
8.3	ENVIRONMENTAL DUE DILIGENCE	55
8.4	NATIONAL ENVIRONMENTAL POLICY ACT (NEPA)	56
8.5	NATIONAL HISTORIC PRESERVATION ACT REQUIREMENTS	57
8.6	FIRE PROTECTION AND LIFE SAFETY	57
8.7	AUTOMATIC FIRE SPRINKLER SYSTEM	58
8.8	FIRE ALARM SYSTEM.....	58
8.9	SEISMIC SAFETY.....	59
8.10	OSHA REQUIREMENTS	59
8.11	ASBESTOS	59
8.12	INDOOR AIR QUALITY	60
8.13	RADON IN AIR.....	61
8.14	HAZARDOUS MATERIALS	61
8.15	RECYCLING	61
8.16	OCCUPANT EMERGENCY PLANS.....	61
9.0	LEASE SECURITY STANDARDS.....	62
9.1	DETERRENCE TO UNAUTHORIZED ENTRY	62
9.2	ACCESS TO UTILITY AREAS.....	62
9.3	EMERGENCY POWER TO CRITICAL SYSTEMS (TENANT IMPROVEMENTS).....	62
9.4	MECHANICAL AREAS AND BUILDING ROOFS	62
9.5	ACCESS TO BUILDING INFORMATION	63
9.6	POSTING OF GOVERNMENT RULES AND REGULATIONS (TENANT IMPROVEMENTS)	63
9.7	BUILDING SECURITY PLAN	63
9.8	ADDITIONAL SECURITY MEASURES AS DETERMINED BY THE GOVERNMENT.....	63
9.9	IDENTITY VERIFICATION OF PERSONNEL	63
9.10	ENTRY SECURITY: INTRUSION DETECTION SYSTEM WITH CENTRAL MONITORING CAPABILITY.....	64
9.11	ENTRY SECURITY: PEEPHOLES (TENANT IMPROVEMENT)	65
9.12	SECURE HVAC: AIRBORNE HAZARDS	65
9.13	TEMPORARY SECURITY UPGRADE DUE TO IMMEDIATE THREAT	65

ATTACHMENTS:

- A. WAREHOUSE REQUIREMENTS
- B. AREA OF CONSIDERATION MAP
- C. SF 2 FORM, U.S. GOVERNMENT LEASE FOR REAL PROPERTY
- D. GSA FORM 3517B, GENERAL CLAUSES
- E. GSA FORM 3518, REPRESENTATIONS AND CERTIFICATIONS
- F. PROPOSAL TO LEASE SPACE
- G. GSA FORM 3516, SOLICITATION PROVISIONS.
- H. FORM 12000, PRE-LEASE FIRE PROTECTION AND LIFE SAFETY EVALUATION
- I. CERTIFICATE OF SEISMIC COMPLIANCE
- J. PRE-LEASE BUILDING SECURITY PLAN
- K. SECURITY REQUIREMENTS – FACILITY SECURITY LEVEL II
- L. PRE-PROPOSAL INQUIRY (PPI) FORM

1.0 SUMMARY OF MINIMUM REQUIREMENTS

1.1 AMOUNT AND TYPE OF SPACE

- A. The Department of the Navy, hereinafter referred to as “Government” and/or “Tenant”, seeks to award one or more 5-year lease(s), with five (5) one-year renewal options near Bremerton, Washington. The Government seeks a minimum of 10,000 to a maximum of 140,000 square feet of warehouse space. Ancillary space is required within or adjacent to the warehouse to support occupancy for 10-25 Government personnel. Such space may be located within the warehouse or in separate interior or exterior structures and must be climate controlled.

Space offered must be in a quality building of sound and substantial construction, either a new, modern building or one that has undergone restoration or rehabilitation for the proposed use. Offerors may propose spaces that require restoration and rehabilitation or spaces that would be new construction or build-to-suit (BTS), but this must be outlined in the Offerors’ proposal and detail how such spaces will meet the Government’s requirements.

The Offeror shall design and propose a layout that optimizes functionality, details space utilization and finishing elements, and complies with applicable federal, state and local building code. The proposed layout should accommodate the requirements as described in Attachment A while ensuring efficient workflow, accessibility and safety.

Section 4.0 and Section 5.0 of this SFO reflect the Government’s preferences for general architecture and architectural finishes as well as performance for completion of such tenant improvements (TI). Offerors are recommended to use these sections as a guide for assessing the level of work and costs associated with offering space to meet the Government’s requirements

A single Offeror may submit an offer covering all or part of the needs identified in this solicitation as described in Attachment A. The rentable space shall yield a net interior square footage in accordance with minimum requirements as described in Attachment A, plus inside corridors available for use by Government for personnel, furnishings, and equipment. Unless otherwise noted, all references in this SFO to SQFT shall mean American National Standards Institute/Building Owners and Managers Association (ANSI/BOMA) SQFT.

The Navy reserves the right to award multiple leases using this Solicitation for Offers as required. The use of space will be for Government purposes.

B. UTILITIES, MAINTENANCE AND SERVICES:

The Government seeks a full-service lease inclusive of all utilities, maintenance and janitorial services associated with the proposed property and as described in Section 7 of this SFO.

Utilities shall include electricity, gas, water, sewer, internet and phone service. Maintenance shall include HVAC, interior maintenance, painting, replacement of lamps, tubes and ballasts, window washing, fence repair and maintenance, parking lot maintenance, exterior site and landscaping services including snow removal, and commercial waste and

disposal services. Janitorial services shall include all cleaning services necessary to maintain the leased space in a clean and acceptable condition, including carpet cleaning, light bulb replacement, trash removal, window cleaning, provision of janitorial cleaning supplies and restroom paper products.

All utilities, maintenance and services shall be provided twenty-four (24) hours per day, seven (7) days per week, including federal holidays. Janitorial services shall be performed during the Government's working hours as defined in Section 7.2.

If the Offeror is unable to provide any required utilities, maintenance, or janitorial services, the Offeror shall clearly identify in its proposal which services will be provided.

C. PARKING REQUIREMENT:

The Offeror should include parking that meets local government code requirements and/or provide a minimum of one parking space for every 1,000 SF of rentable space. Space must be able to receive daily business mail and packages during the business week.

An offer will be considered stronger if it can accommodate parking commensurate with the total warehouse space square footage proposed. For space between 10,000 and 140,000 square feet parking to include a minimum of 10 to 25 parking spaces, with the number of spaces increasing proportionally as total building square footage increase as described in Attachment A.

If an Offeror is unable to provide minimum parking spaces as required by local government code or a minimum of one parking space for every 1,000 SF of rentable space, they must detail how many spaces will be provided.

1.2 AREA OF CONSIDERATION

Space(s) offered must be located within a 40-mile driving range from the Puget Sound Naval Shipyard (PSNS), Bremerton, WA, Farragut Gate as detailed in Attachment B, Area of Consideration.

1.3 SPACE CHARACTERISTICS

- A. Space offered shall comply with all applicable federal, state and local building codes and life and safety criteria. When the applicable codes conflict, the more stringent standard shall apply.
- B. Space shall comply with requirements of Federal, Department of Defense (DoD) unified facility Criteria (UFC) 3-600-01, state, and local fire and life safety standards.
- C. The offered space construction shall comply with DoD Minimum Antiterrorism Standards for Buildings, Unified Facilities Criteria (4-010-01), Seismic Design of Buildings (3-310-04), Standards of Seismic Safety for Existing Federally Owned and Leased Buildings, NIST GCR

110917-12 of December 2011, and applicable sections of Unified Facility Criteria DoD Building Code (1-200-01).

- D. The offered space shall meet the construction requirements of the Architectural Barriers Act (ABA) Standards. This includes the facility and all leased space (entrance areas, parking, accessible route, entrance and egress, ramps, stairs, handrails, alarms, doors, restrooms, drinking fountains, and elevators).
- E. Facilities must meet security standards (Facilities Security Level II) as required by UFC 4-010-01, Change 1, 1 October 2013 which states the security standards established by the Department of Homeland Security's Interagency Security Committee (ISC) in The Risk Management Process for Federal Facilities shall apply to all off installation leased space managed by the DoD. In accordance with these ISC standards, the Navy will conduct a security survey for each facility offered and determine a risk rating. The Navy will determine from that risk rating if the property is acceptable or unacceptable. Offers must receive an acceptable security risk rating from the Navy in order to be eligible for award. The security survey may take up to forty-five (45) days following receipt of offers and must be completed prior to award. For more information, go to: https://www.cisa.gov/sites/default/files/2025-11/The_Risk_Management_Process_2024_Edition.pdf

1.4 LEASE TERM

The lease term will be a five-year lease, with five (5) one-year renewal options. The Government may terminate this lease without cost and in the best interests of the Government, in whole or in part, providing one hundred and twenty (120) days' written notice to the Offeror. Termination shall be at no cost to the Government unless the Lessor has incurred documented, reasonable, and necessary TI costs prior to the termination date that have not been reimbursed or amortized through rental payments. In such a case, the Government shall compensate the Lessor for the unpaid portion of such TI costs as the sole termination fee. The Lessor must submit a detailed itemization of these costs, along with supporting documentation, within sixty (60) days of the Government's termination notice. Any disputed amounts shall be subject to resolution in accordance with the Disputes clause of this lease.

All terms and conditions contained herein shall prevail throughout the term of the lease. The Government reserves the right to award additional leases using this SFO as required.

1.5 EXECUTION

- A. After the conclusion of negotiations, if they are held, the RECO will require the Offeror(s) selected for award to execute the proposed lease prepared by Naval Facilities Engineering Systems Command Northwest, which reflects the proposed agreement of the parties. The proposed lease shall consist of:
 1. Attachment C, Standard Form 2 U.S. Government Lease for Real Property,
 2. Attachment D, GSA Form 3517B, General Clauses,
 3. Attachment E, GSA Form 3518, Required Representations and Certifications,

4. The pertinent provisions of the offer, and
 5. The pertinent provisions of the SFO.
- B. The acceptance of the offer and award of the lease by the Government occurs upon notification of acceptance of the offer or execution of the lease by the RECO and emailing or otherwise furnishing written notification or the executed lease to the successful Offeror.
- C. The Government reserves the right to award the lease without discussions. The Government reserves the right to not award to any Offeror and cancel this SFO if it deems appropriate without liability or cost to the Government.

1.6 OCCUPANCY DATE

With respect to the evaluation factors detailed in Section 2.10 of this SFO, the Government seeks to occupy space meeting the requirements of this SFO as soon as possible. Per Section 2.1 How to Offer, D. Part B. Technical Data, Item 3., Offerors are required to present a high-level schedule that details delivery of a complete and usable space ready for Government occupancy. In the event an Offeror wishes to submit a proposal for two or more of the space requirements described in Section 1.1.A. and in Attachment A, the Offeror must clearly articulate this in their proposed schedule.

1.7 MINIMUM REQUIREMENTS

The requirements listed within Section 1 and Sections 3 through 9 of this SFO are all minimum requirements of the lease.

1.8 AVAILABILITY OF FUNDS

Award of this lease and all agreements related to the obligation of the Government to make payments pursuant to the award of this lease contemplated in this SFO are subject to U.S. Law and the availability of appropriations. Award of any lease under this SFO is contingent upon the availability of appropriated funds from which payments for contract purposes can be made. No legal liability on the part of the Government under this SFO or for any payment may arise until funds are made available to the RECO for a lease and until legally obligated by a fully executed lease contract. In the event sufficient funds are not made available, the Government may not make an award under this SFO.

1.9 SYSTEM FOR AWARD MANAGEMENT REGISTRATION

The Offeror must have an active registration in the System for Award Management (SAM) formerly Central Contractor Registration (CCR) Vendor Registration via the Internet at <https://sam.gov> prior to Lease award and throughout the life of the Lease. Offeror(s) awarded a lease must update or renew registration annually and provide evidence of renewal to the Government. The Government will not process rent payments to an awarded Offeror (Lessor) without an active SAM Registration. The Government only recognizes changes of ownership of the leased Premises after the new owner registers with the SAM system. Additionally, both new and old owners must comply with the procedures established by FAR 42.12 before the Government will recognize a change in ownership.

2.0 **AWARD PROCESS**

2.1 **HOW TO OFFER**

- A. Offers must be received no later than 12:00 PM Pacific Standard Time on Friday, March 20, 2026, and must remain open until award. Be advised that the award may be made based on initial offers without discussion. If necessary, discussions will be held with all Offerors in the competitive range should one be established. Offers shall be submitted electronically via email to DoD SAFE (Secure Access File Exchange) website <https://safe.apps.mil/>. In order to submit a proposal through the DoD SAFE website, Offerors must Request the RECO's designated representatives identified in this SFO N4425526RP00018 to initiate a 'Request a Drop-Off'. Offerors must initiate this request via email to Seana McKiernan seana.k.mckiernan.civ@us.navy.mil and Nicole Leaptrot-Figueras, nicole.m.leaptrot-figueras.civ@us.navy.mil. Offerors will then receive an automated email from DoD SAFE containing the instructions for uploading the file(s). Instructions on how to use DOD SAFE can be found here: <https://safe.apps.mil/>. Submissions must be received by the due date and time listed above.
- B. Format of Offer: Offers must be divided into two separate parts, Part A, Cover Letter with Rental Offer and Part B, Technical Data. On the subject line of all submittals, offers must be marked with the SFO number assigned to this SFO. Example: "SFO N4425526RP00018". If Offeror elects to make multiple offers each submission must be submitted via DoD SAFE website separately. Offers, and any subsequent modifications thereof, shall be submitted via DoD SAFE website addressed to the RECO on or before the due date for offers. Offers shall conform to all instructions set forth in this SFO. Modifications of offers may also be submitted via DoD SAFE website to Sean McKiernan at seana.k.mckiernan.civ@us.navy.mil and Nicole Leaptrot-Figueras at nicole.m.leaptrot-figueras.civ@us.navy.mil on or before the due date for offers.

C. **PART A, Cover Letter with Rental Offer:**

The Offeror shall include with its proposal a dated cover letter on its letterhead stationery formally responding to the SFO. The cover letter shall be signed by the Offeror and all persons or entities, other than limited partners, who will have a financial interest in the project. Erasures or other changes to the cover letter must be initialed by the person(s) signing the offer. Pages should be numbered. The letter should reference this SFO by "SFO N4425526RP00018" and contain the information listed below.

1. The name of the Offeror and confirmation that the Offeror and owner are not U.S. Government employees.
2. Name and telephone numbers of the person(s) authorized to negotiate and execute any resulting lease; internet e-mail address if such communication is accepted; alternate point of contact and phone numbers.

3. Written acknowledgement and permission to represent other owners for the same SFO if a leasing agent or owner's representative is presenting buildings for multiple ownership groups.
4. Provide appropriate evidence of ownership of the property. If the Offeror is not the owner, provide evidence of the Offeror's authority to act for the property owner. Offer signed by an agent shall be accompanied by an original signed document, evidencing the agent's authority to offer the leased space.
5. Identification and location of the property offered.
6. Confirmation the space will meet all minimum specifications, provisions, clauses, terms and conditions of the solicitation and lease, and that the offer remains valid through award unless earlier withdrawn. Include acknowledgement that all pages of the SFO including Attachments were received by the Offeror.
7. Provide the rental offer and breakdown using Attachment F, Proposal to Lease Space. Total annual rent for the initial five (5) year term and for each subsequent option year must be a fixed, level amount and must include all applicable taxes and items listed in 1.1B "Utilities, Maintenance & Services". Rent shall be paid monthly and in arrears.
8. Completed GSA Form 3518, Representations and Certifications (initial all pages). Paragraph 12 of Attachment E is referring Offerors to ensure they are registered in the System for Award Management (SAM) system at <https://sam.gov/>. Section 1.9 of this SFO references this with useful instructions to register in SAM as well.
9. Completed Security Requirements-Facility Security Level II Form (initial all pages)

D. PART B, Technical Data: Include a summary which provides the following:

1. Explanation of how the proposed space will provide an efficient layout for the related space requirement described in Attachment A, including location of space within the building. Preferred documentation is a layout sketch at 1/8" = 1' scale (or larger standard scale) showing location and measurement of existing and/or proposed windows, loading dock(s), entrances and exits of the building, type of construction, interior finishes of walls and ceilings in all habitable rooms, corridors and exit-ways within the space. The proposed location of all spaces should be described in ANSI/BOMA square footage measurements. Offeror should provide a description and location of parking and indicate which spaces are reserved for Government use or shared by other tenants. Additionally, Offerors should provide a description of exterior door construction, direction, and lock type.
2. A location map and statement of distance from PSNS, Bremerton, WA, Farragut Gate. Offered location must be within a forty (40) mile driving distance of Puget Sound Naval Shipyard, Bremerton WA, Farragut Gate.

3. A high-level schedule that details delivery of a complete and usable space ready for Government occupancy subject to award of lease. As applicable, the Government's preferred milestones in the high level schedule consist of (1) date of final layout approval by the Government, (2) 60% completion date, (3) date when Offeror can install systems and furniture, fixtures and equipment, (4) date when Government telephone/data equipment can be installed, (5) date when Government can move equipment into space, (6) date of preliminary acceptance inspection, and (7) date space will be complete and useable for the Government to occupy.
 4. A brief narrative that discloses all deviations from the current local building codes for new structures, including those permitted by so-called "grandfather clauses."
 5. A brief narrative that explains whether and how the property has addressed compliance with the security standards as described in this SFO.
 6. A brief narrative that explains exterior landscaping and drainage direction.
 7. Interior and exterior photos of the existing facilities.
 8. At least one (1) but not more than three (3) examples demonstrating the Offeror's ability to successfully accomplish the necessary TI and/or manage the lease including utilities, maintenance and janitorial services.
 9. A completed Attachment H, Form 12000 Pre-lease Fire Protection and Life Safety Evaluation.
 10. Any other information (such as a fact sheet, color photograph, site plan, location map, and tax parcel map) in cases of multiple tax parcels for an offered building, etc., in order for the Government to perform a complete and adequate analysis of the offered property. Such information may also be requested by the Government, and in such circumstances, shall be submitted by the Offeror within five (5) working days of the request.
- E. Refer to Attachment G, GSA Form 3516 Solicitation Provisions, for additional instructions. If additional information is needed, the RECO (or the RECO's designated representative) should be contacted at the email addresses listed on the cover of this SFO.

2.2 PREPARATION OF OFFERS

- A. Offerors are expected to carefully examine the drawings, specifications, schedules, and all other information and instructions contained in this SFO. Failure to do so will be at the Offeror's risk.
- B. Failure to prepare, format, and submit all information required by this SFO, including all sections and Attachments, will be at the Offeror's risk.

- C. All proposals, presentations, and accompanying information, including post-award submittals by the Offeror, shall be made and submitted in accordance with the directions contained in this SFO. An Offeror's inability to comply with the submission format may, at the Government's option, result in disqualification and removal of an Offeror from consideration under this SFO.

2.3 ALTERNATIVE OFFERS

The Government recognizes that the requirements established in this SFO may not conform to the Offeror's practices. Offerors may submit offers that are alternative to the requirements of this SFO and attachments at their own discretion. Acceptance of an alternative offer is a unilateral decision made solely at the discretion of the Government. Offers that do not comply with the requirements specified in the SFO may be determined to be nonresponsive or unacceptable by the Government.

2.4 WHO MAY SUBMIT AN OFFER

An Offeror may be an individual, partnership, corporation, or association.

The forming of a Joint Venture, an association of two or more persons, corporations, partnerships, and/or associations, to carry out a single business enterprise for profit, for which purposes the parties combine their property, money, efforts, skill and knowledge, is considered an acceptable business entity under this SFO. However, if the Offeror is a Joint Venture, it must (1) be established prior to the submission of initial offers, and (2) the initial offer submitted must contain the Agreement for Joint Venture or similar documentation signed by all participating parties.

2.5 EXPLANATION TO PROSPECTIVE OFFERORS

A prospective Offeror desiring an explanation or interpretation of the SFO, specifications, or other related information, must request such explanation in writing addressed to the RECO at the email addresses provided on the cover of this SFO, and marked "SFO N4425526RP00018" at least twenty-one (21) days prior to the due date for receipt of offers. Verbal explanations or instructions are not binding on the Government. Any information given to a prospective Offeror concerning the SFO will be furnished promptly to all other prospective Offerors if that information is necessary in submitting proposals or if the lack of the information would be prejudicial to other prospective Offerors.

2.6 MULTIPLE OFFERS

Offeror(s) may submit multiple offers. If an Offeror elects to make multiple offers each submission must be submitted separately via DoD SAFE website. Separately price each offer and distinctly mark each package and page so that if the pages become separated, the reader can clearly identify what offer the package or page applies to. Each offer shall meet the requirements of this SFO separately to enable evaluation without the need to request additional information.

2.7 AMENDMENTS TO THE SFO

This SFO shall not be changed or amended except by a formal written Amendment signed by the RECO. Should this SFO be amended, all record holders of the SFO will be provided a copy of the Amendment. If this SFO is amended, all terms and conditions which are not modified shall remain unchanged and shall continue in full force and effect. Offerors shall acknowledge receipt of any Amendment by signing and returning one copy of the Amendment to the RECO. The RECO must receive the signed acknowledgement of the Amendment by the time and at the place specified in the SFO for the receipt of offers.

2.8 LIMITATION

The Government shall not bear any costs associated with the preparation of Offeror's responses to this SFO or the Offeror's post-award submissions and actions required by this SFO. This SFO shall not be interpreted as a contract, a promise to contract, or a commitment of any kind on the part of the United States Government, and any costs to prepare a proposal are the sole responsibility of the Offeror.

2.9 NEGOTIATIONS

- A. Discussions, if any, will be conducted on behalf of the Government by the RECO or the RECO's designated representative. The RECO is named on the cover of this SFO. The Government will negotiate rental price for the initial term, any renewal periods, and any other aspect of the offer as deemed necessary.
- B. The Offeror shall not enter into negotiations concerning the space leased or to be leased with representatives of Government other than the RECO or the RECO's designee(s).
- C. The Government reserves the right to award based on initial offers and not conduct discussions. The Government may conduct written discussions with responsible Offerors within the competitive range, should one be established by the Government. If established, the range will be determined by the RECO on the basis of cost or price and other factors that are stated in this SFO and will include all of the most highly rated offers, unless the range is further reduced for purposes of efficiency. Offerors will be provided a reasonable opportunity to submit any cost or price, technical, or other revisions to their offers that may result from discussions, if held. The Government will provide written notification to Offerors selected or non-selected for competitive range, if applicable.
- D. Offerors within the Competitive Range, if established, will be provided a reasonable opportunity to submit any cost or price, technical, or other revisions to their offers that may result from the discussions. Discussions will be closed with submission of final offer revisions ("Best and Final offers").

2.10 EVALUATION FACTORS

- A. The lease will be awarded to the Offeror whose offer is of best value to the Government.

“Best value” is defined as: the most advantageous tradeoff between price and performance for the government. Best value is determined through a process that compares strengths, weaknesses, risk, price and performance, to select the most advantageous value to the Government. Any proposal found to have a deficiency in meeting the stated SFO requirements or performance objectives will be considered ineligible for award, unless the deficiency is corrected through discussion.

The tradeoff process is selected as appropriate for this acquisition. The Government considers it to be in its best interest to allow consideration of award to other than the lowest priced Offeror or other than the highest technically rated Offeror.

1. Factor 1 – Price: Price is defined as the total cost across the total term of the lease. Total lease cost includes base rent and all items listed in 1.1 B “Utilities, Maintenance, and Services” for the base year and all option years, plus tenant improvements, build out costs and any other applicable costs.
 2. Factor 2 – Space Capacity: The Government’s space requirements, as described in Attachment A, range from 10,000 to 140,000 square feet. Offerors proposing more square footage within this range may be rated more favorably.
 3. Factor 3 – Location: The space must be located in within a 40-mile driving range from the Puget Sound Naval Shipyard (PSNS), Bremerton, WA, Farragut Gate. Facilities outside this delineated area will be ineligible for award. Space that is closer in proximity to PSNS, Bremerton, WA, Farragut Gate, may be evaluated more favorably than space located further from PSNS, Bremerton, WA, Farragut Gate.
 4. Factor 4 – Delivery Time & Useable Space: Offerors that can clearly articulate in their proposal a timely delivery of a complete and useable space meeting the requirements of this SFO for the Government to occupy may be rated more favorably. To support review of this evaluation factor, Offerors should provide a detailed, high-level schedule outlining their proposed delivery schedule of a complete and useable space for the Government to occupy upon lease award.
- B. Factor 2 is substantially more important than Factors 3 and 4, which are equal to each other. When combined, Factors 2, 3, 4 are equal to Factor 1, price. The importance of price increases when the non-price factors are essentially equal.

2.11 AWARD

The Government anticipates, but cannot guarantee, award of the lease no later than June 30, 2026, and lease execution no later than July 31, 2026.

The lease will be awarded to the responsive Offeror(s) who submits an offer which is determined to be the best value to the Government. The Government may, however, at its option: (1) choose to reject any and all offers without a requirement for justification, or (2) accept initial offers

without discussions, or (3) award to other than the lowest priced Offeror or other than the highest technically rated Offeror.

The Government may accept an offer whether or not there are discussions after its receipt, unless a written notice of withdrawal is received before award. Discussions conducted after receipt of an offer do not constitute a rejection or a counteroffer by the Government. Offerors may be requested to submit Best and Final Offers in the form of an executed Standard Form 2, with General Clauses and details of the space offered, sufficient for final execution by the Navy's RECO. The Navy may execute the lease by signing the offered document, or by issuing an award letter with a final lease document to follow upon completion of any remaining Government due diligence. A written notice of award or acceptance of offer signed by the RECO and mailed or otherwise furnished to the Offeror shall result in a binding contract without further action by either party.

Neither financial data submitted with an offer, nor representations concerning financing, will form a part of the resulting lease. However, if the resulting lease contains a clause providing for price reduction for defective cost or pricing data, the lease price will be subject to reduction if the cost or pricing data furnished is incomplete, inaccurate, or not current.

3.0 MISCELLANEOUS

3.1 UNIT COSTS FOR ADJUSTMENTS

A. The Offeror is required to state in the offer, or in an attachment, unit prices for the items listed below. Prices shall be quoted as fully installed and finished. The unit prices may be used, upon acceptance by the Government, during the first year of the lease to price alterations costing \$100,000 or less. These prices may be indexed or renegotiated to apply to subsequent years of the lease upon mutual agreement of the Offeror and the Government:

1. The cost per linear foot of office subdividing ceiling-high partitioning.
2. The cost per wall-mounted duplex electrical outlet.
3. The cost per wall-mounted fourplex (double duplex) electrical outlet.
4. The cost per dedicated clean electrical computer receptacle.
5. The cost per interior door.

3.2 SUBSEQUENT TENANT ALTERATIONS \$100,000 OR LESS

A. The Offeror may be requested to provide alterations during the term of the lease. The two sections from Attachment C, SF 2 Form U.S. Government Lease for Real Property and Attachment D, GSA Form 3517B General Clauses; 552.270-31(a) *Payment due date* and 552.270-31(b) *Invoice and inspection requirements for payments other than rent*, apply to orders for alterations. All orders are subject to the terms and conditions of this lease.

B. Orders may be placed by the RECO and documented by lease modification. The RECO may provide the Offeror with a list of Tenant Agency officials authorized to place orders and will specify any limitations on the authority delegated to Government officials.

3.3 SPECIFIED AREAS

The specified areas in Section 1.1 and Attachment A are the minimum square footage requirement. All offers at or above this minimum will be considered on total annual rent basis.

3.4 ANSI/BOMA OFFICE AREA(ABOA) SQUARE FEET

- A. For the purposes of this SFO, the Government recognizes the American National Standards Institute/Building Owners and Managers Association (ANSI/BOMA) international standard (Z65.1-2017 definition for Office Area, which means “the area where a tenant normally houses personnel and/or furniture, for which a measurement is to be computed.”). The Government also recognizes the American National Standards Institute/Building Owners and Managers Association (ANSI/BOMA) international standard (Z65.2-2019) for Warehouse space.
- B. ANSI/BOMA square feet shall be computed by measuring the area enclosed by the finished surface of the room side of corridors (corridors in place as well as those required by local codes and ordinances to provide an acceptable level of safety and/or to provide access to essential building elements) and other permanent walls, the dominant portion (refer to Z65.1) of building exterior walls, and the center of tenant-separating partitions. Where alcoves, recessed entrances, or similar deviations from the corridor are present, ANSI/BOMA square feet shall be computed as if the deviation were not present.

3.5 COMMON AREA FACTOR

If applicable, the Offeror shall provide the Common Area Factor (a conversion factor(s) determined by the building owner and applied by the owner to the ANSI/BOMA square feet to determine the rental square feet for the offered space).

3.6 APPURTENANT AREAS

The right to use appurtenant areas and facilities is included. The Government reserves the right to post Government rules and regulations where the Government leases space.

3.7 LIQUIDATED DAMAGES

In case of failure on the part of the Offeror to complete the work within the time fixed in the lease contract or letter of award, the Offeror shall pay the Government as fixed and agreed liquidated damages, pursuant to this paragraph, the sum of \$600.00 per calendar day. This amount should equal rent in another location for each and every calendar day that the delivery is delayed beyond the date specified for delivery of all the space ready for occupancy by the Government. This remedy is not exclusive and is in addition to any other remedies which may be available under this lease or at law. This liquidated sum is not meant as a penalty, but as an approximation of actual damages that would be suffered by the Government because of the Offeror's delay.

3.8 ADJUSTMENT FOR VACANT PREMISES

- A. If the Government fails to occupy any portion of the leased Premises or vacates the Premises in whole or in part prior to expiration of the term of the Lease, the rental rate and the base for operating cost adjustments will be reduced using the figure specified in the "Rate for Adjustment for Vacant Leased Premises" paragraph of this Lease.
- B. If no rate reduction has been established in this Lease, the rate will be reduced by that portion of the costs per ABOA square feet of operating expenses not required to maintain the Space.
- C. Said reduction shall occur after the Government gives 30 calendar days' prior notice to the Offeror and shall continue in effect until the Government occupies the vacant Premises or the Lease expires or is terminated.

3.9 AFTER AWARD

Lease: Within ten (10) calendar days after notice of award, the Government shall provide Offeror Attachment C, "U.S. Government Lease for Real Property" drafted for execution. Within five (5) days of receipt, Offeror shall sign and return to the RECO for final execution.

A. ACCEPTANCE OF SPACE AND CERTIFICATE OF OCCUPANCY:

Ten (10) days prior to the completion of interior construction, the Offeror (Lessor) shall issue written notice to the Government to inspect the space. The Government shall have fourteen (14) calendar days to inspect and to either accept or reject the subject space.

- 1. Substantially completed space may be accepted by the Government subject to the completion of minor punch list items. Space which is not substantially complete will not be accepted by the Government. Should the Government reject the Offeror's space as not substantially complete as defined herein, the Offeror shall immediately undertake remedial action and when ready shall issue a subsequent notice to inspect to the Government.
- 2. The Offeror (Lessor) shall provide a valid Certificate of Occupancy, issued by the local jurisdiction, for the intended use of the Government and shall maintain and operate the building in conformance with current local codes and ordinances. If the local jurisdiction does not issue Certificates of Occupancy, the Offeror shall obtain the services of a licensed fire protection engineer to verify the offered space meets all applicable, Federal, Department of Defense UFC 3-600-01, state, and local codes and ordinances to ensure an acceptable level of safety is provided.

B. RENT COMMENCEMENT:

Upon award, the rent commencement date shall occur upon the effective date of the lease. The effective date of the lease shall commence within twelve (12) months of award. Rent shall be paid monthly and in arrears.

In accordance with Attachment F, Proposal to Lease Space, in the event in which an awarded Offeror requires the completion of TI prior to the Government taking occupancy of a leased space, the Government shall pay shell rent, inclusive of applicable taxes, until the TI is certified as acceptable by the RECO and his/her designated representatives. The date after which TI is certified as acceptable, the Government shall pay the negotiated base rent and operating expenses inclusive of utilities, maintenance and janitorial services with rent to be prorated accordingly thereafter.

The Government prefers for the rent commencement date to occur after it has certified space as acceptable and for the rent to be prorated accordingly thereafter. The Government will not be required to accept space and commence rent prior to certifying space as acceptable for occupancy.

3.10 CONSTRUCTION SCHEDULE

- A. Within five (5) calendar days after award, the successful Offeror shall submit to the RECO a tentative construction schedule giving the dates on which the various phases of construction will be completed to coincide with the Government's required occupancy date. Refer to the "Occupancy Date" paragraph in Section 1.6 of this SFO. The finalized schedule shall be submitted no later than 30 days after award.
- B. The schedule shall include timing for completion of design and construction milestones including, but not limited to: 1) submittal of preliminary plans and specifications; 2) submittal of other working drawings; 3) issuance of any building and environmental permits; 4) completed construction documents; 5) start of construction; 6) completion of principal categories of work; 7) completion and availability for move-in of each portion of the Government demised area; and 8) final construction completion prior to the lease start date. Such schedule shall also indicate the dates available for the Government contractors to install telephone/data lines and furnishings and equipment prior to occupancy.
- C. FINAL LAYOUT DRAWINGS FOR REVIEW:
 - 1. The Offeror (Lessor) shall prepare, at the Offeror's expense, and provide to the Government, for the Government's approval, Final Layout Drawings. The Government shall use best efforts to coordinate the provision of such information and details as required by the Offeror's architect to complete such drawings in a timely manner. Final Layout Drawings, for the purposes of this lease, are defined as fully-dimensioned drawings of the leased space and shall consist of: 1) basic architectural information, wall types and location, door types and location, furniture locations, electrical, telephone and data outlet types and locations; 2) specifications necessary for calculation of electrical and HVAC loads; and 3) all finish/color/signage selections. Final Layout Drawings shall be due from the Offeror within fifteen (15) calendar days from award.
 - 2. Review. The Government retains the right to review, and request modifications (if necessary) to, the Offeror's Final Layout Drawings prior to the Offeror's commencement of interior construction. The Government's review of the Final Layout Drawings is

limited to the construction documents' conformance to the specific requirements of the SFO and the Government's adjustments. The Government shall perform all reviews of the Final Layout Drawings within ten (10) calendar days of receipt of such from the Offeror. Should the Government require that modifications be made to the Offeror's Final Layout Drawings, the Government shall state such in writing to the Offeror, and the Offeror shall have five (5) calendar days to cure all noted defects before returning the Final Layout Drawings to the Government for a subsequent review. Upon complete Government review for conformance of the Final Layout Drawings the Offeror shall obtain the necessary permits. Notwithstanding the Government's review of the Final Layout Drawings, the Offeror is solely responsible and liable for the technical accuracy of the Final Layout Drawings in meeting all requirements and provisions of this SFO and the lease. The Offeror shall obtain the necessary permits.

D. CONSTRUCTION OF TENANT IMPROVEMENTS:

The Offeror (Lessor) shall construct all Tenant Improvements in accordance with 1) the Government reviewed Final Layout Drawings and 2) all terms and conditions of the SFO and the lease. The Government reserves the right to access any space within the building during the conduct of interior construction for the purposes of performing inspections or for installing Government-furnished equipment. The Government shall coordinate with the Offeror the activity of Government contractors in order to minimize conflicts with, and disruption to, other contractors on site. Access shall not be denied to authorized Government officials including, but not limited to, Government contractors, subcontractors, or consultants acting on behalf of the Government with regard to this project.

3.11 EVIDENCE OF CAPABILITY TO PERFORM – AFTER AWARD

Within 45 days after award, the successful Offeror (Lessor) shall provide to the RECO evidence of:

1. A firm commitment of funds in an amount sufficient to perform the work.
2. Award of a construction contract for Tenant Improvements with a firm completion date, if required.
3. Issuance of a building permit covering construction of the improvements, if required.

3.12 PROGRESS REPORTS

After start of construction, at the Government's discretion, the successful Offeror (Lessor) shall submit to the RECO, written progress reports at intervals of 30 days. Each report shall include information as to 1) percentage of the work completed by phase and trade; 2) a statement as to expected completion and occupancy date; 3) changes introduced into the work; and 4) general remarks on such items as material shortages, strikes, weather, etc. At the Government's discretion, the Offeror shall conduct periodic meetings to brief Government personnel and/or contractors regarding the progress of design and construction of the Government demised area. Such meetings shall be held at a location to be designated by the Government.

3.13 CONSTRUCTION INSPECTIONS

- A. Construction inspections may be made periodically by the RECO and/or designated technical representatives to review compliance with the SFO requirements and the Final Layout Drawings.
- B. Periodic reviews, tests, and inspections by the Government are not to be interpreted as resulting in any approval of the Offeror's (Lessor's) apparent progress toward meeting the Government's objectives but are intended to discover any information which the RECO may be able to call to the Offeror's attention to prevent costly misdirection of effort.
- C. The Offeror (Lessor) shall remain completely responsible for designing, constructing, operating, and maintaining the building in full accordance with the requirements of this SFO.

3.14 GREEN LEASE COMPLIANCE

Prior to occupancy, the Offeror shall provide a written description of efforts in compliance with the requirements outlined in the lease with respect to the use of environmentally friendly products and materials. This description shall address the reuse and recycling of existing materials, use of recycled content products, use of non-toxic substances, and the following paragraphs:

Construction Waste Water Management	Wall Coverings
Existing Fit-out, Salvages or Reused Building Material	Painting
Indoor Air Quality During Construction	Doors: Interior
Landscaping	Carpet: Broadloom and/or Carpet Tile
Recycled Content Products	Energy Cost Savings
Environmentally Preferable Building Products and Materials	Drinking Fountains
Floor Covering and Perimeters	Toilet Rooms
Wood Products	Heating and Air Conditioning
Adhesives and Sealants	Ventilation
Insulation	Lighting: Interior and Parking
Ceilings	Indoor Air Quality
Janitorial Services	Radon in Water

3.15 WAIVER OF RESTORATION

Offeror shall have no right to require the Government to restore the Premises upon expiration or earlier termination (full or partial) of the Lease, and waives all claims against the Government for waste, damages, or restoration arising from or related to (a) the Government's normal and customary use of the Premises during the term of the Lease (including any extensions thereof), as well as (b) any initial or subsequent alteration to the Premises regardless of whether such alterations are performed by the Offeror or by the Government. At its sole option, the Government may abandon property in the Space following expiration or earlier termination (full or partial) of the Lease, in which case the property will become the property of the Offeror and the Government will be relieved of any liability in connection therewith.

4.0 GENERAL ARCHITECTURE

4.1 QUALITY AND APPEARANCE OF BUILDING EXTERIOR

- A. The warehouse shall be of sound and substantial construction. The facade, downspouts, roof trim, and window casing shall be clean and in good condition. All windows, roof, walls and door frames shall be free from leaks.
- B. Exterior paving must be sloped away from the warehouse for drainage and have no low spots where water will stand. A bituminous wearing course shall be installed over the bituminous base coat.
- C. Exterior pedestrian doors shall be solid, weather tight, and equipped with cylinder locks. All locks must be master keyed. The Government must be furnished at least two master keys and two keys for each lock. Hardware for outward opening doors shall conform to National Fire Protection Association (NFPA) 101. All doors, entrances and doorways (except for loading docks) must be accessible to the physically challenged, including ramps where necessary. Emergency exits shall be provided as required by NFPA codes and any applicable state and county fire and life safety standards.
- D. At the Government's discretion, Offeror is responsible for replacing all interior door locks within the leased Premises. Locking hardware and cylinders must be new. Common area doors locks, and hardware must be in excellent condition at the start of the lease. Conference rooms must have locking function.
- E. The warehouse's exterior must be lighted at a minimum of two foot-candles at ground level fifty feet from the warehouse.

4.2 CONSTRUCTION WASTE MANAGEMENT

- A. The Offeror shall use best efforts for recycling construction waste for initial space alterations of tenant improvements and subsequent alterations under the lease.
- B. Recycling construction waste means providing all services necessary to furnish construction materials or wastes to organizations which will employ these materials or wastes in the

production of new materials. Recycling includes required labor and equipment necessary to separate individual materials from the assemblies of which they form a part.

- C. The Offeror shall use best efforts to recycle the following items during both the demolition and construction phases of the project, subject to economic evaluation and feasibility:
1. Ceiling grid and tile;
 2. Light fixtures, including proper disposal of any transformers, ballasts, and fluorescent light bulbs;
 3. Duct work and HVAC equipment;
 4. Wiring and electrical equipment;
 5. Aluminum and/or steel doors and frames;
 6. Hardware;
 7. Drywall;
 8. Steel studs;
 9. Carpet, carpet backing, and carpet padding;
 10. Wood;
 11. Insulation;
 12. Cardboard packaging;
 13. Pallets;
 14. Windows and glazing materials;
 15. All miscellaneous metals (as in steel support frames for filing equipment); and
 16. All other finish and construction materials.
- D. If any waste materials encountered during the demolition or construction phase are found to contain lead, asbestos, polychlorinated biphenyls (PCBs) (such as fluorescent lamp ballasts), or other harmful substances, they shall be handled and removed in accordance with federal and state laws and requirements concerning hazardous waste.
- E. In addition to providing "one time" removal and recycling of large-scale demolition items such as carpeting or drywall, the Offeror shall use best efforts to provide continuous facilities for the recycling of incidental construction waste during the initial construction.
- F. Construction materials recycling records shall be maintained by the Offeror and shall be accessible to the RECO. Records shall include materials recycled or landfilled, quantity, date, and identification of hazardous wastes.

4.3 EXISTING FIT-OUT, SALVAGED, OR RE-USED BUILDING MATERIAL

Items and materials existing in the offered space, or to be removed from the offered space during the demolition phase, are eligible for reuse in the construction phase of the project. The reuse of items and materials is preferable to recycling them; however, items considered for reuse shall be in refurbished condition and shall meet the quality standards set forth by the Government in this SFO. In the absence of definitive quality standards, the Offeror shall ensure that the quality of the item(s) in question shall meet or exceed accepted industry or trade standards for first quality commercial grade applications.

4.4 INDOOR AIR QUALITY DURING CONSTRUCTION

- A. The Offeror shall provide to the Government safety data sheets (SDS), material safety data sheets (MSDS) or other appropriate documents upon request, but prior to installation or use for the following products including, but not limited to: adhesives, caulking, sealants, insulating materials, fireproofing or fire stopping materials, paints, carpets, floor and wall patching or leveling materials, lubricants, clear finishes for wood surfaces, janitorial cleaning products, and pest control products.
- B. The RECO may eliminate from consideration products with significant quantities of toxic, flammable, corrosive, or carcinogenic material and products with potential for harmful chemical emissions. Materials used often or in large quantities will receive the greatest amount of review.
- C. All SDS and MSDS shall comply with Occupational Safety and Health Administration (OSHA) requirements. The Offeror and its agents shall comply with all recommended measures in the SDS to protect the health and safety of personnel.
- D. To the greatest extent possible, the Offeror shall sequence the installation of finish materials so that materials that are high emitters of volatile organic compounds (VOC) are installed and allowed to cure before installing interior finish materials, especially soft materials that are woven, fibrous, or porous in nature, that may absorb contaminants and release them over time.
- E. Where demolition or construction work occurs adjacent to occupied space, the Offeror shall erect appropriate barriers (noise, dust, odor, etc.) and take necessary steps to minimize interference with the occupants. This includes maintaining acceptable temperature, humidity, and ventilation in the occupied areas during window removal, window replacement, or similar types of work.
- F. FLUSH-OUT PROCEDURE:
 - 1. A final flush-out period of 72 hours minimum is required after installation of all interior finishes and before the tenant agency's occupancy of the space. The Offeror shall ventilate 24 hours a day, with new filtration media at 100% outdoor air (or maximum outdoor air while achieving a relative humidity not greater than 60%).
 - 2. After the 3-day period the space may be occupied; however, the flush-out must continue for 30 days using the maximum percentage of outdoor air consistent with achieving thermal comfort and humidity control.
 - 3. Any deviation from this ventilation plan must be approved by the RECO.
- G. The Offeror is required to provide regularly occupied areas of the tenant space with new air filtration media before occupancy that provides a Minimum Efficiency Reporting Value (MERV) of 13 or better.

- H. During construction, meet or exceed the recommended design approaches of the Sheet Metal and Air Conditioning National Contractors Association (SMACNA) IAQ Guideline for Occupied Buildings Under Construction, 1995, Chapter 3.
- I. Protect stored onsite and installed absorptive materials from moisture damage.
- J. If air handlers are used during construction, the Offeror shall provide filtration media with a Minimum Efficiency Reporting Value (MERV) of 8 at each return air grill, as determined by ASHRAE (American Society of Heating, Refrigeration and Air-Conditioning Engineers) 52.2-1999.

4.5 WORK PERFORMANCE

All work in performance of this lease shall be done by skilled workers or mechanics and shall be acceptable to the RECO. The RECO retains the right to reject the Offeror's workers 1) if such are either unlicensed, unskilled, or otherwise incompetent or 2) if such have demonstrated a history of either untimely or otherwise unacceptable performance in connection with work carried out in conjunction with either this contract or other Government or private contracts. All work performed is subject to security requirements as outlined in this SFO.

4.6 BUILDING SYSTEMS

Whenever requested, the Offeror shall furnish at no cost to the Government a report by a registered professional engineer(s) showing that the building and its systems as designed and constructed will satisfy the requirements of this lease.

4.7 SPACE EFFICIENCY

The design of the space offered shall be conducive to efficient layout and good utilization as determined by the Government at its sole discretion.

4.8 FLOOR PLANS AFTER OCCUPANCY

Within 30 days after occupancy, as-built floor plans, scaled at 1/8" = 1'-0", showing the space under lease, as well as corridors, stairways, and core areas, shall be provided to the RECO.

4.9 CAD AS-BUILT FLOOR PLANS

Computer-Aided Design (CAD) files of as-built floor plans showing the space under lease, as well as corridors, stairways, and core areas, shall be provided to the RECO along with the as-built floor plan drawings required in the "Floor Plans After Occupancy" paragraph in GENERAL ARCHITECTURE Section 4.0 of this SFO. All electronic submittals must be usable without passwords and fully capable to be copied.

4.10 FLOORS AND FLOOR LOAD (FOR WAREHOUSE SPACE REQUIREMENTS)

- A. Floor area must be contiguous without public access.

- B. The floor area of the space must be contiguous without public access and must be of a smooth weight bearing nature (i.e. concrete) that allow for the easy maneuverability of a forklift and should be conducive to shelving and storage racks.
- C. Carpeting is desired for the office space.
- D. Smooth polished concrete is desired for the warehouse space
- E. The Offeror shall repair or replace the Warehouse floor and carpet at the Offeror's expense at any time during the lease term when it is damaged.
- F. Repair or replacement shall include the moving and returning of furnishings. Work shall be performed after normal working hours by a licensed contractor and in accordance with manufacturing instructions to lie smoothly and evenly.

4.11 RACKING

Offeror shall propose pallet racking system within warehouse space, as required to support the Government's operational needs. Racking may utilize up to eighty percent (80%) of the warehouse area, subject to size, configuration, and structural capacity of the building. The Government prefers pushback racking; however, offerors may propose alternative racking systems that meet the Government's operational requirements.

All proposed racking systems shall be designed to support industrial storage loads consistent with the requirements set forth in this solicitation. Specific load and weight requirements, where applicable, are described in Attachment A.

All racking systems identified in the offer as necessary to meet the Government's requirements, including procurement and installation, shall be treated as Tenant Improvements and shall be included in the Offeror's pricing.

The design, installation and use of all proposed racking systems shall comply with all applicable federal, state, and local laws and regulations, including fire, safety, and building code requirements, and shall not interfere with required clearances, egress or building systems.

4.12 EXITS AND ACCESS

The warehouse space must contain a forklift and truck accessible loading dock with motorized and lockable bay doors with minimum clear inside dimensions of 12'x12'. The entire warehouse floor area must be contiguous. In addition to Section 5.9 requirements, all motorized and lockable bay doors shall be on a regular maintenance schedule, to be assessed no less than twice a year.

4.13 WINDOWS

All windows shall be weather-tight. Operable windows that open shall be equipped with locks. Off-street, ground level windows and those accessible from fire escapes, adjacent roofs, and other structures that can be opened must be fitted with a sturdy locking device. Windows accessible from fire escapes must be readily operable from the inside of the building.

Windows located on the ground floor shall remained locked at all times.

All windows shall be outfitted with tinting and window blinds that have the ability to be drawn in as needed in order to restrict visual observation from outside the facility or within the facility main lobby. Windows within the main lobby and doors with glass do not need to be outfitted with blinds but must be tinted.

4.14 ACCESSIBILITY

The warehouse and areas serving the leased space shall be accessible to persons with disabilities in accordance with both the Americans with Disabilities Act Accessibility Guidelines (ADAAG) and the Architectural Barriers Act Accessibility Standard (ABAAS), Appendices C and D to 36 CFR Part 1191 (ABA Chapters 1 and 2, and Chapters 3 through 10). The areas that must comply with this requirement are doors, doorways, and ramps, with the exception of the loading dock. Emergency exits shall be provided as required by NFPA codes and any applicable state and county fire and life safety standards. To the extent the standard referenced in the preceding sentence conflicts with local accessibility requirements, the more stringent shall apply.

5.0 ARCHITECTURAL FINISHES

5.1 RECYCLED CONTENT PRODUCTS (COMPREHENSIVE PROCUREMENT GUIDELINES)

The Offeror shall comply to the extent feasible with the Resource Conservation and Recovery Act (RCRA), Section 6002, 1976. The Offeror shall use recycled content products as indicated in this SFO and as designated by the U.S. Environmental Protection Agency (EPA) in the Comprehensive Procurement Guidelines (CPG), 40 CFR Part 247, and its accompanying Recovered Materials Advisory Notice (RMAN). The CPG lists the designated recycled content products. EPA also provides recommended levels of recycled content for these products. The list of designated products, EPA recommendations, and lists of manufacturers and suppliers of the products can be found at the <https://www.epa.gov/smm/comprehensive-procurement-guideline-cpg-program#products> web site.

5.2 LAYOUT, FINISHES, AND COLORBOARDS

All building finishes shall be for first class, modern space. The Offeror shall consult with the RECO prior to developing a minimum of three (3) color boards to include coordinated samples of finishes for all interior elements such as paint, wall coverings, base coving, carpet, window treatments, laminates, and flooring. All samples provided shall be in compliance with specifications set forth elsewhere in this SFO. The Offeror shall provide the required color boards within ten (10) calendar days of the request for such by the RECO. The color boards shall be approved by the Government prior to installation. Upon review with the Tenant, the RECO must select one (1) color board within fifteen (15) calendar days, and unless otherwise specified prior to lease award, the Offeror may assume that one color board will be accepted for all finishes in the entire space under lease. The Offeror may not make any substitutions after the color board is selected.

5.3 WOOD PRODUCTS

- A. For all new installations of wood products, the Offeror is encouraged to use independently certified forest products. For information on certification and certified wood products, refer to the Forest Stewardship Council United States (<https://us.fsc.org/en-us>) or the Sustainable Forestry Initiative (<https://forests.org/>).
- B. New installations of wood products used under this contract shall not contain wood from endangered wood species, as listed by the Convention on International Trade in Endangered Species. The list of species can be found at the following web site: <https://cites.org/eng/disc/species.php>.
- C. Particle board, strawboard, and plywood materials shall comply with Department of Housing and Urban Development (HUD) standards for formaldehyde emission controls. Plywood materials shall not emit formaldehyde in excess of 0.2 parts per million (ppm), and particleboard materials shall not emit formaldehyde in excess of 0.3 ppm.

5.4 ADHESIVES AND SEALANTS

All adhesives employed on this project (including, but not limited to, adhesives for carpet, carpet tile, plastic laminate, wall coverings, adhesives for wood, or sealants) shall be those with the lowest possible VOC content below 20 grams per liter and which meet the requirements of the manufacturer of the products adhered or involved. The Offeror shall use adhesives and sealants with no formaldehyde or heavy metals.

5.5 INSULATION: THERMAL, ACOUSTIC, AND HVAC

- A. All insulation products shall contain recovered materials as required by EPA's CPG and related recycled content recommendations. This requirement applies to all new insulation to be installed due to Government occupancy.
- B. No insulation installed with this project shall be material manufactured using chlorofluorocarbons (CFC), nor shall CFC be used in the installation of the product.
- C. All insulation containing fibrous materials exposed to air flow shall be rated for that exposure or shall be encapsulated.
- D. Insulating properties for all materials shall meet or exceed applicable industry standards. Polystyrene products shall meet American Society for Testing and Materials (ASTM) C578 91.
- E. All insulation shall be low emitting with not greater than .05 ppm formaldehyde emissions.

5.6 CEILINGS

- A. Ceilings should meet the appropriate height for each space requirement as described in Attachment A. Bulkheads and hanging or surface-mounted light fixtures which impede traffic ways should be avoided. Ceilings should be uniform in color and appearance throughout the leased space, with no obvious damage to tiles or grid or insulation.

- B. Ceilings should have a minimum noise reduction coefficient (NRC) of 0.60 for warehouse space and 0.75 for admin space throughout the Government demised area.
- C. Prior to closing the ceiling, the Offeror shall coordinate with the Government for the installation of any items above the ceiling.
- D. Should the ceiling be installed in the Government demised area prior to the Tenant Improvements, then the Offeror shall be responsible for all costs in regard to the disassembly, storage during alterations, and subsequent re-assembly of any of the ceiling components which may be required to complete the Tenant Improvements. The Offeror shall also bear the risk for any damage to the ceiling or any components thereof during the alterations.
- E. Ceilings shall be a flat plane in each room and shall be suspended with ample light fixtures and finished as follows unless an alternate equivalent is pre-approved by the RECO.
 - 1. *Restrooms*. Plaster or spackled and taped gypsum board and painted with ample light fixtures.
 - 2. *Offices and Conference Rooms*. Mineral and acoustical tile or lay-in panels with textured or patterned surface and regulate edges or an equivalent pre-approved by the RECO. Tiles or panels shall contain recycled content.
 - 3. *Corridors and Eating/Galley Areas*. Plaster or spackled and taped gypsum board or mineral acoustical tile.

5.7 WALL FINISHES

A. BUILDING SHELL:

- 1. *Physical Requirements*. Prior to occupancy, all restrooms within the building common areas of Government occupied floors shall have 1) ceramic tile in splash areas and 2) semi-gloss paint on remaining wall areas or other finish approved by the RECO.
- 2. *Replacement*. The Offeror must maintain all wall coverings, high-performance paint coatings, and paints in "like new" condition for the life of the lease. The Offeror, at its expense, must replace or repair paints, high-performance coatings, or wall coverings any time during the Government's occupancy if they are torn, peeling, permanently stained, marked, or damaged from impact. Repair or replace the ceramic tile in the restrooms if it is loose, chipped, broken, or permanently discolored. All repair or replacement work must be coordinated with the RECO and tenant and may be required to occur after working hours.

B. TENANT IMPROVEMENTS INFORMATION:

- 1. Wall finishes shall comply with the VOC (Volatile Organic Compound) limits of the Green Seal Standard GS-11.

5.8 PAINTING

A. BUILDING SHELL:

1. The Offeror shall bear the expense for all painting associated with the building shell. These areas shall include all common areas. Exterior perimeter walls, columns and interior core walls within the Government demised area shall be spackled and prime painted with low VOC primer. If any building shell areas are already painted prior to Tenant Improvements, then the Offeror shall repaint, at the Offeror's expense, as necessary during Tenant Improvements.
2. Public areas shall be painted at least every three (3) years. Tenant areas shall be repainted every five (5) years, and any time during the occupancy by the Government if paint is peeling or permanently stained, except where damaged due to the negligence of the Government. Repainting includes the moving and returning of furnishings. All work shall be done outside of the tenant's normal business hours.

B. TENANT IMPROVEMENT INFORMATION:

1. The Offeror shall provide interior paints and coatings that meet or are equivalent to the following standards for Volatile Organic Compound (VOC) off gassing:
 - a. Topcoat paints: Green Seal Standard GS-11, Paints, First Edition, May 20, 1993.
 - b. All other architectural coatings, primers, and undercoats: South Coast Air Quality Management District (SCAQMD) Rule 1113, Architectural Coatings, effective January 1, 2004.
 - c. Architectural paints, coatings, and primers applied to interior walls and ceilings:
 - i. Flats: 50 grams per liter (g/L).
 - ii. Non-flats: 150 g/L.
 - d. Anticorrosive and antirust paints applied to interior ferrous metal substrates: 250 g/L.
 - e. Clear wood finishes:
 - i. Varnish: 350 g/L.
 - ii. Lacquer: 550 g/L.
 - f. Floor coatings: 100 g/L.
 - g. Sealers:
 - i. Waterproofing sealers: 250 g/L.
 - ii. Sanding sealers: 275 g/L.
 - iii. All other sealers: 200 g/L.
 - h. Shellacs:
 - i. Clear: 730 g/L.
 - ii. Pigmented: 550 g/L.
 - i. Stains: 250 g/L.
 - j. Use reprocessed latex paint in accordance with EPA's CPG (Comprehensive Procurement Guidelines) on all painted surfaces where feasible. The type of paint shall be acceptable to the RECO.

5.9 DOORS: EXTERIOR (FOR WAREHOUSE SPACE REQUIREMENTS)BUILDING SHELL:

- A. Exterior doors shall be provided at the Offeror's expense. Exterior doors shall be weather-tight and shall open outward. Hinges, pivots, and pins shall be installed in a manner which prevents removal when the door is closed and locked.
- B. These doors shall have a minimum clear opening of 36" wide x 80" high (per leaf). Doors shall be heavy-duty, flush, 1) hollow steel construction, 2) solid core wood, or 3) insulated tempered glass. As a minimum requirement, hollow steel doors shall be fully insulated, flush, #16-gauge hollow steel. Solid-core wood doors and hollow steel doors shall be at least 1-3/4 inches thick. Door assemblies shall be of durable finish and shall have an aesthetically pleasing appearance acceptable to the RECO. The opening dimensions and operations shall conform to the governing building, fire safety, accessibility for the disabled, and energy codes and/or requirements.
- C. The Offeror shall be solely responsible for all aspects of maintenance, repair, and functionality of the bay door(s) located on the leased Premises. This responsibility includes regular inspections, necessary repairs, and ensuring the bay door remains fully operational. Any costs associated with the maintenance, repair, or replacement of the bay door shall be borne entirely by the Offeror. The Government shall not be liable for any expenses incurred to the bay door's upkeep and repair.
 - 1. The Bay door must maintain its weather-tight integrity throughout the lease term. The Offeror shall take all necessary measures to ensure that the bay door effectively prevents the ingress of weather elements, including rain, wind, and snow, into the leased Premises.
 - 2. Failure of the bay door to function properly or to remain weather-tight shall be promptly addressed by the Offeror, and any necessary repairs shall be carried out without delay.
- D. The Offeror must provide an electric-powered bay door(s) for the leased Premises. The bay door shall be equipped with an electric motor and operating mechanism that allows for seamless opening and closing of the door via electric controls.
 - 1. The Offeror shall ensure that the electric-powered bay door is installed and operational throughout the leased term. The bay door(s) electric motor and associated components must be maintained in good working condition throughout the duration of the lease. Any costs associated with the installation, maintenance, repair, or replacement of the electric-powered bay door's motor and related components shall be the sole responsibility of the Offeror. The Government shall not be liable for, and expenses incurred in relation to the electric-powered bay door's motor or operation mechanism.

5.10 DOORS: SUITE ENTRYTENANT IMPROVEMENT INFORMATION:

Suite entry doors shall be provided as part of the Tenant Improvements and shall have a minimum clear opening of 32" wide x 84" high (per leaf). Doors shall meet the requirements of being a flush, solid core, 1 3/4 inch thick, wood door with a natural wood veneer face or an equivalent pre-approved by the RECO. Hollow core wood doors are not acceptable. They shall be operable by a single effort and shall be in accordance with National Building Code requirements. Doors shall be installed in a metal frame assembly, primed and finished with a low VOC semi-gloss oil-based paint with no formaldehyde.

5.11 DOORS: INTERIOR

TENANT IMPROVEMENT INFORMATION:

Doors within the Government demised area shall be glass double doors for entry into the main suite, or an equivalent pre-approved by the RECO. Hollow core wood doors are not acceptable. They shall be operable with a single effort and shall be in accordance with National Building Code requirements. Doors shall be installed in a metal frame assembly, primed and finished with a low VOC semi-gloss oil-based paint with no formaldehyde.

5.12 DOORS: HARDWARE

A. BUILDING SHELL:

Exterior doors shall have door handles or door pulls with heavyweight hinges. All doors shall have corresponding doorstops (wall or floor mounted) and silencers. All public use doors and toilet room doors shall be equipped with kick plates. All building exterior doors shall have locking devices installed to reasonably deter unauthorized entry. Properly rated and labeled fire door assemblies shall be installed on all fire egress doors.

B. TENANT IMPROVEMENT INFORMATION:

Doors shall have door handles or door pulls with heavyweight hinges. The Offeror is encouraged to avoid the use of chrome-plated hardware. All doors shall have corresponding doorstops (wall or floor mounted) and silencers. All door entrances leading into the Government demised area from public corridors and exterior doors shall have automatic door closers. Doors designated by the Government shall be equipped with 5-pin, tumbler cylinder locks and strike plates. All locks shall be on a master key system. Furnish at least two (2) for each lock to the Government. Any exterior entrance shall have a high security lock, with appropriate key control procedures, as determined by Government specifications. Hinge pins and hasps shall be secured against unauthorized removal by using spot welds or peened mounting bolts. The exterior side of the door shall have a lock guard or astragal to prevent jimmying of the latch hardware. Doors used for egress only shall not have any operable exterior hardware. All security-locking arrangements on doors used for egress shall comply with requirements of NFPA 101.

5.13 DOORS: IDENTIFICATION

A. BUILDING SHELL:

All signage required in common areas unrelated to tenant identification shall be provided and installed at the Offeror's expense.

B. TENANT IMPROVEMENT INFORMATION:

Door identification shall be installed in approved locations adjacent to office entrances as part of the lease. The form of door identification shall be approved by the RECO.

5.14 PARTITIONS: GENERAL

BUILDING SHELL:

Partitions in public areas shall be marble, granite, hardwood, or sheetrock covered with durable wall covering or high-performance coating, or equivalent pre-approved by the RECO. Additionally, all partitions shall be on a regular maintenance schedule, to be assessed no less than three times each year.

5.15 PARTITIONS: PERMANENT

BUILDING SHELL:

Permanent partitions shall extend from the structural floor slab to the structural ceiling slab. They shall be provided by the Offeror at the Offeror's expense as necessary to surround the Government demised area, stairs, corridors, toilet rooms, all columns, and janitor closets. They shall have a flame spread rating of 25 or less and a smoke development rating of 50 or less (ASTM E-84). Stairs, elevators, and other floor openings shall be enclosed by partitions and shall have the fire resistance required by National Fire Protection Association (NFPA) Standard 101, Life Safety Code. Additionally, all partitions shall be on a regular maintenance schedule, to be assessed no less than three times each year.

5.16 PARTITIONS: SUBDIVIDING

A. BUILDING SHELL:

Any demolition of existing improvements which is necessary to satisfy the Government's layout shall be done at the Offeror's expense. Additionally, all partitions shall be on a regular maintenance schedule, to be assessed no less than three times each year.

B. OFFICE SUBDIVIDING PARTITIONS:

1. Office subdividing partitions shall comply with applicable building codes and local requirements. Partitioning shall extend from the finished floor to the finished ceiling and shall be designed to provide a sound transmission class (STC) of 37. Partitioning shall be installed by the Offeror at locations to be determined by the Government as identified in the Final Layout Drawings. They shall have a flame spread rating of 25 or less and a smoke development rating of 50 or less (ASTM E-84).

2. HVAC shall be rebalanced and lighting repositioned, as appropriate, after installation of partitions.
3. Partitioning requirements may be met with existing partitions if they meet the Government's standards and layout requirements.

5.17 FLOOR COVERING AND PERIMETERS

A. BUILDING SHELL:

1. Exposed interior floors in primary entrances and lobbies shall be marble, granite, terrazzo, or an equivalent pre-approved by the RECO. Exposed interior floors in secondary entrances, elevator lobbies, and primary interior corridors shall be high-grade carpet, marble, granite, terrazzo, durable vinyl composite tile, or an equivalent pre-approved by the RECO. Resilient flooring, or an equivalent pre-approved by the RECO, shall be used in telecommunications rooms. Floor perimeters at partitions shall have wood, rubber, vinyl, marble, carpet base, or an equivalent pre-approved by the RECO.
2. Terrazzo, unglazed ceramic tile, recycled glass tile, and/or quarry tile shall be used in all toilet and service areas unless another covering is pre-approved by the RECO.
3. Use of existing carpet must be approved by the RECO.

B. CARPET – REPAIR OR REPLACEMENT:

1. Except when damaged by the Government, the Offeror shall repair or replace carpet at the Offeror's expense at any time during the lease term when:
 - a. backing or underlayment is exposed;
 - b. there are noticeable variations in surface color or texture;
 - c. it has curls, upturned edges, or other noticeable variations in texture;
 - d. tiles are loose; or
 - e. tears and tripping hazards are present.
2. Repair or replacement shall include the moving and returning of furnishings, including disassembly and reassembly of systems furniture per manufacturer's warranty, if necessary. Work shall be performed after normal working hours as defined elsewhere in this SFO.

C. RESILIENT FLOORING – REPAIR OR REPLACEMENT:

1. Except when damaged by the Government, the Offeror shall repair or replace resilient flooring at the Offeror's expense at any time during the lease term when it has curls, upturned edges, or other noticeable variations in texture.

2. Repair or replacement shall include the moving and returning of furnishings. Work shall be performed after normal working hours as defined elsewhere in this SFO.

D. CONCRETE FLOORING INFORMATION:

1. Concrete flooring must be coated with a watertight sealant. Regular upkeep shall be monitored by the Offeror and reapplied as necessary. Offeror is responsible for all upkeep costs and maintenance.
2. Concrete Maintenance Responsibility: The Offeror is responsible for the regular maintenance and repair of the concrete surface and foundation within the leased Premises. This includes but is not limited to cleaning, repairing, and protecting the concrete to ensure its safe and functional condition. The Offeror shall bear the costs associated with these maintenance activities, including the purchase of cleaning supplies, repair materials, and any professional services required. In the event of cracks, spalling or other damage, the Offeror shall promptly arrange for necessary repairs, including the filling of cracks and leveling of uneven areas. The Offeror shall take proactive measures to protect the concrete, such as applying sealers or coatings as the Government deems necessary. The Offeror shall ensure that these maintenance activities are conducted at regular intervals to uphold the quality and durability of the concrete surfaces throughout the leased Premises.

E. TENANT IMPROVEMENT INFORMATION:

1. Floor covering shall be either carpet or resilient flooring, as specified in the Government's Final Layout Drawings. Floor perimeters at partitions shall have wood, rubber, vinyl, carpet base, or an equivalent pre-approved by the RECO.
2. The use of existing carpet may be approved by the RECO; however, existing carpet shall be repaired, stretched, and cleaned before occupancy and shall meet the static buildup requirement for new carpet.
3. If the Government requires restrooms and/or shower rooms in the Government demised area, floor covering shall be terrazzo, unglazed ceramic tile, and/or quarry tile.

F. INSTALLATION:

Floor covering shall be installed in accordance with manufacturing instructions to lay smoothly and evenly.

5.18 CARPET TILE

- A. Any carpet to be newly installed pursuant to this paragraph shall meet the following specifications: Pile Yarn Content. Pile yarn content shall be staple filament or continuous filament premium branded nylon branded by a major fiber producer [e.g., Invista (formerly DuPont), Solutia (formerly Monsanto), Shaw, and Honeywell (formerly BASF)].

1. Environmental Requirements. The Offeror shall use carpet tiles that meet the “Green Label Plus” requirements of the Carpet and Rug Institute unless an exception is granted by the RECO. Refer to the EPA’s environmentally preferable purchasing web site, www.epa.gov/greenerproducts.
2. Carpet Pile Construction. Carpet pile shall be level loop, textured loop, level cut pile, or level cut/uncut pile.
3. Pile Weight. Pile weight shall be a minimum of 20 oz./square yard for level loop or textured loop construction. Pile weight shall be a minimum weight of 30 oz./ square yard for level cut/uncut construction.
4. Secondary Back. The secondary backing shall be PVC free made from Polyurethane hardback, Thermoplastic Polyolefin Composite, Ethylene Vinyl Acetate-EVA, Polyurethane Cushion, or Olefin hardback reinforced with fiberglass.
5. Total Weight. Total weight shall be a minimum of 90 oz. /square yard.
6. Density. The density shall be a minimum of 5,000 oz. /cubic yard.
7. Pile Height. The minimum pile height shall be 1/8 inch. The combined thickness of the total product shall not exceed 1/2 inch (13 mm).
8. Static Buildup. Static buildup shall be a maximum of 3.5 kilovolt, when tested in accordance with AATCC 134.
9. Carpet Construction. Carpet construction shall be a minimum of 64 tufts per square inch.
10. Carpet Reclamation. Dispose of any carpet replaced during the life of the lease from the site to a carpet recycling program or participate in a carpet buyback program. When carpet is replaced, submit documentation of carpet reclamation to RECO.

5.19 ACOUSTICAL REQUIREMENTS

BUILDING SHELL:

1. *Reverberation Control*. Ceilings in carpeted space shall have a noise reduction coefficient (NRC) of not less than 0.55 in accordance with ASTM C-423. Ceilings in offices, conference rooms, and corridors having resilient flooring shall have an NRC of not less than 0.75.
2. *Ambient Noise Control*. Ambient noise from mechanical equipment shall not exceed noise criteria curve (NC) 35 in accordance with the ASHRAE *Handbook of Fundamentals* in offices and conference rooms; NC 40 in corridors, cafeterias, lobbies, and toilets; NC 50 in other spaces.
3. *Noise Isolation*. Rooms separated from adjacent spaces by ceiling-high partitions (not including doors) shall not be less than the following noise isolation class (NIC) standards when tested in accordance with ASTM E-336:
 - a. Break Rooms NIC 40
 - b. Offices NIC 35 j

4. *Testing.*

- a. The RECO may require, at no cost to the Government, test reports by a qualified acoustical consultant showing that acoustical requirements have been met.
- b. The requirements of this paragraph shall take precedence over any additional specifications in this SFO if there is a conflict.

5.20 WINDOW COVERINGS

TENANT IMPROVEMENT INFORMATION:

1. *Window Blinds and Shades.* All exterior windows shall be equipped with window blinds or shades in new or like new condition. The blinds may be aluminum or plastic vertical blinds or horizontal blinds with aluminum slats of 1-inch width or less or an equivalent. The window blinds shall have non-corroding mechanisms and synthetic tapes.
2. *Draperies.* Blackout draperies are to be provided in all conference rooms unless there are no windows. If draperies are required, the following minimum specifications shall apply:
 1. Fabrics shall be lined with either white or off-white plain lining fabric suited to the drapery fabric weight. Draperies shall be either floor, apron, or sill-length, as specified by the Government, and shall be wide enough to cover window and trim. Draperies shall be hung with drapery hooks on well-anchored heavy duty traverse rods. Traverse rods shall draw from either the center, right, or left side.
 2. Construction. Any draperies to be newly installed, shall be made as follows:
 - i. fullness of 100 percent, including overlap, side hems, and necessary returns;
 - ii. double headings of 4 inches turned over a 4-inch permanently finished stiffener;
 - iii. doubled side hems of 1-1/2 inches; 4-inch doubled and blind stitched bottom hems;
 - iv. three-fold pinch pleats;
 - v. safety stitched intermediate seams;
 - vi. matched patterns;
 - vii. tacked corners; and
 - viii. no raw edges or exposed seams.
 3. Use of existing draperies must be approved by the RECO.

6.0 MECHANICAL, ELECTRICAL, PLUMBING

6.1 MECHANICAL, ELECTRICAL, PLUMBING: GENERAL

A. BUILDING SHELL:

The Offeror shall provide and operate all building equipment and systems in accordance with applicable technical publications, manuals, and standard procedures. Mains, lines, and meters for utilities shall be provided by the Offeror. Exposed ducts, piping, and conduits are not permitted in the office space.

B. SYSTEMS COMMISSIONING:

The Offeror shall incorporate commissioning requirements to verify that the installation and performance of energy consuming systems meet the Government's project requirements. The commissioning shall cover only work associated with tenant improvements or alterations or at a minimum: heating, ventilating, air conditioning and refrigeration (HVAC&R) systems and associated controls, lighting controls, and domestic hot water systems. Testing and balancing HVAC shall be completed prior to occupancy and "Flush out" procedure described in Section 4.4F.

6.2 ENERGY INDEPENDENCE AND SECURITY ACT (SEPT 2013)

- A. The Energy Independence and Security Act (EISA) establishes requirements for Government leases relating to energy efficiency standards and potential cost-effective energy efficiency and conservation improvements.
- B. Unless one of the statutory exceptions listed in sub-paragraph C below applies, the Government may award a lease for a building only if the building has earned the ENERGY STAR® label conferred by the U.S. Environmental Protection Agency (EPA) within the most recent year prior to the due date for final proposal revisions. The term "most recent year" means that the date of award of the ENERGY STAR® label by EPA must not be more than 1 year prior to the due date of final proposal revisions. For example, an ENERGY STAR® label awarded by EPA on October 1, 2010, is valid for all lease procurements where final proposal revisions are due on or before September 30, 2011. In lieu of the above, all new Buildings being specifically constructed for the Government must achieve an ENERGY STAR® label within 18 months after occupancy by the Government. In addition, Offerors of the following Buildings shall also have up to 18 months after occupancy by the Government, or as soon thereafter as the Building is eligible for Energy Star consideration, to achieve an Energy Star label: 1) All existing Buildings that have had an Energy Star label but are unable to obtain a label in the most recent year (i.e., within 12 months prior to the due date for final proposal revisions) because of insufficient occupancy; 2) Newly built Buildings that have used Energy Star's Target Finder tool and either achieved a "Designed to Earn the Energy Star" certification or received an unofficial score (in strict adherence to Target Finder's usage instructions, including the use of required energy modeling) of 75 or higher prior to the due date for final proposal revisions and who are unable to obtain a label in the most recent year because of insufficient occupancy; 3) An existing Building that is unable to obtain a label because of insufficient occupancy but that can produce an indication, through the use of energy modeling or past utility and occupancy data input into Energy Star's Portfolio Manager tool or Target Finder, that it can receive an unofficial score of 75 or higher using all other requirements of Target Finder or Portfolio Manager, except for actual data from the most recent year. ENERGY STAR tools and resources can be found at www.energystar.gov.
- C. EISA allows a federal agency to lease Space in a Building that does not have an ENERGY STAR® Label if:
1. No Space is offered in a Building with an ENERGY STAR® Label that meets SFO requirements, including locational needs;

2. The agency will remain in a Building it currently occupies;
 3. The Lease will be in a Building of historical, architectural, or cultural significance listed or eligible to be listed on the National Register of Historic Places; or
- D. If one or more of the statutory exceptions applies, and the offered Space is not in a Building that has earned the ENERGY STAR® Label within one year prior to the due date for final proposal revisions, Offerors are required to include in their offer an agreement to renovate the Building for all energy efficiency and conservation improvements that it has determined would be cost effective over the First Term of the Lease, if any, prior to acceptance of the Space (or not later than one year after the Lease Award Date of a succeeding or superseding lease). Such improvements may consist of, but are not limited to, the following:
1. Heating, Ventilating, and Air Conditioning (HVAC) upgrades, including boilers, chillers, and Building Automation System (BAS)/Monitoring/Control System (EMCS).
 2. Lighting Improvements. See Lease paragraph "Lighting: Interior and Parking" for required specifications.
 3. Building Envelope Modifications.
- E. The term "cost effective" means an improvement that will result in substantial operational cost savings to the landlord by reducing electricity or fossil fuel consumption, water, or other utility costs. The term "operational cost savings" means a reduction in operational costs to the landlord through the application of Building improvements that achieve cost savings over the First Term of the lease sufficient to pay the incremental additional costs of making the building improvements.
- F. Instructions for obtaining an ENERGY STAR® Label are provided at <https://www.energystar.gov/products/how-product-earns-energy-star-label> (use partner log in "Portfolio Manager" to apply). ENERGY STAR® tools and resources can be found at www.energystar.gov. Building Upgrade Value Calculator (<https://www.energystar.gov/buildings/tools-and-resources/building-upgrade-value-calculator>) tool can be useful in considering energy efficiency and conservation improvements to Buildings.
- G. If one or more of the statutory exceptions applies, and the offered Space is not in a Building that has earned the ENERGY STAR® Label within one year prior to the due date for final proposal revisions, the successful Offeror will be excused from performing any agreed-to energy efficiency and conservation renovations if it obtains the Energy Star Label prior to the Government's acceptance of the Space (or not later than one year after the Lease Award Date for succeeding and superseding leases).
- H. If no improvements are proposed, the Offeror must demonstrate to the Government using the ENERGY STAR® Online Tools why no energy efficiency and conservation improvements are cost effective. If such explanation is unreasonable, the offer may be rejected.
- I. All new Buildings being specifically constructed for the Government must achieve the ENERGY STAR® Label within 18 months after occupancy by the Government.

6.3 ENERGY COST SAVINGS

- A. The Offeror is encouraged to use 1) Energy Savings Performance Contracts (ESPC) or 2) utility agreements to achieve, maintain, and/or exceed the ENERGY STAR Benchmark Score of 75. The Offeror is encouraged to include shared savings in the offer as a result of energy upgrades where applicable. ESPC information can be found at <https://www.energy.gov/femp/energy-savings-performance-contracts-federal-agencies>. The ENERGY STAR Online Benchmark Tool can be found at the <https://www.energystar.gov> website.
- B. The Offeror may obtain a list of energy service companies qualified under the Energy Policy Act to perform ESPC, as well as additional information on cost-effective energy efficiency, renewables, and water conservation. For the ESPC qualified list, refer to the EPA's EPSC website or call the Federal Energy Management Program (FEMP) Help Desk at 1-800-566-2877
- C. Incandescent bulbs shall not be used. Where it is not feasible to eliminate incandescent bulbs, exceptions must be approved by the RECO.
- D. All new construction is encouraged to achieve an Energy Star score of 75 or above within one year after reaching 95 percent occupancy and will continue to retain the qualifying ENERGY STAR score or better (www.energystar.gov).

6.4 DRINKING FOUNTAIN

BUILDING SHELL:

The Offeror shall provide, on each floor of office space, a minimum of one chilled drinking fountain with a water bottle filling station. The Offeror's maintenance responsibility includes initial supply and replacement of all supplies, materials, and equipment necessary for such maintenance, including replacement of all fountain filters.

6.5 TOILET FACILITIES

A. BUILDING SHELL:

1. Separate toilet facilities for men and women shall be provided on each floor occupied by the Government in the building. The facilities shall be located so that employees will not be required to travel more than 200 feet on one floor to reach the toilets. The men's toilet room shall have at least one (1) water closet with one (1) lavatory for Government's use. The women's toilet room shall have at least one (1) water closet and one (1) lavatory. These facilities may be located either within the Government's leased space or located in the Common Area on the same floor. If provided in the common area, it is the responsibility of the Offeror to ensure that sufficient number of restroom facilities are provided for the Government leased space and other tenants. Each toilet room shall have sufficient water closets enclosed with modern stall partitions and doors, and hot (set in

accordance with applicable building codes) and cold water. Water closets shall not be visible when the exterior door is open.

2. Each main toilet room shall contain the following equipment:
 - a. A mirror above the lavatory;
 - b. A toilet paper dispenser in each water closet stall, that will hold at least two rolls and allow easy, unrestricted dispensing;
 - c. A coat hook on the inside face of the door to each water closet stall and on several wall locations by the lavatories;
 - d. At least one modern paper towel dispenser, soap dispenser, and waste receptacle for every two lavatories;
 - e. A coin-operated sanitary napkin dispenser in women's toilet rooms with a waste receptacle for each water closet stall;
 - f. Ceramic tile, recycled glass tile, or comparable wainscot from the floor to a minimum height of 4 feet, 6 inches;
 - g. A disposable toilet seat cover dispenser; and
 - h. A counter area of at least 2 feet, 0 inches in length, exclusive of the lavatories (however, it may be attached to the lavatories) with a mirror above and a ground fault interrupt-type convenience outlet located adjacent to the counter area.

B. If newly installed, toilet partitions shall be made from recovered materials as listed in EPA's CPG.

1. For new installations:
 - a. Water closets shall not use more than 1.6 gallons per flush.
 - b. Urinals shall not use more than 1.0 gallons per flush.
 - c. Faucets shall not use more than 2.5 gallons per minute at a flowing water pressure of 80 pounds per square inch.

6.6 JANITOR CLOSETS

BUILDING SHELL:

- A. Janitor closets with service sink, hot and cold water, and ample storage for cleaning equipment, materials, and supplies shall be provided on all floors. Each janitor closet door shall be fitted with an automatic deadlocking latch bolt with a minimum throw of 1/2 inch.
- B. When not addressed by local code, provide containment drains plumbed for appropriate disposal of liquid wastes in spaces where water and chemical concentrate mixing occurs for cleaning or maintenance purposes. Disposal is not permitted in restrooms.
- C. Refer to the "Indoor Air Quality" paragraph in the SAFETY AND ENVIRONMENTAL MANAGEMENT Section 8.0 of this SFO.
- D. Janitor closets shall not be part of the Government's net square feet.

6.7 HEATING AND AIR CONDITIONING

A. BUILDING SHELL:

1. Thermostats serving ancillary spaces shall be set to maintain temperatures between 72°F (+/- 3 degrees) 24 hours a day during Government workdays during the heating season, and between 74°F (+/- 3 degrees) 24 hours a day during the cooling season. These temperatures must be maintained throughout the ancillary spaces regardless of outside temperatures as described in Attachment A.
2. The warehouse space shall be capable of being maintained at temperatures above freezing with a minimum temperature of 32° F. Depending on the operational needs, portions of the space may be maintained at temperature of 60°F, as determined by the Government.
3. The Data Room should be designed to be 64°F -75°F degrees with 33-55% humidity measured at 5' above finished floor. Data Room temperatures and humidity need to be maintained at all times. If applicable, the communications rooms shall be maintained to be 58°F - 66°F degrees. Additionally, all supplemental units shall be on a regular maintenance schedule, to be assessed no less than three times each year.
4. Thermostats shall be secured from manual operation by key or locked cage. A key shall be provided to the local Navy representative.
5. Simultaneous heating and cooling are not permitted.
6. Areas having excessive heat gain or heat loss or affected by solar radiation at different times of the day, shall be independently controlled.
7. *Equipment Performance.* Temperature control for office spaces shall be assured by concealed central heating and air conditioning equipment. The equipment shall maintain space temperature control over a range of internal load fluctuations of plus 0.5 W/sqft. to minus 1.5 W/sqft. from initial design requirements of the tenant.
8. *HVAC Use (During Construction).* The permanent HVAC system may be used to move both supply and return air during the construction process only if the following conditions are met:
 - a. A complete air filtration system with 60 percent efficiency filters is installed and properly maintained;
 - b. No permanent diffusers are used;
 - c. No plenum-type return air system is employed;
 - d. The HVAC duct system is adequately sealed to prevent the spread of airborne particulate and other contaminants; and
 - e. Following the building “flush-out,” all duct systems are vacuumed with portable High- Efficiency Particulate Arrestance (HEPA) vacuums and documented clean in accordance with National Air Duct Cleaners Association (NADCA) specifications.

9. *Ductwork Re-use and Cleaning.* Any ductwork to be reused and/or to remain in place shall be cleaned, tested, and demonstrated to be clean in accordance with the standards set forth by NADCA. The cleaning, testing, and demonstration shall occur immediately prior to Government occupancy to avoid contamination from construction dust and other airborne particulates.
10. *Insulation.* All insulation shall contain recovered materials as required by EPA's CPG and related recycled content recommendations.
11. The Offeror shall conduct HVAC system balancing after any HVAC system alterations during the term of the lease and shall make a reasonable attempt to schedule major construction outside of office hours.
12. Offeror is responsible for installation, maintenance, troubleshooting, and replacement of supplemental air conditioning units to specifically service communications rooms and/or Data Room.
13. *Thermal Comfort.* During working hours in periods of heating and cooling, comply with ASHRAE Standard 55-2004, Thermal Comfort Conditions for Human Occupancy.

B. TENANT IMPROVEMENT INFORMATION:

1. *Zone Control.* Provide individual thermostat control for office space with control areas not to exceed 1,500 ANSI/BOMA office area square feet. Interior spaces must be separately zoned. Specialty occupancies (conference rooms, kitchens, etc.) must have active controls capable of sensing space use and modulating HVAC system in response to space demand. Areas that routinely have extended hours of operation shall be environmentally controlled through dedicated heating and air conditioning equipment. Special purpose areas (such as photocopy centers, large conference rooms, computer rooms, etc.) with an internal cooling load in excess of 5 tons shall be independently controlled. Provide concealed package air conditioning equipment to meet localized spot cooling of tenant special equipment. Portable space heaters are prohibited.

6.8 VENTILATION

BUILDING SHELL:

- A. Ventilation shall be provided in accordance with the latest edition of ANSI/ASHRAE Standard 62, Ventilation for Acceptable Indoor Air Quality.
- B. Air filtration shall be provided and maintained with filters having a minimum efficiency rating as determined by ANSI/ASHRAE Standard 52.2, *Method of Testing General Ventilation Air Cleaning Devices for Removal Efficiency by Particle Size*. Pre-filters shall be 30 percent to 35 percent efficient. Final filters shall be 80 percent to 85 percent efficient for particles at 3 microns.

- C. A minimum of 20 CFM of fresh air per person shall be provided in the building during periods of occupation in accordance with ASHRAE 62-1989.

6.9 VENTILATION: TOILET ROOMS

BUILDING SHELL:

Toilet rooms shall be property exhausted, with a minimum of 10 air changes per hour.

6.10 ELECTRICAL: GENERAL

The Offeror shall be responsible for meeting the applicable requirements of local codes and ordinances. When codes conflict, the more stringent standard shall apply. Main service facilities shall be enclosed. The enclosure may not be used for storage or other purposes and shall have door(s) fitted with an automatic deadlocking latch bolt with a minimum throw of 1/2 inch. Distribution panels shall be circuit breaker type with 10 percent spare power load and circuits.

6.11 ELECTRICAL: DISTRIBUTION

A. BUILDING SHELL:

- Main power distribution switchboards and distribution and lighting panel boards shall be circuit breaker type with copper buses that are properly rated to provide the calculated fault circuits. All power distribution panel boards shall be supplied with separate equipment ground buses. All power distribution equipment shall be required to handle the actual specified and projected loads plus 10 percent spare load capacity. Distribution panels are required to accommodate circuit breakers for the actual calculated needs plus 10 percent spare circuits that will be equivalent to the majority of other circuit breakers in the panel system. Electrical service shall be provided at 120/208 V, 3 phase, 4 wire with bond, 60 hertz. Power distribution shall include standard 20A, 120V, NEMA 5-20R circuits, and a minimum of four (4) dedicated 30A/208V/NEMA L6-30R circuits shall be provided. The Telecommunications Main Grounding Busbar (TMGB) must be bonded to the nearest electrical panel or directly to building steel to meet applicable grounding standards.
 1. Main distribution for standard office occupancy shall be provided at the Offeror's expense. In no event shall such power distribution (not including lighting and HVAC) for the Government demised area fall below 7 W per ANSI/BOMA Office Area square foot.
 2. Convenience outlets shall be installed in accordance with NFPA Standard 70, National Electrical Code, or local code, whichever is more stringent.
 3. Sufficient power capacity to support industrial equipment (e.g. forklifts charging, machinery).

B. TENANT IMPROVEMENT INFORMATION:

1. All electrical, telephone, and data outlets within the Government demised area shall be installed by the Offeror in accordance with the Final Layout Drawings. All electrical outlets shall be installed in accordance with NFPA Standard 70, or local code, whichever is more stringent.

2. All tenant outlets shall be marked and coded for ease of wire tracing; outlets shall be circuited separately from lighting. All floor outlets shall be flush with the plane of the finished floor.
3. The Offeror shall ensure that outlets and associated wiring (for electricity, voice, and data) to the workstation(s) shall be safely concealed in partitions, ceiling plenums, in recessed floor ducts, under raised flooring, or by use of a method acceptable to the RECO. In any case, cable on the floor surface shall be minimized.
4. The Offeror shall provide electrical infrastructure necessary to support connections to required equipment, including junction points and associated conduit or raceways necessary to support electrical connections to required equipment and door panels. Electrical service wiring shall be routed through ceilings or other designated connection locations. Electrical service shall be provided at 120V, 20A, and installed in accordance with applicable codes and standards.

6.12 TELECOMMUNICATIONS AND DATA WIRING: GENERAL

The Offeror shall provide all facilities necessary and suitable for delivering telephone and data service to and within the leased Premises, at no additional cost. Facility will require a dedicated Business-Class commercial internet connection with a minimum download speed of 1 Gbps (Gigabit per second) and upload speed of 1 Gbps (Gigabit per second). Outlets and the associated wiring shall be safely concealed in floor ducts, walls, columns, or below access flooring. The data cables must be installed in a conduit consisting of rigid pipe, Polyvinyl Chloride (PVC), or Electrical Metallic Tubing (EMT). All connections must be permanently sealed. The carrier (conduit) should be buried a minimum of one meter below the surface.

6.13 TELECOMMUNICATIONS: DISTRIBUTION AND EQUIPMENT

A. BUILDING SHELL:

1. Sufficient space shall be provided on the floor(s) where the Government occupies space for the purposes of terminating telecommunications service into the building. The building's telecommunications closets located on all floors shall be vertically stacked. Telecommunications switch rooms, wire closets, and related spaces shall be enclosed. The enclosure shall not be used for storage or other purposes and shall have door(s) fitted with an automatic door-closer and deadlocking latch bolt with a minimum throw of 1/2 inch.
2. Telecommunications switch rooms, wire closets, and related spaces shall meet wire closets, and related spaces shall meet applicable Telecommunications Industry Association (TIA) and Electronic Industries Alliance (EIA) standards. These standards include the following:
 - a. TIA/EIA-568, Commercial Building Telecommunications Cabling Standard,
 - b. TIA/EIA 569-B, Commercial Building Standard for Telecommunications Pathways and Spaces,

- c. TIA/EIA-570, Residential and Light Commercial Telecommunications Wiring Standard, and
 - d. TIA/EIA-607-B, Commercial Building Grounding and Bonding Requirements for Telecommunications Standard.
3. Telecommunications switch rooms, wire closets, and related spaces shall meet applicable NFPA standards. Bonding and grounding shall be in accordance with NFPA Standard 70, National Electrical Code, and other applicable NFPA standards and/or local code requirements.
 4. Offeror shall provide all rough-in infrastructure necessary to support communications cabling, including conduit, pull strings, boxes, and cable trays, from the point of connection in the server room to designated end locations. Offeror shall provide power to the network cabinets. The Government will provide communication cabling, badge readers, server hub equipment and perform final connections.

B. TENANT IMPROVEMENT INFORMATION:

COMDATA, DMARC, or other similar communication unit boxes must be provided as required. At a minimum, each communication box shall be capable of housing four Category 6E (CAT 6E at a minimum) jacks and wires. The Offeror shall ensure that all outlets and associated wiring, copper, coaxial cable, optical fiber, or other transmission medium used to transmit telecommunications (voice, data, video, Internet, or other emerging technologies) service to the workstation shall be safely concealed under raised floors, in floor ducts, walls, columns, or molding. All outlets/junction boxes shall be provided with rings and pull strings to facilitate the installation of cable. Some transmission medium may require special conduit, inner duct, or shielding as specified by the Government.

6.14 TELECOMMUNICATIONS: LOCAL EXCHANGE ACCESS

A. BUILDING SHELL:

1. The Government reserves the right to contract its own telecommunications (voice, data, video, Internet or other emerging technologies) service in the space to be leased. The Government may contract with one or more parties to have inside wiring (or other transmission medium) and telecommunications equipment installed.
2. The Offeror shall allow the Government's designated telecommunications providers access to utilize existing building wiring to connect its services to the Government's space. The existing building space should be able to handle the transmission of eight T-1s from the Government's designated telecommunications providers to the communications closet, which will serve the occupied space. The Offeror shall provide access from the point of entry into the building to the Government's floor space, subject to any inherent limitations in the pathway involved.
3. The Offeror shall allow the Government's designated telecommunications providers to affix telecommunications antennae (high frequency, mobile, microwave, satellite, or

other emerging technologies), subject to weight and wind load conditions, to roof, parapet, or building envelope as required. Access from the antenna(e) to the leased space shall be provided.

4. The Offeror shall allow the Government's designated telecommunications providers to affix antennae and transmission devices throughout its leased space and in appropriate common areas frequented by the Government's employees so as to allow the use of wireless telephones and communications devices necessary to conduct business.

B. SEALED CONDUIT:

Should the Government's security requirements require sealed conduit to house the telecommunications transmission medium, the Offeror shall provide such conduit.

6.15 DATA DISTRIBUTION

TENANT IMPROVEMENT INFORMATION:

The Government shall at its expense be responsible for purchasing and installing data cable. The Offeror shall reimburse the Government for the repair and/or replacement of any damage to installed cable(s), whether internal or external, according to the specifications in the SFO, at the Offeror's expense if the damage is caused by the Offeror and/or its subcontractors. If the Offeror is unable to repair or replace the cable(s) then the cost shall be provided by the Offeror to the Government to replace the cable. The Offeror shall ensure that data outlets and the associated wiring used to transmit data to workstations shall be safely concealed in floor ducts, walls, columns, or below access flooring. The Offeror shall provide outlets, which shall include rings and pull strings to facilitate the installation of the data cable. When cable consists of multiple runs, the Offeror shall provide ladder type cable trays to ensure that Government provided cable does not come into contact with suspended ceilings. Cable trays shall form a loop around the perimeter of the Government demised area such that they are within a 30-foot, 0-inch horizontal distance of any single drop.

6.16 ELECTRICAL, TELEPHONE, DATA FOR SYSTEMS FURNITURE

TENANT IMPROVEMENT INFORMATION:

1. The Offeror shall provide separate data/telephone, and electric junction boxes for the base feed connections to Government provided modular or systems furniture, when such feeds are supplied via wall outlets or floor penetrations. When overhead feeds are used, junction boxes shall be installed for electrical connections. Raceways shall be provided throughout the furniture panels to distribute the electrical, telephone, and data cable. The Offeror shall provide all electrical service wiring and connections to the furniture at designated junction points. Each electrical junction shall contain four general purpose 120V circuits with separate hot, neutral and ground wires. A 20A circuit shall have no more than eight general-purpose receptacles or four isolated ground "computer" receptacles.
2. The Government shall at its expense be responsible for purchasing data and telecommunications cable. Said cable shall be installed and connected to systems furniture by

the Offeror/contractor with the assistance and/or advice of the Government or computer vendor. The Offeror shall provide wall mounted data and telephone junction boxes, which shall include rings and pull strings to facilitate the installation of the data and telecommunications cable. When cable consists of multiple runs, the Offeror shall provide ladder type cable trays to ensure that Government provided cable does not come into contact with suspended ceilings. Cable trays shall form a loop around the perimeter of the Government demised area such that they are within a 30-foot, 0-inch horizontal distance of any single drop. Said cable trays shall provide access to both telecommunications data closets and telephone closets.

3. The Offeror shall furnish and install suitably sized junction boxes in the vicinity of the “feeding points” of the furniture panels. All “feeding points” shall be shown on Government approved Final Layout Drawings. The Offeror shall temporarily cap off the wiring in the junction boxes until the furniture is installed during Phase 2. The Offeror shall make all connections in the power panel and shall keep the circuit breakers off. The Offeror shall identify each circuit with the breaker number and shall identify the computer hardware to be connected to it. The Offeror shall identify each breaker at the panel and identify the devices that it serves.
4. PHASE 2 involves the Offeror’s electrical contractor connecting power poles or base feeds in the junction boxes to the furniture electrical system and testing all pre-wired receptacles in the systems furniture. It also involves other Government contractors who will be installing the data cable in the furniture panels for the terminal and printer locations, installing the connectors on the terminal/printer ends of the cable, and continuity testing each cable. All Phase 2 work shall be coordinated and performed in conjunction with the furniture, telephone, and data cable installers. Much of this work may occur over a weekend on a schedule that requires flexibility and on-call visits.

6.17 ELEVATORS

- A. The Offeror shall provide suitable passenger and freight elevator service to any Government demised area not having ground level access. Service shall be available during the hours specified in the “Normal Hours” paragraph in the UTILITIES, MAINTENANCE, SERVICES Section 7.0 of this SFO. However, one passenger elevator shall be available at all times for Government use if the Government space is above the ground floor. The freight elevator shall be accessible to the loading areas. When possible, the Government shall be given 24-hour advance notice if the service is to be interrupted for more than 1-1/2 hours. Normal service interruption shall be scheduled outside of the Government’s normal working hours. The Offeror shall also use best efforts to minimize the frequency and duration of unscheduled interruptions.

B. CODE:

Elevators shall conform to the current edition of the American Society of Mechanical Engineers ANSI/ (ASME) A17.1, *Safety Code for Elevators and Escalators*, except that elevator cabs are not required to have a visual or audible signal to notify passengers during automatic recall. Elevator lobby smoke detectors shall not activate the building fire alarm

system but shall signal the fire department or central station services and capture the elevators. The elevator shall be inspected and maintained in accordance with the current edition of the ANSI/ASME A17.2, *Inspectors' Manual for Elevators*. All elevators shall meet ABAAS requirements.

C. SAFETY SYSTEMS:

Elevators shall be equipped with telephones or other two-way emergency signaling systems. The system used shall be marked and shall reach an emergency communication location staffed during normal operating hours when the elevators are in service. When Government occupancy is three or more floors above grade, automatic elevator emergency recall is required.

D. SPEED:

The passenger elevators shall have a capacity to transport in 5 minutes 15 percent of the normal population of all upper floors (based on 150 square feet per person). Further, the dispatch interval between elevators during the up-peak demand period shall not exceed 35 seconds.

E. INTERIOR FINISHES:

Elevator cab walls shall be hardwood, marble, granite, or an equivalent pre-approved by the RECO. Elevator cab floors shall be marble, granite, terrazzo, or an equivalent.

6.18 LIGHTING: INTERIOR AND PARKING

The Offeror shall provide interior lighting in accordance with the following:

1. Modern, diffused, recessed fluorescent lighting fixtures shall be provided in the office area. Such fixtures shall be capable of producing a light level of 50 average maintained foot-candles at working surface height throughout the space. Warehouse space fixtures shall be capable of producing a light level of 20 average-maintained foot-candles throughout the space. When the space is not in use by the Government, interior and exterior lighting, except that essential for safety and security purposes, shall be turned off. Switches must be located near each door entrance.
2. Exterior parking areas, vehicle driveways, pedestrian walkways, and building perimeter shall have 5 foot-candles for doorway areas, 3 foot-candles for transition areas (including stairwells), and at least 1 foot-candle overlapping throughout the lot, except where local codes conflict. Illumination shall be designed based on Illuminating Engineering Society of North America (IESNA) standards. Indoor parking shall have a minimum of 10 foot-candles and shall be designed based on IESNA standards. The intent is to provide adequate lighting at entrances/exits, garages, parking lots or other adjacent areas to the building to discourage crimes against persons.
3. Lighted exit signs, each with a battery pack, shall be provided throughout the building in accordance with buildings and fire codes. Battery pack emergency lights must be provided in all means of egress in accordance with National Standards.

4. The Offeror shall provide occupancy sensors and/or scheduling controls through the building automation system to reduce the hours that the lights are on when the space is unoccupied. The Offeror shall provide daylight dimming controls in atriums or within 15 feet of windows where daylight can contribute to energy savings.

6.19 BREAKROOM

Breakroom shall include cabinets, refrigerator, sink, and a microwave. The refrigerator shall be a model without an ice maker and water dispenser. If such model cannot be provided, the Offeror is responsible for providing the necessary filter replacements in order to maintain the function of the ice and water features.

7.0 UTILITIES, MAINTENANCE, SERVICES

7.1 UTILITIES, MAINTENANCE, SERVICE: GENERAL

Utilities, maintenance and services shall be provided by the Offeror as part of the rental consideration. The Offeror is responsible for the total maintenance and repair of the leased Premises. The Offeror shall have a building superintendent or a locally designated representative available to promptly correct deficiencies. The Offeror shall provide the labor, material, and supervision to adequately maintain the structure in its entirety, including the roof, exterior of the building, interior walls and windows, doors, and any other necessary building appurtenances to provide watertight integrity, structural soundness and acceptable appearance of the Premises. The Offeror shall properly maintain the outside areas, including plants, lawns, and lighting. The Offeror shall provide and maintain all lighting: bulbs, tubes, ballasts and starters. The Offeror shall provide and maintain all building equipment and systems in accordance with applicable technical publications, manufacturers' manuals and industry standards. Maintenance shall include regular servicing and filter replacement. The Offeror shall maintain all applicable electrical, plumbing, HVAC and utility systems in good working condition. Repairs shall be made in timely fashion-48 hours for routine maintenance and two hours for emergencies such as loss of power, heat or water. All equipment and systems shall be maintained to provide reliable energy efficient service without unusual interruption, disturbing noises, exposure to fire or safety hazards, uncomfortable drafts, excessive air velocities, or unusual emissions of dirt. Maintenance work must be done in accordance with local and manufacturer codes and regulations. Inspection certificates must be displayed, as applicable.

7.2 NORMAL HOURS

The leased space will be used twenty-four (24) hours a day, seven (7) days per week, including holidays. Utilities, maintenance and services shall be available, twenty-four (24) hours, seven (7) days a week, including federal holidays. The Government shall have access to the leased space at all times without additional payment, including the use of necessary services and utilities such as toilets, lights, and electric power. For the purpose of scheduling repairs and maintenance work, working hours shall be considered 7 a.m. to 5 p.m. Monday through Friday and shall be coordinated with the local Government representative.

7.3 OVERTIME USAGE

- A. The Government shall have access to the leased space at all times without additional payment, including the use, during other than normal hours, of necessary services and utilities such as elevators, toilets, and electricity, except heating and cooling.
- B. If heating or cooling is required on an overtime basis, such services will be ordered in writing by the RECO or the local Navy representative. When ordered, services shall be provided at the hourly rate established in the contract.
- C. An invoice from the Offeror shall be submitted to the official placing the order for certification and payment. At the option of the Government, the order may be paid for by Government credit card. The two clauses from Attachment C, *U.S. Government Lease for Real Property*, General Clauses, 552.232-75, *Prompt Payment*, and 552.232-70, *Invoice Requirements (Variation)*, apply to all orders for overtime services.
- D. All orders are subject to the terms and conditions of this lease. In the event of a conflict between an order and this lease, the lease shall control.

7.4 UTILITIES

- 1. The Offeror shall ensure that utilities necessary for operation are provided and that all associated costs are included as a part of the established rental rate. The Offeror shall provide all systems and infrastructure required to deliver electric, telephone, and gas service to the building, and all services required for water and sewer, whether directly or through the pertinent utility supplier. If the pertinent utility suppliers do not construct the utility systems, the Offeror in accordance with the requirements of all the pertinent utility service suppliers shall construct them. The Offeror shall provide a separate electrical and gas meter for the leased space occupied by the Government, or a means of allocating costs which is acceptable to the Government.
- 2. Upon the effective date of the lease, the Offeror shall provide regular quarterly reports of the amount of all utilities consumed at the building in monthly detail for the duration of the Lease. These reports must be provided within 45 days of the end of each quarterly period and shall be in either written or electronic form, as requested by the Government. The reports shall contain the number of actual units consumed. If reports are available detailing only the Government's consumption, then the reports shall be limited solely to the Government's consumption. Additionally, said reports shall indicate, for each utility being reported, the use of the specific utility.
- 3. Offeror shall obtain a statement from a registered professional engineer stating that all HVAC, plumbing, and other energy intensive Building systems can operate under the control conditions stated in the lease. The statement shall also identify all Building systems that do not conform to the system performance values, including the "recommended" or "suggested" values of ANSI/ASHRAE Standard 90.1, "Energy Efficiency Design of New Buildings Except Low Rise Residential Buildings," or more restrictive state and local codes.

7.5 JANITORIAL SERVICES

- A. The Offeror is responsible to provide janitorial services to the office area, shower areas and bathrooms only. If the Government requires a breakroom, janitorial services may be required for this area. Cleaning of the office area and bathrooms shall be performed during tenant working hours between Monday through Friday.

B. SELECTION OF CLEANING PRODUCTS:

The Offeror shall make careful selection of janitorial cleaning products and equipment to:

1. use products that are packaged ecologically;
2. use products and equipment considered environmentally beneficial and/or recycled products that are phosphate-free, non-corrosive, non-flammable, and fully biodegradable; and
3. minimize the use of harsh chemicals and the release of irritating fumes.
4. Examples of acceptable products may be found at <https://www.gsa.gov/real-estate/historic-preservation/historic-preservation-policy-tools/preservation-tools-resources/technical-procedures/types-of-cleaning-detergents>.

C. SELECTION OF PAPER PRODUCTS:

The Offeror shall select and provide within the leased costs paper and paper products (i.e., bathroom tissue and paper towels) with recycled content conforming to the EPA CPG.

- D. The Offeror shall maintain the leased Premises, including outside areas, in a clean condition and shall provide supplies and equipment. The following schedule describes the level of services intended. Performance will be based on the RECO evaluation of results, not the frequency or method of performance.

1. Daily. Clean drinking fountains. Sweep and damp mop or scrub toilet rooms. Clean all toilet fixtures and replenish toilet supplies. Dispose of all trash and garbage generated in or about the bathrooms and breakroom areas. Police or clear sidewalks, parking areas, and driveways of debris. Sweep loading dock areas and platforms.
2. Daily (Monday through Friday). Empty trash receptacles, ensuring a clean plastic liner is available in each trash receptacle in cubicle work areas and offices.
3. Weekly. Damp mop and spray buff all resilient floors in toilets and breakroom areas. Spray buff main corridors, entrances and lobbies. Clean glass entry doors to the Government demised area. Sweep or vacuum stairs. Clean elevators and escalators. Disposal of smoking materials in outdoor area.
4. Annually. Strip and refinish floors in office areas, secondary lobbies and corridors. Shampoo all carpets.
5. Every Five Years. Dry clean or wash (as appropriate) all draperies.

6. As Required. Properly maintain plants and lawns. Remove snow and ice from entrances, exterior walks, and parking lots of the building. Provide initial supply, installation, and replacement of light bulbs, tubes, ballasts, and starters. Replace worn floor coverings (this includes the moving and returning of furnishings).
7. Cleaning and disinfecting requirements. The Offeror shall routinely wipe down all solid, high contact surfaces in common and high traffic areas using soap and water, followed by a disinfectant from the EPA-registered list of products. Cleaning staff shall use products in accordance with directions provided by the manufacturer, including the use of personal protective equipment (PPE), if applicable. Disinfection application and products should be chosen so as to not damage interior finishes or furnishings.

7.6 LANDSCAPE MAINTENANCE

Landscape maintenance shall be performed during the growing season on a weekly cycle and shall consist of watering, mowing, and policing the area to keep it free of debris. Pruning and fertilization shall be done on an as needed basis. In addition, dead or dying plants shall be replaced. Landscape management practices shall prevent pollution by employing practices which avoid or minimize the need for fertilizers and pesticides. The Offeror shall use landscaping products with recycled content as required by the Environmental Protection Agency's (EPA's) Comprehensive Procurement Guidelines for landscaping products.

7.7 PEST CONTROL

The Offeror is responsible for providing and maintaining the Premises in a pest-free condition at all times. In the event of a pest infestation during the lease term, the Government shall notify the Offeror. The Offeror is responsible for arranging pest control services to address the issue. The Offeror must use Integrated Pest Management techniques, as specified in the GSA Environmental Management Integrated Pest Management Technique Guide (E402-1001).

7.8 FLAGPOLE

If the Government is the sole occupant of the building, a flagpole shall be provided at a location to be approved by the RECO. The flag of the United States of America will be provided by the Offeror, as part of the rental rate, and replaced at all times during the Lease term when showing signs of wear, damage, or tear. If the Government is not the sole occupant of the building, and if the Offeror has a flagpole, the Offeror is responsible for maintaining the flagpole and the flag of the United States of America at no additional charge to the Government.

7.9 TRASH REMOVAL

The Offeror is responsible for providing a six (6) cubic yard dumpster and ensuring that it is emptied every other week. Offeror is responsible for dumpster removal/replacement.

7.10 SNOW REMOVAL

The Offeror is responsible for removing snow and ice from the entrance, exterior walks, driveways and parking lots to the building.

7.11 MAINTENANCE AND TESTING OF SYSTEMS

- A. The Offeror is responsible for the total maintenance and repair of the leased Premises. Such maintenance and repairs include site and private access roads. All equipment and systems shall be maintained to provide reliable, energy efficient service without unusual interruption, disturbing noises, exposure to fire or safety hazards, uncomfortable drafts, excessive air velocities, or unusual emissions of dirt. The Offeror's maintenance responsibility includes initial supply and replacement of all supplies, materials, and equipment necessary for such maintenance, including replacement of all HVAC filters. Maintenance, testing, and inspection of appropriate equipment and systems shall be done in accordance with applicable codes, and inspection certificates shall be displayed as appropriate. Copies of all records in this regard shall be forwarded to the local Navy Representative or a designated representative.
- B. Without any additional charge, the Government reserves the right to require documentation of proper operations or testing prior to occupancy of such systems as fire alarm, sprinkler, emergency generator, etc. to ensure proper operation. These tests shall be witnessed by a designated representative of the RECO.

7.12 SERVICE CALLS

Service Calls: Service calls are requests for work made to the Offeror's designated maintenance personnel by the local Navy representative. The work requirements resulting from service calls will be completed in accordance with the level and quality of maintenance standards established herein and within the specified time limits for each type of service call. The Offeror shall develop forms and a system for tracking and documenting service calls. The Offeror's system shall provide a mechanism for obtaining the signature of the local Navy representative or appointed designee for all completed service call work and shall include a description of the work performed.

A. Classification of Service Calls:

1. Emergency Service Calls: The Offeror shall respond to service calls classified as emergency service calls within 60 minutes after receipt of the call, 24 hours per day, seven days per week. Once begun, the Offeror shall prosecute the work to completion. Emergency service calls consist of correcting failures in service or facilities which endanger occupants or property or break security. Examples of emergency service calls are overflowing drains, broken water pipes, electrical service outage, broken electrical components which may cause fire or shock to persons, gas leaks, complete failure of Offeror supplied equipment, problems which would render the space uninhabitable, or inability to lock or unlock an exterior door.
2. Urgent Service Calls: The Offeror shall respond to service calls classified as urgent calls within 24 hours after receipt of the call seven days per week. Once on-site, the Offeror shall prosecute the work to completion. Urgent service calls consist of correcting failures in service or facilities which do not immediately endanger the occupants or threaten damage to property but would soon inconvenience and affect the health or well-being of

the Government occupant and visitors. Examples of urgent service calls include heating, air conditioning equipment and water heaters' failures or issues. When the Offeror determines that the equipment cannot be repaired within 48 hours of the call or the equipment must be removed for repairs, the Offeror shall remove the failing equipment and install clean properly operating equipment. The removed equipment shall be cleaned by the Offeror.

3. Routine Service Calls: The Offeror shall complete routine service calls within ten (10) calendar days of receipt of call, during normal working hours. Routine service calls consist of calls which cannot be classified as emergency or urgent. Included, but not limited to, repair of windows, floors, counters and cabinets, freeing binding doors, repair of bathroom tile, and etc. Routine service calls requiring maintenance, repair, or replacement shall be completed prior to the end of normal working hours on the day the work started. If it is not possible to complete the work, the area shall be reassembled, and left in a clean orderly condition, and the work shall be completed the next working day.

- B. Rework: The Offeror shall correct, as required, those maintenance deficiencies with respect to service calls which are due to poor workmanship, unsatisfactory completion, failure during warranty period or neglect. Rework will be affected within three working days from notification of Offeror by the local Navy representative of the requirement.

8.0 SAFETY AND ENVIRONMENTAL MANAGEMENT

8.1 CERTIFICATE OF OCCUPANCY

The Offeror shall provide a valid Certificate of Occupancy, issued by the local jurisdiction, for the intended use of the Government and shall maintain and operate the building in conformance with current local codes and ordinances. If the local jurisdiction does not issue Certificates of Occupancy, the Offeror shall obtain the services of a licensed fire protection engineer to verify the offered space meets all applicable Federal, Department of Defense UFC 3-600-01, state, and local codes and ordinances to ensure an acceptable level of safety is provided.

8.2 ENVIRONMENTAL CONSIDERATION

- a. The Government requests space with no known hazardous conditions or recognized environmental conditions that would pose a health and safety risk or environmental liability to the Government.
- B. Upon request by the Government, Offeror must provide all known previous use of the offered Space, Building or Property.
- C. Offeror must indicate in its written offer any known hazardous conditions or environmental releases with/from the offered Space, Building or Property.

8.3 ENVIRONMENTAL DUE DILIGENCE

- A. Offeror must allow Government and/or its Contractors site access for the purpose of collecting information for environmental due diligence studies.

- B. If any recognized environmental conditions (RECs) are identified, the Offeror will be responsible for addressing such RECs, at its sole cost and expense, in accordance with federal and state standards and requirements and submitting a proposed schedule for complying with these obligations. The Government will evaluate whether the nature of any of the RECs, any completed cleanup, and the proposed schedule meet the Government's needs. The Government reserves the right to reject any offer or lease award based on the outcome of the environmental due diligence process.

8.4 NATIONAL ENVIRONMENTAL POLICY ACT (NEPA)

- A. The Government is responsible for compliance with NEPA, whether in whole or in part, on its own or with the assistance of the Offerors. NEPA requires federal agencies to consider the effects of their actions on the quality of the human environment as part of the federal decision-making process and, to that end, the Government's obligations may, and in some cases will, be augmented by the Offerors as described in greater detail in the SFO.
- B. The Government may either request information from the Offerors to help it meet its obligations under NEPA or share information provided in response to this provision with federal, state and local regulatory agencies as part of its compliance responsibilities under NEPA and other applicable federal, state and local environmental laws and regulations. Further consultation with these regulatory agencies may be necessary as part of the NEPA process.
- C. The Offerors are advised that the Government may be required to release the location of each offered site and other building specific information in public hearings or in public NEPA documents. By submitting an offer in response to this SFO and without the need for any further documentation, the Offeror acknowledges and consents to such release.
- D. The Government reserves the right to reject any offer where (i) the NEPA-related documentation provided by the Offeror for the offered Property is inadequate, (ii) the offer entails unacceptably adverse impacts on the human environment, (iii) the identified adverse impacts cannot be readily mitigated, or (iv) the level of NEPA analysis is more extensive than is acceptable to the Government (e.g., offers must be of a nature that would allow NEPA to be satisfied by preparation of a Categorical Exclusion (CATEX) NEPA study or an Environmental Assessment (EA) with or without mandatory mitigation).
- E. An Offeror must allow the Government access to the offered Property to conduct studies in furtherance of NEPA compliance. This requires research and field surveys to assess the potential impacts to the natural, social and cultural environments. Any recent studies previously conducted by the Offeror may be submitted to be included in the NEPA process.
- F. The Government will not proceed with Lease execution until the NEPA process is complete as evidenced by the Government's issuance of a completed Categorical Exclusion (CATEX), Environmental Assessment or Environmental Impact Statement. Upon Lease execution any mitigation measures, whether optional or mandatory, identified and adopted by the Government will become Lease obligations. All costs and expenses for development of

design alternatives, mitigation measures and review submittals for work to be performed under the Lease will be the sole responsibility of Offeror.

8.5 NATIONAL HISTORIC PRESERVATION ACT REQUIREMENTS

- A. The Government is responsible for complying with section 106 of the National Historic Preservation Act of 1966, as amended, 54 U.S.C. § 306108 (Section 106). Section 106 requires federal agencies to consider the effects of their actions on historic properties prior to expending any federal funds on the undertaking. The Government is responsible for identifying whether any historic properties exist in, on, under, or near the offered Property that could be affected by the leasing action. Historic properties include both above-grade (i.e., buildings and historic districts) and below-grade (i.e., archeological sites) resources. The Government is responsible for assessing effects to identified historic properties and for consulting with the State Historic Preservation Officer (SHPO), the Tribal Historic Preservation Officer (THPO), if applicable, any local Historic Preservation or Landmarks Commission, and other interested parties, if applicable, in accordance with the implementing regulations set forth at 36 C.F.R. part 800 (Protection of Historic Properties).
- B. An Offeror must allow the Government access to the offered Property to conduct studies in furtherance of the Section 106 compliance. This requires research and field surveys to assess the potential presence of historic properties that may be affected by construction activity, both above- and below-grade. Compliance also may require below-grade testing to determine the presence of archeological resources and possible artifact recovery, recordation and interpretation mitigation measures.
- C. Demolition or destruction of a historic property by an Offeror in anticipation of an award of a Government lease may disqualify the Offeror from further consideration.
- D. The Government reserves the right to reject any offer where documentation for the offered Property is inadequate or otherwise indicates preservation concerns or adverse effects to historic properties that cannot be reasonably mitigated.

8.6 FIRE PROTECTION AND LIFE SAFETY

- A. Offered space shall meet or be upgraded to meet prior to occupancy, the applicable egress requirements in the National Fire Protection Association (NFPA) 101, *Life Safety Code*, or an alternative approach or method for achieving a level of safety deemed equivalent and acceptable by the Government.
- B. Offered space shall provide unrestrictive access to a minimum of two remote exits on each floor of Government occupancy. Scissor stairs shall only be counted as one approved exit. Open air exterior fire escapes shall not be counted as an approved exit.

8.7 AUTOMATIC FIRE SPRINKLER SYSTEM

- A. Offered space located below-grade, including parking garage areas, and all areas in a building referred to as "hazardous areas" (defined in NFPA 101) that are located within the entire building (including non-Government areas) shall be protected by an automatic fire sprinkler system or an equivalent level of safety.
- B. For buildings in which any portion of the offered space is on or above the sixth floor, then, at a minimum, the building up to and including the highest floor of Government occupancy shall be protected by an automatic fire sprinkler system or an equivalent level of safety.
- C. For buildings in which any portion of the offered space is on or above the sixth floor, and lease of the offered space will result, either individually or in combination with other Government leases in the offered building, in the Government leasing 35,000 square feet or more ANSI/BOMA Office Area square feet of space in the offered building, then the entire building shall be protected throughout by an automatic fire sprinkler system or an equivalent level of safety.
- D. Automatic sprinkler system(s) shall be maintained in accordance with the requirements of the applicable local codes or NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-based Fire Protection Systems*.
- E. **Definitions:**
 - 1. "Automatic sprinkler system" means an electronically supervised, integrated system of underground and overhead piping, designed in accordance with National Fire Protection Association (NFPA) 13, *Installation of Sprinkler Systems*. The system is usually activated by heat from fire and discharges water over the fire area. The system includes an adequate water supply.
 - 2. "Equivalent level of safety" means an alternative design or system (which may include automatic sprinkler systems), based upon fire protection engineering analysis, which achieves a level of safety equal to or greater than that provided by automatic sprinkler systems.

8.8 FIRE ALARM SYSTEM

- A. A building-wide fire alarm system shall be installed in buildings in which any portion of the offered space is located two or more stories above the lowest level of exit discharge. The fire alarm system shall meet the installation and operational requirements of the applicable local codes and ordinances (current as of the date of this SFO) adopted by the jurisdiction in which the building is located. Provide fire alarm pull boxes at each exterior exit.
- B. The fire alarm system shall be maintained in accordance with the requirements of the applicable local codes or NFPA 72, *National Fire Alarm Code*. The fire alarm system wiring, and equipment shall be electrically supervised and shall automatically notify the local fire department or approved central station. Emergency power shall be provided for the fire alarm system.

- C. If a building's alarm control unit is over 25 years old, the Offeror shall install a new fire alarm system in accordance with the requirements of NFPA 72, National Fire Alarm Code (current as of the award of the lease) or applicable local codes prior to Government acceptance and occupancy of the offered space.

8.9 SEISMIC SAFETY

To meet the seismic safety requirements means that the Offeror has provided a written certification (see Attachment I) from a licensed professional engineer, qualified to practice structural and earthquake engineering, certifying that the subject building construction is in full compliance with the Basic Performance Objective for Existing Buildings (BPOE) as described in NIST IR 8458e2022, ICSSC RP 10, Standards of Seismic Safety for Existing Federally Owned and Leased Buildings. Full compliance means that the subject building conforms to exemption criteria (RP10 Section 1.3), benchmark criteria (RP 10 Section 1.4) or the minimum performance objective for deterministic seismic evaluation of existing buildings (RP 10 Section 2.1.2).

8.10 OSHA REQUIREMENTS

The Offeror shall maintain buildings and space in a safe and healthy condition in accordance with applicable parts of the OSHA General Industry Standard (29 CFR 1910 Occupational Safety and Health Standards).

8.11 ASBESTOS

- A. Offers are requested for space with no asbestos-containing materials (ACM), or with ACM in a stable, solid matrix (e.g., asbestos flooring or asbestos cement panels) which is not damaged or subject to damage by routine operations. For purposes of this paragraph, ACM is defined as any materials with a concentration of greater than 1 percent by dry weight of asbestos; "space" includes the 1) space offered for lease; 2) common building area; 3) ventilation systems and zones serving the space offered; and 4) the area above suspended ceilings and engineering space in the same ventilation zone as the space offered. If no offers are received for such space, the Government may consider space with thermal system insulation ACM (e.g., wrapped pipe or boiler lagging) which is not damaged or subject to damage by routine operations.
- B. Space with ACM of any type or condition may be upgraded by the Offeror to meet the conditions described in subparagraph A by abatement (removal, enclosure, encapsulation, or repair) of ACM not meeting those conditions. If an offer involving abatement of ACM is accepted by the Government, the Offeror shall, prior to occupancy, successfully complete the abatement in accordance with OSHA, EPA, Department of Transportation (DOT), state, and local regulations and guidance.
- C. *Management Plan.* If space is offered which contains ACM, the Offeror shall submit an asbestos-related management plan for acceptance by the Government prior to lease award. This plan shall conform to EPA guidance, be implemented prior to occupancy, and be revised promptly when conditions affecting the plan change. If asbestos abatement work is to be performed in the space after occupancy, the Offeror shall submit to the RECO the occupant

safety plan and a description of the methods of abatement and re-occupancy clearance, in accordance with OSHA, EPA, DOT, state, and local regulations and guidance, at least 4 weeks prior to the abatement work.

8.12 INDOOR AIR QUALITY

- A. The Offeror shall control contaminants at the source and/or operate the space in such a manner that the GSA indicator levels for carbon monoxide (CO), carbon dioxide (CO₂), and formaldehyde (HCHO) are not exceeded. The indicator levels for office areas shall be CO – 9 ppm time-weighted average (TWA – 8 - hour sample); CO₂ - 1,000 ppm (TWA); HCHO - 0.1 ppm (TWA).
- B. The Offeror shall make a reasonable attempt to apply insecticides, paints, glues, adhesives, and HVAC system cleaning compounds with highly volatile or irritating organic compounds, outside of working hours. The Offeror shall provide at least 72 hours advance notice to the Government before applying noxious chemicals in occupied spaces and shall adequately ventilate those spaces during and after application.
- C. The Offeror shall promptly investigate indoor air quality (IAQ) complaints and shall implement the necessary controls to address the complaint.
- D. The Government reserves the right to conduct independent IAQ assessments and detailed studies in space that it occupies, as well as in space serving the Government demised area (e.g., common use areas, mechanical rooms, HVAC systems, etc.). The Offeror shall assist the Government in its assessments and detailed studies by 1) making available information on building operations and Offeror activities; 2) providing access to space for assessment and testing, if required; and 3) implementing corrective measures required by the RECO.
- E. The Offeror shall provide to the Government safety data sheets (SDS) upon request for the following products prior to their use during the term of the lease: adhesives, caulking, sealants, insulating materials, fireproofing or firestopping materials, paints, carpets, floor and wall patching or leveling materials, lubricants, clear finish for wood surfaces, janitorial cleaning products, pesticides, rodenticides, and herbicides. The Government reserves the right to review such products used by the Offeror within 1) the Government demised area; 2) common building areas; 3) ventilation systems and zones serving the leased space; and 4) the area above suspended ceilings and engineering space in the same ventilation zone as the lease space.
- F. Where hazardous gasses or chemicals (any products with data in the Health and Safety section of the SDS sheets) may be present or used, including large-scale copying and printing rooms, segregate areas with deck-to-deck partitions with separate outside exhausting at a rate of at least 0.5 cubic feet per minute per square foot, no air recirculation. The mechanical system must operate at a negative pressure compared with the surrounding spaces of at least an average of 5 Pa (pascal) (0.02 inches of water gauge) and with a minimum of 1 Pa (0.004 inches of water gauge) when the doors to the rooms are closed.

8.13 RADON IN AIR

If space planned for occupancy by the Government is on the second floor above grade or lower, the Offeror shall, prior to occupancy, test the leased space for two days to three days using charcoal canisters or electric ion chambers to ensure that radon in air levels is below EPA's action concentration of 4 picocuries per liter. After the initial testing, a follow-up test for a minimum of 90 days using alpha track detectors or electric ion chambers shall be completed. For further information on radon, see EPA's website on radon at <https://www.epa.gov/radon/epa-map-radon-zones>.

- A. Where hazardous gasses or chemicals (any products with data in the Health and Safety section of the SDS sheets) may be present or used, including large-scale copying and printing rooms, segregate areas with deck-to-deck partitions with separate outside exhausting at a rate of at least 0.5 cubic feet per minute per square foot, no air recirculation. The mechanical system must operate at a negative pressure compared with the surrounding spaces of at least an average of 5 Pa (pascal) (0.02 inches of water gauge) and with a minimum of 1 Pa (0.004 inches of water gauge) when the doors to the rooms are closed.

8.14 HAZARDOUS MATERIALS

The leased space shall be free of hazardous materials according to applicable federal, state, and local environmental regulations. Storage for HAZMAT will be supplied by the Government. A material safety data sheet (MSDS) for the materials can be supplied for review upon request.

8.15 RECYCLING

Where state or local law, code, or ordinance requires recycling programs (including mercury containing lamps) for the space to be provided pursuant to this SFO, the successful Offeror shall comply with such state and/or local law, code, or ordinance in accordance with Attachment C, U.S. Government Lease for Real Property, General Clauses, 552.270-8, Compliance with Applicable Law. In all other cases, the successful Offeror shall establish a recycling program for (at a minimum) paper, corrugated cardboard, glass, plastics, and metals where local markets for recovered materials exist. Provide an easily accessible, appropriately sized (2 square feet per 1,000 square feet of building gross floor area) area that serves the tenant space for the collection and storage of materials for recycling. Telecom rooms are not acceptable as recycling space. During the lease term, the Offeror agrees, upon request, to provide the Government with additional information concerning recycling programs maintained in the building and in the leased space.

8.16 OCCUPANT EMERGENCY PLANS

The Offeror is required to participate in the development and implementation of the Government Occupant Emergency Plan. The Occupant Emergency Plan shall include procedures for notification of the Offeror's building engineer or manager, building security, local emergency personnel, and Government personnel.

9.0 LEASE SECURITY STANDARDS

Nothing in the following section is intended to conflict with the security standards established by UFC 4-010-01, Change 1, 1 October 2013 which states the security standards established by the Department of Homeland Security's Interagency Security Committee (ISC) in the Risk Management Process for Federal Facilities shall apply to all off-installation leased space managed by the DoD, see Section 1.3.E of this SFO.

9.1 DETERRENCE TO UNAUTHORIZED ENTRY

The Offeror shall provide a level of security that prevents unauthorized entry to the space at all times and deters loitering or disruptive acts in and around the leased space. The Offeror shall ensure that security cameras and lighting are not obstructed. The Offeror shall allow the Government to install any security equipment deemed necessary to support the Command mission and Force Protection requirements throughout the term of the lease.

9.2 ACCESS TO UTILITY AREAS

Utility areas shall be secure, and only authorized personnel shall have access. Access to Utility areas within the leased space will be controlled by the Government. Any individuals requiring access will be vetted by the Government or escorted by authorized personnel.

9.3 EMERGENCY POWER TO CRITICAL SYSTEMS (TENANT IMPROVEMENTS)

Emergency power backup is required for all alarm systems, CCTV monitoring devices, fire detection systems, entry control devices, lighting, etc., and special equipment, as identified elsewhere in the SFO.

9.4 MECHANICAL AREAS AND BUILDING ROOFS

- A. Keyed locks, keycards, or similar security measures shall strictly control access to mechanical areas. Additional controls for access to keys, keycards, and key codes shall be strictly maintained. The Offeror shall develop and maintain accurate HVAC diagrams and HVAC system labeling within mechanical areas.
- B. Roofs with HVAC systems shall also be secured. Fencing or other barriers may be required to restrict access from adjacent roofs based on a Government Building Security Assessment. Roof access shall be strictly controlled through keyed locks, keycards, or similar measures. Fire and life safety egress shall be carefully reviewed when restricting roof access.
- C. Building Systems and Roof Access: Provide emergency shutdown, shelter-in-place (SIP) and evacuation procedures in an effort to protect exterior air intakes. All intake grills will be secured to prevent tampering or removal. If an emergency generator is used, it shall be secured to protect against unauthorized access. Generator and fuel tanks shall be located at least 25 feet from loading docks, entrances and parking. Develop written procedures for emergency shutdown or exhaust handling of systems. Ventilation equipment and controls will be protected from unauthorized access. Trash containers, mailboxes, vending machines and other fixtures will be positioned away from building entrances.

9.5 ACCESS TO BUILDING INFORMATION

The RECO may direct that the names and locations of Government tenants are not disclosed in any publicly accessed document or record. If that is the case, the Government may request that such information not be posted in the building directory.

9.6 POSTING OF GOVERNMENT RULES AND REGULATIONS (TENANT IMPROVEMENTS)

The Government may post applicable Government rules and regulations at the entrance to any Government occupied space for such things as, but not limited to, barring the unauthorized possession of firearms and dangerous weapons.

9.7 BUILDING SECURITY PLAN

The Offeror shall provide a Pre-Lease Building Security Plan, as attached that addresses in detail its compliance with the lease security standards, as described in this SFO and its attachments.

9.8 ADDITIONAL SECURITY MEASURES AS DETERMINED BY THE GOVERNMENT

The Government reserves the right to require additional security measures to meet specific tenant occupancy requirements, as may be determined by the Government's building security assessment or any type of Government risk assessment evaluation of the proposed building, location, and tenant mix. The Government may furnish its own third-party security system and include electrical back-up protection in the case of power disruptions or outages.

9.9 IDENTITY VERIFICATION OF PERSONNEL

- A. The Government reserves the right to verify identities of personnel with routine access to Government space. The Offeror shall comply with the agency personal identity verification procedures below that implement Homeland Security Presidential Directive-12 (HSPD-12), Office of Management and Budget (OMB) guidance M-05-24, and Federal Information Processing Standards Publication (FIPS PUB) Number 201, as amended.
- B. The Offeror shall insert this paragraph (9.9.A) in all subcontracts when the subcontractor is required to have physical access to a federally controlled facility or access to a federal information system.
- C. Offeror compliance with subparagraphs 1 through 4 below will suffice to meet the Offeror's requirements under HSPD-12, OMB M-05-24, and FIPS PUB Number 201.
 1. The Government reserves the right to conduct background checks on Offeror personnel and contractors with routine access to Government leased space.
 2. Upon request, the Offeror shall submit completed fingerprint charts and background investigation forms for each employee of the Offeror, as well as employees of the Offeror's contractors or subcontractors, who will provide building operating services requiring routine access to the Government's leased space for a period greater than six

months. The Government may also require this information for the Offeror's employees, contractors, or subcontractors who will be engaged to perform alterations or emergency repairs in the Government's space.

3. The Offeror must provide Form FD-258, Fingerprint Chart (available from the Government Printing Office at <https://www.edo.cjis.gov/artifacts/standard-fingerprint-form-fd-258-1.pdf>), and Standard Form 85P, Questionnaire for Public Trust Positions, completed by each person and returned to the RECO (or the RECO'S designated representative) within 30 days from receipt of the forms. Based on the information furnished, the Government will conduct background investigations of the employees. The RECO will advise the Offeror in writing if an employee fails the investigation, and, effective immediately, the employee will no longer be allowed to work or be assigned to work in the Government's space.
4. Throughout the life of the lease, the Offeror shall provide the same data for any new employees, contractors, or subcontractors who will be assigned to the Government's space. In the event the Offeror's contractor or subcontractor is subsequently replaced, the new contractor or subcontractor is not required to submit another set of these forms for employees who were cleared through this process while employed by the former contractor or subcontractor. The Offeror shall resubmit Form FD-258 and Standard Form 85P for every employee covered by this paragraph on a 5-year basis.

9.10 ENTRY SECURITY: INTRUSION DETECTION SYSTEM WITH CENTRAL MONITORING CAPABILITY

The Offeror shall install a perimeter Intrusion Detection System (IDS) to be operated and maintained by the Offeror.

If the Government will occupy the entirety of the facility, then the Offeror shall allow the Government's security office to outfit the facility with an Electronic Access Control System (EACS) and IDS equipment on any exterior point of entry and internal doors or utility identified as security-related areas as needed. If the Government will only occupy a portion of our suite within the facility, then the Offeror shall allow the Government to outfit any exterior points of entry and other Command specific security-related areas with EACS and IDS equipment as needed. In all cases, the Government shall maintain full day-to-day policy, maintenance, and operational control capabilities for any Government installed EACS. Any EACS maintained by the Offeror shall utilize an issued proximity or similar type of credential to authenticate and allow access. The EACS system must be capable of generating cardholder and card history/usage reports for review by the Government as required. Any EACS equipment installed within the leased space, which has not been provided by the Government, must be compatible with the system currently in use by the Government. If the equipment is not compatible with the system currently in use by the Government, the Government reserves the right to replace any EACS equipment with that of the Government's own choosing.

If the Government will occupy the entirety of the facility, then the Offeror shall allow the Government to outfit the facility with a speaker-based mass notification system (MNS). If the Government will only occupy a portion of or suite within the facility, then the Offeror shall

allow the Government's security office to outfit the leased area with a speaker-based MNS. In all cases, the Government's security office shall maintain full day-to-day policy, maintenance, and operational control responsibilities for any Government installed MNS equipment.

9.11 ENTRY SECURITY: PEEPHOLES (TENANT IMPROVEMENT)

Upon the Government's request, the Offeror must provide and install peepholes in all doors to the Government occupied space as an effective visual recognition system for small offices. This system shall comply with the Architectural Barriers Act, Section F230.1.

9.12 SECURE HVAC: AIRBORNE HAZARDS

Air-handling units shall be able to be shut down in response to a threat. Procedures shall be in place for notification of the Offeror's building engineer or manager, building security guard desk, local emergency personnel, local Navy representative, and RECO for possible shut-down of the air handling units serving the mailroom and/or any other possibly affected areas of the building to minimize contamination, as deemed appropriate to the hazard.

9.13 TEMPORARY SECURITY UPGRADE DUE TO IMMEDIATE THREAT

The Government reserves the right, at its own expense and with its own personnel, to temporarily heighten security in the building under lease during heightened security conditions due to emergency situations such as terrorist attacks, natural disaster, and civil unrest.