Summit Peak Roofing

802 Ridge Rd, Ashford, VA 23991 | (804) 555-0176

ROOF REPLACEMENT ESTIMATE
No. SPR-26-118
Date: 2026-11-01

Customer	Harold & Betty Simmons
Vehicle / Property	33 Orchard Hill Rd, Ashford, VA 23991 - Main roof (22 squares)

#	Description	Qty	Unit	Unit price	Amount
1	Tear off & replace architectural shingles	22	sq	$515.00	$11,330.00
2	Synthetic underlayment	22	sq	$45.00	$990.00
3	Drip edge	180	LF	$4.25	$765.00
4	Ridge cap	48	LF	$11.50	$552.00
5	Pipe boots	3	ea	$65.00	$195.00
6	Dumpster & disposal	1	ea	$625.00	$625.00
7	Building permit	1	ea	$185.00	$185.00
	TOTAL				**$14,642.00**

Notes / Findings

Inspection 11/01/2026: approx. 40% of shingles on south and west slopes missing or creased, consistent with wind. Exposed underlayment deteriorated by rain exposure; active leak above upstairs bedroom. Existing roof approx. 20 years old; matching shingles unavailable. Interior ceiling repair not included.

Prices valid 30 days. Hidden damage may require a supplement. Payment is the responsibility of the customer unless the insurer has authorized direct payment in writing.