



RM. MAYILERU & Co.,

CONSULTING ENGINEERS (CIVIL & MECH) ★ CHARTERED ENGINEERS
APPROVED VALUERS ★ INDUSTRIAL CONSULTANTS
INSURANCE SURVEYORS ★ CRANE TESTING AUTHORITY

Phone : 0422 - 2494942

0422 - 2497455

Cell : 87783 25799

DOOR No. 365, 1st FLOOR, BHARATHIYAR ROAD, SIDDHAPUDUR, COIMBATORE - 641 044.

E-mail : mayileruandco@gmail.com Visit us at : www.mayileruandco.com

RMM/MI/SY/24/2024

GSTIN : 33ADJPM0983E1ZN DATE : 22.06.2024

STATEMENT ACCOMPANYING FORM - A

- 1) Door Number of the building : S.F.No.1345/1A, Gudalur Village
- 2) Location (Street No. Ward No. name of place ie. Corporation / Municipality/ Panchayat / Panchayat Union Township Cantonment) : NOVA PUBLIC SCHOOL,
S.F.No.1345/1A, Gudalur Village,
Selvapuram, Jothipuram P.O.
Via. Veerapandi Pirivu,
Coimbatore North - 641 047
- 3) Year of construction : Ground Floor - 2002
First Floor - 2010
- 4) Approximate cost of construction as per current rates : Rs.2,20,45,500/-
- 5) Purpose for which the building is being used or proposed to be used : School Building (Class Rooms, Labs and Staff Rooms)
- 6) Purpose for which the building has hitherto been used : School Building (Class Rooms, Labs and Staff Rooms)
- 7) Details of construction of the building (particulars) of the Foundation soils specification of the various parts under:
 - (a) Foundation : PCC 1:5:10 & RCC M 20 Raft
 - (b) Basement : RCC Pedestal M20, Beam with M20 BW in CM 1:6
 - (c) Superstructure in CM : RCC column M20, BW to CM 1:6, Plastering
 - (d) Floor : Cement concrete Floor, Vitrified Tiles Floor in CM 1:4
 - (e) Roof : RCC Beams & Slabs with M20
 - (f) Plinth Area in SFT : Ground Floor - 9585 Sq. Ft.
First Floor - 9585 Sq. Ft.
Total - 19170 Sq. Ft.
- 8) Period for which the licence is required : For the period of 3 years from 22.06.2024 to 21.06.2027
- 9) Number of persons to be accommodated : 500 persons.

Station : Coimbatore

Dated : 22.06.2024

Signature of the Engineer
RM. MAYILERU, BE, M.I.E., F.I.I., A.F.I.I., C. Engr
CONSULTING ENGINEER

APPROVED VALUER & CHARTERED ENGINEER

COLLECTOR'S PANEL ENGINEER (Ref. No. 42525/2014/C2 DL12/01/2015)

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license of the purpose for which the licence was granted for the use of the building or a portion of the building or a portion of the building originally is changed or altered subsequently.

Signature of the owner of the building



RM. MAYILERU & Co.,

CONSULTING ENGINEERS (CIVIL & MECH) ☆ CHARTERED ENGINEERS
APPROVED VALUERS ☆ INDUSTRIAL CONSULTANTS
INSURANCE SURVEYORS ☆ CRANE TESTING AUTHORITY

Phone : 0422 - 2494942
0422 - 2497455
Cell : 87783 25799

DOOR No. 365, 1st FLOOR, BHARATHIYAR ROAD, SIDDHAPUDUR, COIMBATORE - 641 044.
E-mail : mayilleruandco@gmail.com Visit us at : www.mayilleruandco.com
GSTIN : 33ADJPM0983E1ZN

RMM/MI/SY/24/2024

DATE : 22.06.2024

FORM - B

(Form of Certificate of structural soundness under sub-section (4) of section of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamilnadu Act of 1965) referred to in rule 4 of the Tamil Nadu Buildings (licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:-

(1) Foundation :

- | | | |
|--|---|--------------------------|
| (i) Depth below ground level | : | 1.5 m below Ground Level |
| (ii) Nature of soil met with at Foundation level | : | Soft Rock mixed with DIR |
| (iii) Pressure at Foundation | : | 24 Tons / Sq. m |
| (iv) Probable safe bearing Capacity of the Starta met with at foundation | : | 35 Tons / Sq. m |

(2) Super structure :

- | | | | |
|---|---|--------------------------|---|
| (i) Maximum stress in the most critical section of masonry and concrete | : | BW in CM 1:6
RCC M 20 | 0.0603 N/ mm ²
0.24 N/mm ² |
| (ii) Nature of masonry and Concrete and its safe permissible stress | : | BW in CM 1:6
RCC M 20 | 0.55 N/mm ²
7.00 N/mm ² |

The structural soundness of the building has been verified by me with reference, to ISI loading standards 875 (latest version) and other relevant India standards code of practice and declare that the building is structurally sound to be used as a Public Building for the purpose noted in the statement. A license may be granted for the period from 22.06.2024 to 21.06.2027 inclusive.

Date : 22.06.2024
Place : Coimbatore

Signature of the Engineer
Registration No.

RM. MAYILERU, B.E., M.I.E., F.I.J., A.F.I.I., C.Engr
CONSULTING ENGINEER
APPROVED VALUER & CHARTERED ENGINEER
COLLECTOR'S PANEL ENGINEER (Ref. No. 42525/2014/C2 D.L. 12/01/2015)



RM. MAYILERU & Co.,

CONSULTING ENGINEERS (CIVIL & MECH) ☆ CHARTERED ENGINEERS
APPROVED VALUERS ☆ INDUSTRIAL CONSULTANTS
INSURANCE SURVEYORS ☆ CRANE TESTING AUTHORITY

Phone : 0422 - 2494942

0422 - 2497455

Cell : 87783 25799

DOOR No. 365, 1st FLOOR, BHARATHIYAR ROAD, SIDDHAPUDUR, COIMBATORE - 641 044.

E-mail : mayilleruandco@gmail.com Visit us at : www.mayilleruandco.com

RMM/MI/SY/24/2024

GSTIN : 33ADJPM0983E1ZN

DATE : 22.06.2024

FORM - C

(Form of opinion under sub-section (1) of section 5 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 5 of the Tamil Nadu Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:-

(1) Foundation :

- | | | |
|--|---|--------------------------|
| (i) Depth below ground level | : | 1.5 m below Ground Level |
| (ii) Nature of soil met with at Foundation level | : | Soft Rock mixed with DIR |
| (iii) Pressure at Foundation | : | 24 Tons / Sq. m |
| (iv) Probable safe bearing Capacity of the Starta met with at foundation | : | 35 Tons / Sq. m |

(2) Super structure :

- | | | | |
|---|---|--------------------------|---|
| (i) Maximum stress in the most critical section of masonry and concrete | : | BW in CM 1:6
RCC M 20 | 0.0603 N/ mm ²
0.24 N/mm ² |
| (ii) Nature of masonry and Concrete and its safe permissible stress | : | BW in CM 1:6
RCC M 20 | 0.55 N/mm ²
7.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian standards code of the practice and declare that the building is structurally sound to be used as a Public Building for the purpose noted in the statement. A license may be granted for the period from 22.06.2024 to 21.06.2027 inclusive.

Date : 22.06.2024
Place : Coimbatore

Signature of the Engineer
Registration No.

RM. MAYILERU, BE, M.I.E., F.I.I., A.F.I.I., C.Engi
CONSULTING ENGINEER
APPROVED VALUER & CHARTERED ENGINEER
COLLECTOR'S PANEL ENGINEER (Ref. No. 42525/2014/C2 Dt. 12/01/2015)



RM. MAYILERU & Co.,

CONSULTING ENGINEERS (CIVIL & MECH) ☆ CHARTERED ENGINEERS
APPROVED VALUERS ☆ INDUSTRIAL CONSULTANTS
INSURANCE SURVEYORS ☆ CRANE TESTING AUTHORITY

Phone : 0422 - 2494942

0422 - 2497455

Cell : 87783 25799

DOOR No. 365, 1st FLOOR, BHARATHIYAR ROAD, SIDDHAPUDUR, COIMBATORE - 641 044.

E-mail : mayilleruandco@gmail.com Visit us at : www.mayilleruandco.com

RMM/MI/SY/24/2024

GSTIN : 33ADJPM0983E1ZN DATE : 22.06.2024

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

- 1) Location of the building Door No. Street and name place : NOVA PUBLIC SCHOOL,
S.F.No.1345/1A, Gudalur Village,
Selvapuram, Jothipuram P.O.
Via. Veerapandi Pirivu,
Coimbatore North - 641 047
- 2) Age of the building : Ground Floor - 22 years
First Floor - 14 years
- 3) No of Storeys : Ground Floor and First Floor
- 4) Short Description of structure Steel R.C.C framed of load : RCC Framed structure with
vitrified tile floor, RCC Roof beam
with Slab.
- 5) Purpose for which the building is certified for use : School Building (Class Rooms, Labs and
Staff Rooms)
- 6) Period for which the building will be structurally sound : For the period of 3 years from 22.06.2024
to 21.06.2027.
- 7) No. of persons to be Accommodated : 500 persons.

Signature of the Engineer
Registration No.

RM.MAYILERU, BE,M.T.E., F.I.I., A.F.I.I., C.Engg
CONSULTING ENGINEER

APPROVED VALUER & CHARTERED ENGINEER

COLLECTOR'S PANEL ENGINEER (Ref. No.42525/2014/C2 Dt.12/01/2015)

DECLARATION

I, RM.Mayileru residing at Door No.365, First Floor, Bharathiyar Road, Siddhapudur, Coimbatore - 641 044, do hereby declare that, I possess the qualification and experience specified in the table to rule 11, of the Tamil Nadu Public Buildings (Licensing) rules, 1966, for Issuing the certificate of structural soundness of the building covered by the certificate.

Signature of the certifying Engineer

RM.MAYILERU, BE,M.T.E., F.I.I., A.F.I.I., C.Engg
CONSULTING ENGINEER

APPROVED VALUER & CHARTERED ENGINEER

Station : Coimbatore

Dated : 22.06.2024

- (i) Name and Address (in Block letters) : RM.MAYILERU,
Door No.365, First Floor, Bharathiyar Road, Siddhapudur, Coimbatore - 641 044
- (ii) Engineering qualification : B.E, M.T.E., F.I.V., A.F.I.I., C.ENGN.
- (iii) Number of years of experience & nature thereof : 32 Years
: CIVIL, MECHANICAL

PKS/SI

PLAN SHOWING THE PROPOSED CONSTRUCTION

ON E.A.C. ROOMS CHANGING AND FIVE FLOORS

NOVA SCHOOL BUILDING

JOHNSTOWN, COUMBERLAND DISTRICT

SCALE: 1/8" = 1'-0"

PLAN, SECTION & ELEVATION

ARCHITECT: SPECIALIST

DATE: 10-1-58

BY: J. H. H. H.

FOR: J. H. H. H.

AT: J. H. H. H.

IN: J. H. H. H.

OF: J. H. H. H.

THE: J. H. H. H.

AREA: J. H. H. H.

DETAILS: J. H. H. H.

SECTION: J. H. H. H.

ELEVATION: J. H. H. H.

NOTE: J. H. H. H.

1. ALL DIMENSIONS AND MATERIALS

2. AS SHOWN ON THIS PLAN

3. UNLESS OTHERWISE SPECIFIED

4. SEE NOTES ON REVISIONS

5. SEE NOTES ON REVISIONS

6. SEE NOTES ON REVISIONS

7. SEE NOTES ON REVISIONS

8. SEE NOTES ON REVISIONS

9. SEE NOTES ON REVISIONS

10. SEE NOTES ON REVISIONS

11. SEE NOTES ON REVISIONS

12. SEE NOTES ON REVISIONS

13. SEE NOTES ON REVISIONS

14. SEE NOTES ON REVISIONS

15. SEE NOTES ON REVISIONS

16. SEE NOTES ON REVISIONS

17. SEE NOTES ON REVISIONS

18. SEE NOTES ON REVISIONS

19. SEE NOTES ON REVISIONS

20. SEE NOTES ON REVISIONS

21. SEE NOTES ON REVISIONS

22. SEE NOTES ON REVISIONS

23. SEE NOTES ON REVISIONS

24. SEE NOTES ON REVISIONS

25. SEE NOTES ON REVISIONS

26. SEE NOTES ON REVISIONS

27. SEE NOTES ON REVISIONS


28. SEE NOTES ON REVISIONS

29. SEE NOTES ON REVISIONS


30. SEE NOTES ON REVISIONS

31. SEE NOTES ON REVISIONS

32. SEE NOTES ON REVISIONS



GROUND FLOOR



FIRST FLOOR

CERTIFICATE PREPARED
AS PER THIS DRAWING ONLY

[Signature]

RM MAYLE, JR., M.E., E.L., E.C.E.
CONSULTING ENGINEER


APPROVED BY THE BOARD OF ENGINEERS

COLLECTOR'S PANEL ENGINEER (REL. NO. ASSIGNMENT DL 12512015)


PLAN SHOWING THE PROPOSED CONSTRUCTION
OF B.C.C. BOOM GROUND AND FIRST FLOOR

NOVA SCHOOL BUILDING
KOTHRUMBAM, COIMBATORE DISTRICT.

SCALE: DETAILS	PLAN: SECTION & ELEVATION	1" = 40' CLEAR
ARCHITECT: DETAILS		
DOOR	30" x 70"	
WINDOW	30" x 40"	
VENTILATOR	30" x 20"	
STREET	30" x 10"	
CEILING	30" x 10"	
ROOF	30" x 10"	
AREA: DETAILS		
SECTION	30" x 10"	
AREA OF THE GROUND FLOOR		
AREA OF THE FIRST FLOOR		
NOTES:		
1. ALL DIMENSIONS ARE IN FEET & INCHES.		
2. ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE SPECIFIED.		
3. ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE SPECIFIED.		



GROUND FLOOR



FIRST FLOOR

CERTIFICATE PREPARED
AS PER THIS DRAWING ONLY.

[Signature]

AN MATH ERI, BE.M.E., A.I.A., C.Engg
CONSULTING ENGINEER

APPROVED UNDER & SUPERVISED BY

COLLECTOR'S PANEL ENGINEER (Ref. No. 43/570/MC/20/12/16/2015)