

OFFICE OF THE SENIOR PROJECT MANAGER, INFRASTRUCTURE DIVISION  
ODISHA BRIDGE & CONSTRUCTION CORPORATION LIMITED

(A Government of Odisha Undertaking under Works Department)

O.M.P. Square, Cuttack – 753004

Email: ctcdiv3@obcc.in

No: 364/WE

Date 26-07-2022

To

Mr. Neelakandan E  
AGM-Project  
CNBT-Cuttack  
URC Construction Pvt. Ltd

Sub: Construction of Netaji Bus Terminus at Cuttack on lumpsum turnkey basis / **Approved Estimate for new connection of 500 KW**

Ref: TPCODL Email Dt-26-07-2022

Sir,

With reference to the subject cited above, it is forwarded herewith the copy of the TPCODL approved estimate regarding installation of 1 no. 11 KV, 3 Way RMU with metering unit to provide power supply of 500 KW for CNBT project under 6% deposit scheme.

This is for your information & necessary action.

Encl:- TPCODL Estimate (12 pages)

Yours faithfully,

  
Sr. Project Manager,  
Infrastructure Division  
O.B. & C.C. Ltd, Cuttack

Memo No. 365(2)/WE /Dt 26-07-2022

Copy submitted to the E.I.C-cum-M.D., O.B. & C.C. Ltd./ Senior Chief General Manager, O.B. & C.C. Ltd. Bhubaneswar for favour of kind information and necessary action.

  
Sr. Project Manager,  
Infrastructure Division  
O.B. & C.C. Ltd, Cuttack



Received by  
Mr. - Aris (P.E.)  
26/07/22 - 05.30pm.

Received through mail on dt 26/7/2022

TP CENTRAL ODISHA DISTRIBUTION LTD.					
Notification No.-5001163458		NEG Tracking No. NC/DCDD2/00015		Date: 22.07.2022	
Name of the Division :-		CUTTACK			
Name of the Sub-Division :-		CDD-2			
Name of the Section :-		BADAMBADI			
Name of Consumer:-		CNBT			
Name of the Work :-		Installation of 1 No of 11 KV, 3WAY RMU with metering unit for providing Power supply of CNBT having CD of 555.55 KVA.			
Scope of work:-		1 Installation of 1 No of 11 KV, 3WAY RMU with metering unit at consumer premises.(Refer SLD-K1)			
Names of Schemes:-		6% deposit work.			
Type of Work		New Connection			
Abstract of Estimate					
Sl. No.	Description	Gross	6% S.C	18% GST on 6% S.C	Total (6% S.C + 18% GST)
1	PART A: 1 Installation of 1 No of 11 KV, 3WAY RMU with metering unit at consumer premises.(Refer SLD-K1) (To be executed by party & maintained by TPCODL under 6% Deposit work Scheme).	9,70,590.01	46,558.52	8,330.53	54,939.06
2	Inspection Charges	2,900.00			
3	Total Estimated Cost	9,73,490.01			
4	Total Estimated Cost on 6% deposit (6% S.C + 18% GST)				54,939.06
Total Estimated Cost to be deposited by party Rs. 54,939.06 (Rupees Fifty Four Thousand Nine Hundred Thirty Nine and Six Paise only.)					
<p>Note:</p> <ol style="list-style-type: none"> <li>1. All equipments to be purchased as per TPCODL specs., GTP.</li> <li>2. All the inspection to be done as per TPCODL standards.</li> <li>3. In case the scope of work changes, the estimate may change and the difference amount to be payable by party after reconciliation.</li> <li>4. Party has to resolve all RoW issues if arises while construction and after charging also.</li> <li>5. All installation to be done as per TPCODL Drawing.</li> <li>6. Rate taken in the estimate are from Cost Data Book(CDB) released from DoE(GoO) and may be on lower or higher than the actual procurement cost.</li> </ol>					

PREPARED BY  
LEAD ENGG.-NEG

CHECKED BY  
TEAM LEAD - NEG

APPROVED BY  
HOG - NEW CONNECTION

APPROVED BY  
HOG - NEG

APPROVED BY  
HEAD -(E & Q)

22/7/22

## Technical Feasibility Report

**Project Name** : CNBT, CUTTACK  
**KCG Request No** : 5001163458  
**Division** : CDD2  
**Sub-Division** : BADAMBADI  
**Section** : BADAMBADI  
**Type of Load** : Commercial (NEW CONNECTION)  
**Supply Voltage** : 11KV  
**Consumer Category** : Govt.  
**Load requirement in KVA** : 555.55 KVA  
**Network Feasibility** : Feasible  
**Latitude/Longitude** : NA

Load requirement	Final Power Supply
Connected load (KVA)	--
Estimated Demand (KVA)	555.55
Power Supply Requirement Date	NA
33/11KV PSS Name	BADAMBADI
11KV Feeder Name	BADAMBADI-2
11KV feeder Trunk conductor Size	100 sq.mm, AAAC
11KV Feeder Peak loading	215 A
11KV feeder conductor Size from where Tapping to be done for releasing load	11 KV 3C X 400 Sq.mm. U/G Cable
Existing 33KV Feeder Name	BADAMBADI FEEDER
Existing 33KV Feeder conductor Size	232 mm <sup>2</sup>
Rating of the Existing 33/11KV PTR	12.5 MVA
Existing 33/11KV PTR loading (MVA)	7.53 MVA
Existing 33KV Feeder Loading (Amp)	243
33KV feeder conductor Size from where Tapping to be done for releasing load	NA
Loading of 33/11KV PTR loading with new consumer (MVA)	8.08 MVA
Loading of 33KV feeder with new consumer( Amp)	252.71 A
Loading of 11KV Feeder with new consumer (Amp)	244.15 A

# TPCDDL

Existing 11 KV Bus Voltage at PSS (in KV)	10.7
Proposed Feeder Section	BADAMBADI
Route Length in Mtr for Construction of New line / UG	NA
Voltage Drop (in KV)	0.1118
Voltage at Consumer end in 11KV	10.58
Voltage at Consumer end in 1.1 (V)	NA

<b>Last Mile Connectivity:</b>	<b>1 PH</b>	<b>3PH</b>
No. of Meters	-	1

Space Req for Utility Infra	Nos.	Space
DSS Overhead Space Req.	1	4x5
DSS for UG Network Space Req.	0	8X5
Type of DSS (Indoor/ Outdoor)	Outdoor	
PSS Space Req.	0	NA
LT Meter Room Space Req.		
Earth Pit for DSS	0	NA
Earth Pit for PSS (33/11kv)	0	NA
Earth pits for LT Meter	1/mtr room	each earth pit @ 2.5 mtr
<b>Proposed new DT Capacity (KVA)</b>	<b>Total Capacity</b>	
Transformers		

Remarks	
Temporary Power supply remarks	
Final Power supply remarks (Scope of Work)	1. Installation of 1 No of 11 KV, 3WAY RMU with metering unit at consumer premises.(Refer SLD-K1)

**Note:** 1. The route length to be checked during JSV. Any change in the load would lead to revision in Feasibility.

2. Power supply can be released as per OERC SOP Norms.

**Validity:** This report is valid for 6 months. Post validity please reinitiate for feasibility.

**Validity Date:** 22.07.2022

Prepared by  
Lead Engineer

Checked by  
Team Lead-NEG

Approved by  
HOG, New Connection

1. Installation of 1 No of 11 KV, 3WAY RMU with metering unit at consumer premises.(Refer SLD-K1)					
<b>Supply Portion</b>					
Sl. No.	Description of items	Unit	Quantity	Rate (in Rs.)	Amount (in Rs.)
1	Supply of 11kV RMU				
a	No. of 11kV 3Way RMU (LLV+M)	nos.	1		
1.1	Supply of RMU 3W 11kV 630A with metering unit (LLV+M)	Nos.	1	5,76,739.00	5,76,739.00
2	Earthing				
2.1	Earthing Conductor: 50X6 mm (2.4kg./mtr.) GI Flat for equipment, structure etc.)	kg	13.20	88.50	1,168.20
2.2	Pipe Earthing 40mm. GI Pipe	Nos.	2	1,239.00	2,478.00
<b>Sub Total (Supply Portion) (in Rs.)</b>					<b>5,80,385.20</b>
<b>Erection Portion</b>					
Sl. No.	Description of items	Unit	Quantity	Rate (in Rs.)	Amount (in Rs.)
1	Erection of RMU 3W 11kV 630A with metering unit (LLV+M)	Nos.	1	15,000.00	15,000.00
<b>Sub Total (Erection Portion) (in Rs.)</b>					<b>15,000.00</b>
<b>Civil Portion</b>					
Sl. No.	Description of items	Unit	Quantity	Rate (in Rs.)	Amount (in Rs.)
1	Civil works for Prefabricated RCC foundation with supply of all materials				
1.1	Prefabricated RCC foundation of 11kV RMU	Nos.	1	23,145.30	23,145.30
1.2	Supply of GI Fencing with Gate around each RMU	sqmtr	20	3,600.00	72,000.00
1.3	Installation of Earth Pit, Charcoal, Salt etc. including construction of earthing chamber (Size: 2'x2') and RCC slab cover	Set	2	2,407.00	4,814.00
<b>Sub Total (Civil Portion) (in Rs.)</b>					<b>99,959.30</b>
A	<b>Sub Total (Supply Portion)</b>				<b>5,80,385.20</b>
B	Stock, Storage & Insurance @ 3 % of A				17,411.56
C	<b>Sub Total (A+B)</b>				<b>5,97,796.76</b>
D	Contingency @ 3 % of C				17,933.90
E	Tools & Plants Charges @ 2% of C (considered for earthing items)				75.11
F	Transportation @ 7.5% of C				44,834.76
G	Erection Charges @ 10% of earthing items				375.56
H	<b>Total (C+D+E+F+G)</b>				<b>6,61,016.09</b>
I	Sub Total (Erection Portion + Civil Portion)				1,14,959.30
J	<b>Total Cost (H+I)</b>				<b>7,75,975.39</b>
K	Other Overhead /(including Supervision Charges) @ 6 % of J				46,558.52
L	<b>Total Estimated Capital Cost i.e. (J+K)</b>				<b>8,22,533.91</b>
M	GST @ 18% of L				1,48,056.10
N	<b>Grand Total (L+M)</b>				<b>9,70,590.01</b>
O	Inspection Fee of RMU - Rs. 2000/ RMU				2000
P	Inspection Fee of Drawing Checking and Approval				400.00
Q	Final decision by electrical Inspector				500.00
R	<b>Gross Total Material, Services and Inspection Fees (N+O+P+Q)</b>				<b>9,73,490.01</b>


Prepared By  
Lead Engineer

Checked By  
Team Lead (NEG)

Approved By  
HoG, New Connection

Approved By  
HOG, NEG

# EXISTING SLD AT NETAJI BUS TERMINAL, CNBT, KHANNAGAR



Prepared By  
Lead Engineer

Checked By  
Team Lead (NEG)

Approved By  
HoG, New Connection

Approved By  
HOG, NEG



To be executed by party & maintained by  
TPCODL under 6% Deposit Scheme

To be executed by Party

To be executed in shifting scope  
under OB & CC deposit work

Prepared By  
Lead Engineer

Checked By  
Team Lead (NEG)

Approved By  
HoG, New Connection

Approved By  
HOG,NEG

**CNBT, CUTBACK (CD-555.55 KVA)**

**11 KV FEEDER LOADING ANALYSIS**

Scenario	Main source structure/PSS	Main source feeder	Main source feeder peak load (MVA)	Current Carrying Capacity of Conductor(Main source feeder) (MVA)	Feeder Status	Backfeeding feeder name	Backfeeding Structure name	Backfeeding feeder Peak load (MVA)	Total feeder Peak of the circuit (MVA)	Current Carrying Capacity of Backfeeding conductor (MVA)	N-1 FEEDER STATUS
Existing	BADAMBADI	11KB BADAMBADI-2	4.10	5.2	OK	No back feed Available	NA	NA	NA	NA	NOT OK
After releasing 0.555 MVA load	BADAMBADI	11KV BADAMBADI-2	4.65	5.2	OK	No back feed Available	NA	NA	NA	NA	NOT OK

**PTR LOAD (MVA) ANALYSIS**

Scenario	Main source structure	Main source PTR No.	Main source PTR peak load in MVA	Backfeeding PTR Peak load	Backfeeding PTR No.	Backfeeding structure Name	N-1 PTR Peak of the circuit	PTR STATUS	N-1 STATUS
Existing	BADAMBADI	PTR-1(12.5MVA)	7.53	1.9	PTR-2(12.5MVA)	BADAMBADI	9.47	OK	OK
After releasing 0.555 MVA load	BADAMBADI	PTR-1(12.5MVA)	8.08	1.9	PTR-2(12.5MVA)	BADAMBADI	10.03	OK	OK

VOLTAGE DROP	Main Source Structure	Main source feeder	Source 11KV Feeder Voltage in KV	Feeder Length in KM	Proposed Feeder Loading in Amp	Conductor/ CABLE size in sqmm	Resistance ( ohm/km)	Voltage drop in KV	Voltage at Tail End (KV)
For 0.555 MVA load	BADAMBADI	11KB BADAMBADI-2	10.7	1.2	244.15	100	0.375	0.11	10.59
	BADAMBADI	11KB BADAMBADI-2	10.59	0.15	29.15	400 SQ.MM,XLPE U/G	0.1200	0.0005	10.59
	BADAMBADI	11KB BADAMBADI-2	10.59	0.2	29.15	150 SQ.MM,XLPE U/G	0.2400	0.0014	10.583

Prepared By  
Lead Engineer

Checked By  
Team Lead (NEG)

Approved By  
HOG, New Connection

Approved By  
HOG, NEG



TPCODL

TATA POWER CENTRAL ODISHA DISTRIBUTION LIMITED

Form No: F03-  
(09.04.01)  
Rev. : 00

Eff. Dt.: 23.06.2021

Site Visit form for 11kV and below

Notification No.

5001163458

Date

16-July-2022

WBS No

Name &amp; Address

CNBT, Cuttack

Circle

Division

Sub-Division

Section

Cuttack

CSD-2

Badambadi

Badambadi

Type of Case (Tick Any)	Express Consumer (>550kW)	HRB (10kW to 99kW)	KCG (99kW - 550kW)	CAPEX	Govt Affairs	
Request Type (Tick Any)	New Conn. <input checked="" type="checkbox"/>	Load Enhancement	Shifting	SI	Street Lighting	Electrifi- cation
Type of Consumer (Tick Any)	Industrial	Commercial	Residential	MLHT	Amalgama- tion	Agricult- ure
	Educational Institute	Temporary	Permanent			

Existing-

KW

KVA

Sanctioned Load Additional-

KW

Contract Demand

KVA

New-

KW

555.55 KVA

Exist. Primary  
Fdr. Name

m Badambadi

Exist. Structure Name

Badambadi  
P.R.

Peak Load

Amp

Exist. Back Fdr.  
Name No.1

Exist. Structure Name

Peak Load

Amp

Exist. Back Fdr.  
Name No.2

Exist. Structure Name

Peak Load

Amp

Prop. Primary  
Fdr. Name

Prop. Structure Name

Peak Load

Amp

Prop. Back Fdr.  
Name No.1

Prop. Structure Name

Peak Load

Amp

Prop. Back Fdr.  
Name No.2

Prop. Structure Name

Peak Load

Amp

Proposed HT  
Line Length  
(Mtr)

O/H Bare

(M)

U/G Cable

(M)

Proposed HT  
Line Size (Mtr)

O/H Bare

U/G Cable

Road Restoration Detail

Type Of Road	Road Width (Mtr)	Road Owning Agency	Open Excavation (Mtr)	Manual Trenchless (Mtr)	Trenchless by Machine (Mtr)	Pole Pit
--------------	------------------	--------------------	-----------------------	-------------------------	-----------------------------	----------

Ordinary Soil  
Kuccha

Footh  
Path/Brick Work  
Bituminous  
Road

Dense Carpet  
upto 200mm

Dense Carpet  
above 200mm

Rocky

#### Feeder Proposal

Structure Name  
& Bus No.

Panel No. If Panel  
available in Structure

Space availability if  
additional panel  
required

#### Interconnector Proposal

Name of 1st CSS	Panel No. If panel available in RMU	Space availability if additional RMU Required.	Name of 2nd CSS	Panel No. If panel available in RMU	Space availability if additional RMU Required.
-----------------	--	--	-----------------	--	---

#### RMU Proposal

Breaker Rating	4 Way I/D	4 Way O/D	3 Way I/D	3 Way O/D	Plinth	Fencing
	5 Way I/D (No)	5 Way O/D	6 Way I/D (No)	6 Way O/D (No)		

#### DT Proposal (Aug/Addition)

Feeding from By DT Name	Peak Load of Existing DT	No. of LT Feeder from DT	LT Fdr 1. Peak	LT Fdr 2. Peak	LT Fdr-3, Peak	LT Fdr-4, Peak	LT Fdr-5, Peak
----------------------------	-----------------------------	-----------------------------	-------------------	-------------------	----------------	----------------	----------------

KVA rating	No. of DT	Requirement of plinth	Fencing	(SQ. M)	space Availability	LT Feeders (No.)	Feeding arrangement GO/RMU
------------	-----------	-----------------------	---------	---------	--------------------	---------------------	-------------------------------

#### LT Feeder Proposal

O/H Burn (Mtr)	O/H LT AGC (Mtr)	M/G Cable (Mtr)	LT poles (No)	ACE/MCB (No.)	Feeder/Service Pillar (No.)	Tyco Box (Mtr)
-------------------	------------------	--------------------	------------------	------------------	--------------------------------	----------------

#### HT Metering Proposal

Metering Cubicle (CT Ratio)	Metering Cubicle (No.)	Feeding arrangement- GO/RMU	Room for RMU standard)	(as per	Room for Metering Cubicle (As per standard)	Plinth for RMU	Plinth for Metering Cubicle
-----------------------------------	---------------------------	--------------------------------	---------------------------	---------	---	----------------	--------------------------------

## Requirement of Land for ESS

For 11kV ESS			For Grid		
Land provided by RWA / Applicant	Existing ESS	Land required from GONCTD	Existing Grid	Land provided by RWA	Land required from

## Safety Items Proposal

Trench Cover	Locks	Lighting Arrangement	Exhaust Fan	Fire Extinguisher	Safety Charts	Rubber Mat	Danger Board
--------------	-------	----------------------	-------------	-------------------	------------------	------------	--------------

## Remarks / Comments / Concerns: (Sick cables, Weak links, etc., If any)

- Estimate / work will be executed under 64. deposit work  
Scheme!

Scope of work discussed during site visit

1. Only 1 no. of new 3 my RMV with metering unit is  
proposed. (Concern raised to consider RMV with  
metering unit)

## Existing Network Arrangement / Single Line Diagram

Proposed Network Arrangement / Single Line Diagram

Major Material

Material Description

Qty

Material Description



Qty

Site Sketch


ROW Issues(if any)

Row issue will be resolved by Rly.

Safety Issues(if any)

Company / Department	(Name of the Officer, Designation, Contact No) (in block Letters)	E.No	Sign. & Date
NEG	Pranab Ranjan Saha	50046	
MRT	Bijay Prasad Pathy	112102	
KCG			

Projects

Division	Harekrishna Nathi	104588	
Distribution Services			
Consumer Rep.	S. Pant.	70055641 28	