

ATTERBERG LIMITS (BS 1377 PART 2, 4.3 : 1990)

Client:

PCEA CHURCH

Project:

THE PROPOSED CONSTRUCTION OF PCEA CHURCH

Date Tested:

Sample ID:

BH01

Depth (m):

ATTERBERG LIMITS TEST

	Trial 1 (PL) (HCL)	Trial 2 (PL) (WK)	Trial 3 (PL) (2KZ)	Trial 4 (PL) (SH)
PLASTIC LIMIT				29.45

LINEAR SHRINKAGE

Initial length (mm)	40
Final length (mm)	32
Shrinkage (%)	5.71

RESULTS SUMMARY

LIQUID LIMIT (%)	50.97
PLASTIC LIMIT (%)	29.45
PLASTICITY INDEX (%)	21.52
Passing 425 μ m (%)	6
MODULUS OF PLASTICITY	16671.3
LINEAR SHRINKAGE (%)	5.71

SOIL CLASSIFICATION

USCS	Silt of High Plasticity
AASHTO	A-7.5 Elastic silty soil

Tested by: JILLO

Date reported: _____

Checked by: _____

