


SECOND FLOOR KEY PLAN: 2ND  
ALL SLAB THICKNESS = 125MM THK. U.N.O  
SCALE = 1:75



ROOF KEY PLAN: RB  
ALL SLAB THICKNESS = 150MM THK. U.N.O  
SCALE = 1:75

- GENERAL NOTE :
- FOR R.C WORKS
  - DESIGNED IN ACCORDANCE TO BS 8110
  - CONCRETE CURE STRENGTH MINIMUM 25 N/MM AT 28 DAYS
  - EXCAVATION SHALL BE INSPECTED AND APPROVED BY THE SO OR ENGINEER BEFORE CONCRETING
  - COVER TO MAIN REINFORCEMENT
  - FOOTING : 40 MM  
BEAMS : 25 MM  
COLUMNS : 25 MM  
SLAB : 25 MM
  - ALL FOUNDATION SHALL BE ON THE ORIGINAL GROUND OR WELL COMPACTED FILL GROUND
  - THE CONTRACTOR SHALL CHECK THE DIMENSIONS BEFORE SETTING OUT AND ANY DISCREPANCY SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER IMMEDIATELY
  - REINFORCEMENT (ALL BARS ARE TO BS 4449)  
R - RAIN MILD STEEL BARS  
Y - HIGH YIELD STEEL BARS
  - SLICES IN REINFORCEMENT BARS

	MILD STEEL	HIGH YIELD STEEL	MIN LAP LENGTH
BAR IN TENSION	46 DA	51 DA	25 DA+150MM
BAR IN COMP	33 DA	35 DA	20 DA+150MM

11.REMOVAL OF SHUTTERING FOR CONCRETE WORKS OF ORDINARY PORTLAND CEMENTS:

FORMWORK TYPE	MINIMUM PERIOD BEFORE STRONG FORMWORKS (DAYS)	CONTINUOUS DURING PERIOD (DAYS)
BEAM SIDES	1	7
SLAB (PROP LEFT UNDER)	4	7
PROPS OF SLAB	14	7
BEAMS SOTTIS (PROPS LEFT UNDER)	8	7
PROPS TO BEAMS	15	7

12.125MM & 150 MM RC STRIPPERS REINFORCED WITH #12-140 SHALL BE PROVIDED AT ALL CORNERS OF WALL AND FOR BROCKWORKS AT EVERY THREE METER CENTER TO CENTER.

13.APPROVED WATER PROOFING LAYER SHALL BE PROVIDED AT ALL TOILET SUBSIDIARY SUBSIDIARY SLAB AND RC GUTTER.

No.	TARIKH	PINDAAN

PEMILIK :

Y. BHG DATO' LOO SON YONG  
NO.K/P : 470110-10-5193

Y. BHG DATIN FARINA HARTANTO @ CHIN PIE FONG  
NO.K/P : 480210-71-5246

NO.116B, JALAN TENGGU BADAR, PORT KLANG,  
42000 KLANG, SELANGOR DARUL EHSAN.

TANDATANGAN JURUTERA :

IR. AZMAN BIN TEH  
B. Sc(Hons), MEM. P. Eng.  
I hereby certify that these works have been design by me in accordance with sound engineering practice and I take full responsibility for the design and performance of the same.

JURUTERA PERUNDING :  
**PERUNDING TRUSSMAJU**  
(JURUTERA PERUNDING - CONSULTING ENGINEERS)

8-2B, JALAN BOWLING PADANG E13/E,  
SEKSYEN 13, 40100 SHAH ALAM,  
SELANGOR DARUL EHSAN.  
TEL: 03-5523 6961  
FAX: 03-5523 6985  
EMAIL: bms\_consult@yahoo.com

TAJUK PROJEK :  
CADANGAN PINDAAN KEPADA PELAN LULUS NO. MBSA/BGN/BB/600-5/SEK.11/ 242-2019 BERTARIKH 21.08.2019 KEPADA CADANGAN MEROBOKH DAN MEMBINA SEMULA SEBUAH BANGLO 3 TINGKAT DI NO.1, JALAN BADIK 11/4, SEKSYEN 11,40100 SHAH ALAM, SELANGOR DARUL EHSAN.  
DARIPADA  
CADANGAN MEROBOKH DAN MEMBINA SEMULA SEBUAH BANGLO 2 TINGKAT DI NO.1, JALAN BADIK 11/4, SEKSYEN 11, 40100 SHAH ALAM, SELANGOR DARUL EHSAN.

UTK : Y. BHG DATO' LOO SON YONG  
Y. BHG DATIN FARINA HARTANTO @ CHIN PIE FONG

TAJUK LUKISAN :

SECOND FLOOR KEY PLAN  
ROOF KEY PLAN

DILUKIS OLEH : HY  
DI REKA OLEH : HASNA

DISEMAK OLEH : IR. AZMAN TEH  
DILULUS OLEH : IR. AZMAN TEH

SKALA : 1 : 75  
TARIKH : DISEMBER 2023

RUJUKAN :

No. LUKISAN :  
BMS/NO1-S11/STR-07