

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR

Office of the Chief Electrical Inspector Udyog Bhavan, 6th Floor, Block No.18, Sector-11, Gandhinagar.

No/CEI/Gan/Plan/38735/2020

E-mail :

cei-epd@gujarat.gov.in

ph no : (079) 23256642 to 44

fax no : (079) 232 566 51

Date : 17/11/2020

To

PREVAIL CASTING PVT LTD

Survey No-282, Village-Shapar, Ta-Kotda Sangani, Dist.-Rajkot 360024

Vi.shapar

Ta.Kotda Sangani

Dist.Rajkot, 360024

Subject Approval to the drawing for the electrical installation of 1 x 193.8 KW Grid Connected Solar Power Plant along with associated equipments at PREVAIL CASTING PVT LTD, Survey No-282, Village-Shapar, Ta-Kotda Sangani, Dist.-Rajkot 360024, Vi.shapar, Ta.Kotda Sangani, Dist.Rajkot, Gujarat, 360024 (Consumer No. 25859).

Sir,

Referring to your online Application Electrical Installation-B-RJK-27-09-2020-15-29-13 on date 13/11/2020, the undersigned is pleased to approve the layout/alteration as shown in the enclosed drawing subject to the conditions that:

1. The work shall be carried out by Licensed Electrical Contractor of the Gujarat State.
2. The work shall be carried out in accordance with the relevant standards of the Bureau of Indian Standards.
3. If the installation is found defective in actual practice or any modification is necessary, you shall have to carry out addition and / or alteration as may be required by this Inspectorate.
4. Adequate fire protection shall be provided as required under the Central Electricity Authority (Measures relating to safety and Electric Supply) Regulations, 2010.
5. The value of earth resistance /I.R value shall be furnished along with the test report on completion of the work.
6. Adequate earthing shall be provided wherever required under the Central Electricity Authority (Measures relating to safety and Electric Supply) Regulations, 2010.
7. Safety Provision for Electrical Installations & Apparatus shall be provided as per Regulation 19,44,45,46,47, 48, 49 of the Central Electricity Authority (Measures relating to safety and Electric Supply) Regulations, 2010.
8. This approval doesn't contain approval for any kind of future installations mentioned in approved drawing and this approval is given only for those equipments which incorporated in above mentioned subject.

9. If there is/are any kind of DG set in your premise you will have to provide an arrangement of changeover switch or Electrical/Mechanical interlock between two breakers at output end of Solar power plant.
10. This approval is subject to condition that you have to provide "No Volt Relay" with contactor with auto reset facility
11. Tax Invoice received from the Vendor / EPC Agency in respect of the proposed Solar Power Plant shall be furnished along with the test inspection application.

Your's Faithfully

H H Khoja
CHIEF ELECTRICAL INSPECTOR
Gandhinagar

Encl: As above

Copy along with the drawings forwarded for information to:

Deputy Chief Electrical Inspector, West Zone - Rajkot.

Electrical Inspector, Rajkot.

Assistant Electrical Inspector, Rajkot.