

Direction Industrielle – Clients Industriels Centre de Technologie et d'Expertises

180 Avenue Charles Floquet - 93155 LE BLANC MESNIL CEDEX (France)

33 (0) 1.48.14.71.00

∄ 33 (0) 1.48.14.71.34

TEST REPORT No. 2005/OL 047

TEST ORDER: OB5464

DESCRIPTION OF TESTS:

Autogenous Ignition Test with oxygen on Surfactant BIOMEX Industry according to EN ISO 11114-3 Standard

Applicant: Air Liquide / Ingénierie - Mr Colson

7 th Elquide 7 mgemene ivii ook

94503 Champigny sur Marne - France

Technical Manager: Jean-Paul Schaaff

Technician (s): Olivier Longuet

57 Avenue Carnot - BP 313

Emission date: March 10th, 2005

This report includes 3 pages

Accreditation by the COFRAC certifies competency of the laboratories for only tests covered by accreditation

This report may not be reproduced other than in full



The Head of Center

Fabien WILLOT

Accréditation n° 1-0860 Hors Programme Gaz



C.T.E.

Rapport d'essais N° 2005/OL 047

Autogenous Ignition Test with oxygen on Surfactant BIOMEX Industry according to EN ISO 11114-3 Standard

Date: March 10th, 2005


Page: 2/3

	SPONTANEOUS IGNITION TEST	Data sheet # : Test date :	5464 04-mars-05
		Request # :	OB 5464
Request by :	Air Liquide Ingenierie / M. Colson		
	DTOUSY To distant		
Material :	BIOMEX Industry		
unction :	Surfactant		
Supplier :	Diamond Cleaning Products		
Country :	France 02-mars-05		
Date of reception :	UZ-mars-UD		
onditions of use	O2		
	Condition, shape, appearance: Clear liquid		
	Assumed composition :		
	·		
est conditions	02		
Standard applied :	EN ISO 11114-3		
Veight of sample (g) :	0,453 ± 0,004		
	Pressure in bar Start	Teni	perature in °C Start
	120,5		(*)
	Peak		Peak
			(*)
	difference dP	di	fference dT
		ui,	i jei ence u i
	an per ence ur		/*\
	difference di		(*)
			(*)
	<u>OBSERVATIONS</u>	<u> </u>	(*)
	OBSERVATIONS (*) Auto ignition no de	i tected	(*)
	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction b	i tected	(*)
	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS	i tected	(*)
-	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS ted at 120 bar to 500°C.	i tected	(*)
-	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS ted at 120 bar to 500°C.	i tected	(*)
_	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS ted at 120 bar to 500°C.	i tected	(*)
mple tested after e	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS ted at 120 bar to 500°C. evaporation	i tected	
mple tested after e	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS ted at 120 bar to 500°C.	i tected	(*) Operator
mple tested after e	OBSERVATIONS (*) Auto ignition no de HOT WIRE: No reaction be COMMENTS ted at 120 bar to 500°C. evaporation	i tected	



Rapport d'essais N° 2005/OL 047 Autogenous Ignition Test with oxygen on Surfactant BIOMEX Industry according to EN ISO 11114-3 Standard Date : March 10th, 2005

Page: 3/3



<u>NOTA BENE</u>: Ce rapport d'essais ne concerne que les échantillons qui ont été soumis aux essais.