

RELAY INSTRUCTIONS

INSTRUCTION NAME

	STUTIO 500	SIEMENS TIA PORTAL
-] [-	EXAMINE IN CLOSED (XIC) EXAMINE ON	NORMALLY OPEN
-] \ [-	EXAMINE IN OPEN (XIO) EXAMINE OFF	NORMALLY CLOSED

For these instruction statements to be TRUE:

-] [- = VOLTAGE = ON = LOGIC '1' = SET

-] \ [- = NO VOLTAGE = OFF = LOGIC '0' = RESET

To Determine Instruction Type

- ① What is the function of the input field device?

What is “role” of the input in the rung’s logic?

- ② How is the input field device wired?

Is the input device wired Normally Open or Normally Closed?

- ③ What is the state of the field device’s contacts at the time the instruction is to be TRUE?

Is the input device Actuated or Unactuated?

Answering questions 2 and 3 determines if the contacts are MADE (Voltage) or APART (No Voltage). Based on the answer use the instruction that is **TRUE** for the voltage state.
