

Device Wired State for TRUE PLC Instruction

The table shows for wired Normally Opened and Normally Closed Devices for the TRUE PLC Instruction Type for the Actuated and Unactuated wired device.

A wired device's Normal State is when it is UNACTUATED.



UNACTUATED Normally Opened device, contacts are Apart, No Voltage.



UNACTUATED Normally Closed device, contacts are Made, Voltage.

For these instruction statements to be TRUE:

-] [- = VOLTAGE = ON = LOGIC '1' = SET

-] \ [- = NO VOLTAGE = OFF = LOGIC '0' = RESET

DEVICE	ACTUATED	TRUE INSTRUCTION
WIRED NORMALLY OPENED		-] [-
	UNACTUATED	TRUE INSTRUCTION
		-] / [-
DEVICE	ACTUATED	TRUE INSTRUCTION
WIRED NORMALLY CLOSED		-] / [-
	UNACTUATED	TRUE INSTRUCTION
		-] [-