

## Section 260536 – Cable Tray Specification

1. Scope: Ladder and channel tray per project design.
2. Materials: Aluminum Type A for risers; Steel Type S for corridors.
3. Spacing: 9 in OC; capacity 40% fill.
4. References: See Drawing E■401.
5. Notes: No substitutions without written approval.