

Submittal 23■017 Rev 2 – Vendor Update

Submitted: Ladder Tray LT■R (Aluminum)

Submitted: *Channel Tray CT■1 changed to Aluminum* (Deviation)

Notes: Vendor claims faster lead time.

Highlight: Change not referenced in RFI.