

Engineer Response – Submittal 23■017

Status: Approved As Noted

Notes: CT■1 must remain steel per Spec 260536.

Deviation in Rev 2 not accepted.