

Onderhoudsrapport Keuring NEN-3140 & NEN-EN-IEC 60974-4

	Datum :	14-01	-2020									
	Firma :	J. de	Jonge	Lease	BV							
	Telefoon :	+31	10 248	58 00)							
		DHR										
	E-mail :											
	Adres :	Riga	3									
		2993		Bare	endrecht	t						
		_			_	-	_		_	_		
	Onderhoud van :	✓	Mig	L	Tig		\cup	Elektroden	Plasma	L	Overig	
	Merk :	Linco	ıln Elec	tric								
	Type :		erwave									
	Serienummer	U119	01066	71								
	Machinenummer klant :		1MI005									
		402 \	V									
_	Omschrijving werkzaamheden											
느	Inwendig vrijmaken van ijzerhoudend stof en and	der vu	il									
느	Elektrische verbindingen											
느	Mechanische verbindingen											
\Box	Schakelcontacten van magneetschakelaars, relais	s, etc.										
	Steekcontacten van printen											
√	Controleren van bijbehorende kabels (secundair o	en stu	urstroc	m) op	slijtage	, juiste	aans	sluiting en treko	ontlasting			
✓	Juiste werking stroombron											
✓	Waterpomp en waterdrukschakelaar, evt. luchtdr	uksch	akelaaı	plasm	na							
	Controleren van mechanische gedeelte op slijtage	e, spe	ling op	lagers	en bus	sen, sn	nering	yan mechanis	che gedeelte			
✓	Draadaanvoer op uitlijning, druk, juiste afstelling											
V	Toorts c.q. pistool											
✓	Draadaanvoer controleren op juiste werking											
√	Proeflassen met geheel											
	Werking VRD											
	Werking relevante veiligheidsgerelateerde functie	es										
	NEN-3140 & NEN-EN-IEC 60974-4											
	52.10 6.11 2.11. 2.20 6.67.1		Maa	Mi	T220 C	N. 1017	25026	0 / DCM20EE (CN.170611FF			
	Meetinstrument	:			11230 3		33030	58 / DCM305E S Functionele c			Ja	Nee
	Visuele controle			Ja •	Ξ	Nee			ontrole	•	Ja	☐ Nee
	Beschermingsklasse	:	_	Ι .	\cup	II		∐III				
	Weerstand beschermingsleiding	:	0.02	ohm								
	Gemeten lekstroom	:	mA									
	Isolatieweerstand tussen voeding	:	1000	Mohm	1							
	primair en secundair (las gedeelte) Isolatieweerstand tussen voeding		1000	Mohm	1							
	primair en behuizing PE	•	1000		•							
	Isolatiewaarde tussen secundair deel	:	1000	Mohm	1							
	en behuizing		47.0	\/o!+								
	Open spanning: gelijkspanning	:	47.9	VUIT								
	Open spanning: wisselspanning	:	Volt	_			_					
	Keuringsresultaat	:	✓	Goe	edgekeu	rd	\Box	Afgekeurd				
	Opmerkingen	:										

Monteur Arnold van Drie





Calibration report

Client: J de Jonge Lease BV

Kon. Wilhelminahaven ZZ 18

3134 KG Vlaardingen

Verification by: Laspartners Multiweld BV

Riga 3

2993LW Barendrecht

Brand and type: Lincoln PowerWave s500CE

Serial number : U1190106671 **Machine No.:** 09LMMI0050

No-load voltage Uo: (rating plate) 50 V

Highest set values for WFS 20,00 m/min

Highest set values for current(rating plate) 500 A Calibration range (max. set current) 400 A 396 V Supply voltage: Ambient temperature: 18 °C

Standard: NEN-EN-IEC 60974-14:2019

Calibration grade: Standard Method of calibration: Load resistor

Equipment function under test: CV **Equipment mode: GMAW Date of Calibration:** 14-1-2020

Results of Measurements:

No	Specifications			Setting	Meas	Measured		Reference		Deviation		Within tolerance	
	X % Of highest set value Setpoint		Loadresistance	Current	Voltage	Current	Voltage	Current	Voltage	Current	Voltage		
1	20%	400,0 A	80,0 A	80,0 A	165	82,20 A	17,4 V	80,0 A	17,3 V	2,20 A	0,10 V	Yes	Yes
2	40%	400,0 A	160,0 A	160,0 A	240	164,00 A	19,5 V	160,0 A	19,4 V	4,00 A	0,10 V	Yes	Yes
3	60%	400,0 A	240,0 A	240,0 A	345	246,00 A	23,5 V	240,0 A	23,4 V	6,00 A	0,10 V	Yes	Yes
4	80%	400,0 A	320,0 A	360,0 A	360	365,80 A	27,9 V	360,0 A	27,8 V	5,80 A	0,10 V	Yes	Yes
5	100%	400,0 A	400,0 A	400,0 A	405	407,00 A	28,6 V	400,0 A	28,5 V	7,00 A	0,10 V	Yes	Yes

Used measuring instrument(s):

Description:	Seriai no.	Cal. Date Due Date.	
Fluke 179	16170029	28-2-2019 28-2-2020	
N12R	66400501	21-11-2019 20-11-2020	
Digital tachometer	181210582	27-12-2019 27-12-2020	

C--:-1 ---

Final result: **PASSED**

Calibrated by: Arnold van Drie

Date of Certificate: 14-1-2020

Autograph:

Daaanin4ian.



Cal Data Dua Data



Calibration report

Client: J de Jonge Lease BV

Kon. Wilhelminahaven ZZ 18

3134 KG Vlaardingen

Verification by: Laspartners Multiweld BV

Riga 3

2993LW Barendrecht

Brand and type wire feeder: Lincoln PF 46
Serial number: P1190402546
Machine No.: 09LMMI0050

Highest set values for WFS 20 m/min

Ambient temperature: 18 °C

Standard: NEN-EN-IEC 60974-14:2019

Calibration grade:StandardDate of Calibration:14-1-2020

Results of Measurements:

No.		Spe	cifications		Measured	Reference	Deviation	Within tolerance
	X % Of	highest s	et value	Setpoint	m/min	m/min	m/min	m/min
1	20%	20,00	4,00	4,0	4,1	4,0	0,10	Yes
2	40%	20,00	8,00	8,0	8,2	8,0	0,20	Yes
3	60%	20,00	12,00	12,0	12,2	12,0	0,20	Yes
4	80%	20,00	16,00	16,0	16,3	16,0	0,30	Yes
5	100%	20,00	20,00	20,00	20,3	20,00	0,30	Yes

Used measuring instrument(s):

 Description:
 Serial no.
 Cal. Date
 Due Date.

 ST-6236B
 181210582
 27-12-2019
 27-12-2020

Final result: PASSED

Calibrated by: Peter den Engelsman

Date of Certificate: 14-1-2020

Autograph:

PD



Calibration report

Client: J de Jonge Lease BV

Kon. Wilhelminahaven ZZ 18

3134 KG Vlaardingen

Verification by: Laspartners Multiweld BV

Riga 3

2993LW Barendrecht

Brand and type wire feeder: Lincoln PowerFeed

Serial number: P1190108367
Machine No.: 09LMMI0050

Highest set values for WFS 20 m/min

Ambient temperature: 18 °C

Standard: NEN-EN-IEC 60974-14:2019

Calibration grade:StandardDate of Calibration:14-1-2020

Results of Measurements:

No.		Spe	cifications		Measured	Reference	Deviation	Within tolerance
	X % Of	highest s	et value	Setpoint	m/min	m/min	m/min	m/min
1	20%	20,00	4,00	4,0	4,1	4,0	0,10	Yes
2	40%	20,00	8,00	8,0	8,2	8,0	0,20	Yes
3	60%	20,00	12,00	12,0	12,3	12,0	0,30	Yes
4	80%	20,00	16,00	16,0	16,4	16,0	0,40	Yes
5	100%	20,00	20,00	20,00	20,4	20,00	0,40	Yes

Used measuring instrument(s):

 Description:
 Serial no.
 Cal. Date
 Due Date.

 ST-6236B
 181210582
 27-12-2019
 27-12-2020

Final result: PASSED

Calibrated by: Peter den Engelsman

Date of Certificate: 14-1-2020

Autograph:

