Validation Certificate NEN-EN-50504

Certificate number 2019-NEN-EN-50504-38680

:	J.	de	Jonge	Lease	В١	V
	:	: J.	: J. de	: J. de Jonge	: J. de Jonge Lease	: J. de Jonge Lease B\

Riga 3

2993 LW Barendrecht

Validated by : Laspartners Multiweld

Riga 3

2993 LW BARENDRECHT

Acting upon instructions from : J. de Jonge lease

Brand and type : Lincoln Electric, Powerwave S500

 Serial number
 : U1190105265

 Machine No
 : 09LMMI0051

 Open Voltage Uo
 : 47.7 V

Machine range : min.: 40 A max.: 550 A

Validation range Current : min.: 50 A max.: 400 A

Voltage : min.: 14 V max.: 30 V

Standards : NEN-EN-ISO 17662:2005

NEN-EN 50504:2008

Grade of validation : Standard

Type of validation : Accuracy

Equipment function under test : CV

Method of validation : Load resistor

Welding process : ☐ MMA ☐ GTAW ✔ GMAW

Date of Validation : 8-7-2019

Results of Measurements in attached form

Used measuring instrument(s):

 Fluke 175
 Serial No.:
 38350605
 Certificate No.:
 N-63853

 NI16R
 Serial No.:
 26500023
 Certificate No.:
 N-63607

Final result : PASSED

Validated by : Jan Willem van der Vorm

Date of certificate : 09-07-2019

Autograph :



Measurements Results

Certificate number 2019-NEN-EN-50504-38680

Client : J. de Jonge Lease BV

Riga 3

2993 LW Barendrecht

Validated by : Laspartners Multiweld

Riga 3

2993 LW BARENDRECHT

Engineer : Jan Willem van der Vorm

Brand and type : Lincoln Electric, Powerwave S500

Serial number : U1190105265
Machine No : 09LMMI0051

Supply voltage : 3 phases: 402 V 401 V 403 V

Ambient temperature : 23,6 °C Cables : 15

Setting slope / weld dynamics :

	Reading	Measured Value #1	Measured Value #2	Mean Value		Deviation	Max. allowed	Within range
	50 A	50.5 A	50.3 A	50.4 A		0.4 A	13.75 A	Yes
Amperage	138 A	139.1 A	138.7 A	138.9 A		0.9 A	13.75 A	Yes
Digital	225 A	226.7 A	226.6 A	226.6 A		1.6 A	13.75 A	Yes
meters	313 A	315.5 A	315.3 A	315.4 A		2.4 A	13.75 A	Yes
	400 A	403 A	403 A	403.0 A		3.0 A	13.75 A	Yes
	14 V	13.9 V	13.9 V	13.9 V		0.1 V	1.19 V	Yes
Voltage	18 V	18.1 V	17.8 V	18.0 V		0.0 V	1.19 V	Yes
Digital	22 V	21.7 V	21.8 V	21.8 V		0.2 V	1.19 V	Yes
meters	26 V	25.7 V	25.7 V	25.7 V		0.3 V	1.19 V	Yes
	30 V	29.7 V	29.7 V	29.7 V		0.3 V	1.19 V	Yes



Onderhoudsrapport Keuring NEN-3140 & NEN-EN-IEC 60974-4

Datum	8-7-2019
Firma	J. de Jonge Lease BV
Telefoon	: +31 10 248 58 00
Contactpersoon	DHR R.Langerak
E-mail	
Adres	Riga 3
Postcode - Plaats	2993 LW Barendrecht
Onderhoud van	: 📝 Mig 📗 Tig 📗 Elektroden 🦳 Plasma 📗 Overig
Merk	: Lincoln Electric
Туре	Powerwave S500
Serienummer	. U1190105265
Machinenummer klant	: 09LMMI0051
Netspanning	: 402 V
Juiste werking stroombron Waterpomp en waterdrukschakelaar, evt. luchto	en stuurstroom) op slijtage, juiste aansluiting en trekontlasting rukschakelaar plasma ge, speling op lagers en bussen, smering van mechanische gedeelte
NEN-3140 & NEN-EN-IEC 60974-4	
Meetinstrument	: Megger MIT230 SN:101350368 / DCM305E SN:17061155
Visuele controle	: 🗹 Ja 🗌 Nee Functionele controle : 🗹 Ja 🦳 Nee
Beschermingsklasse	: 🗸 г 🗌 п 🔲 ш
Weerstand beschermingsleiding	: 0.03 ohm
Gemeten lekstroom	; mA
Isolatieweerstand tussen voeding primair en secundair (las gedeelte) Isolatieweerstand tussen voeding	: 1000 Mohm : 1000 Mohm
primair en behuizing PE	
Isolatiewaarde tussen secundair deel en behuizing	: 1000 Mohm
Open spanning: gelijkspanning	: 47.7 Volt
Open spanning: wisselspanning	: Volt
Keuringsresultaat	: 🕢 Goedgekeurd 🗌 Afgekeurd
Opmerkingen	: Nieuwe machine

Monteur Jan Willem van der Vorm