SAFEMAN · STUDENT MODULE

SM-FIRE

Basic Firefighting & Fire Marshal

SafeMan™ by Oryx Institute · safeman.oryxinstitute.org

Theory + Live/Simulated Fire Practicum · Pass mark 70% · 3 modules

Name _____

Student no. _____ Class _____



info@oryxinstitute.org

WELCOME

SafeMan Basic Firefighting, Fire Marshal & Evacuation Commander

SafeMan Basic Firefighting, Fire Marshal & Evacuation Commander — Theory + Live/Simulated Fire Practicum. This SafeMan course is engineered for corporate audit readiness against: NTA Unit Std 1763 & 1157; GN 156 Fire Precautions; Fire Brigade Services Act 5 of 2006 (local authority).

REGULATORY DISCLOSURE — READ FIRST

SafeMan™ is a proprietary inter-organizational safety management and operational competency benchmark developed by Oryx Institute (safeman.oryxinstitute.org). Courses are engineered in alignment with ISO 45001:2018, ISO 14001:2015, ISO 31000, ILO-OSH guidelines, and pre-referenced against Namibia Training Authority (NTA) Unit Standards and Namibian Government Notice 156 of 1997 for corporate audit readiness. SafeMan credentials verify industry competency and attendance between organizations and are non-NQA credit-bearing.

Contact: info@oryxinstitute.org

Author: Tangi Iigonda · Institution: Oryx Institute | Oryx Safety Academy

How to use this module pack

Work through the modules in order. Each module states its focus and the key points you are expected to carry into practice. Diagrams referenced as web assets accompany the online reader at safeman.oryxinstitute.org. After the modules, sit the knowledge check: 12 questions, pass mark 70%, closed book.

This is a practicum course: after passing the knowledge check you must complete the assessor practicum checklist with a qualified assessor before your SafeMan credential is issued. A practical demonstration video slot is reserved in the online reader for every module.

MODULES

Module 1 — Fire tetrahedron & fire classes

What fire needs and how classes A, B, C, D and F/Electrical decide which medium fights it.

Key points

Tetrahedron: fuel, oxygen, heat, chain reaction — break one leg and the fire dies.

Class A solids, B flammable liquids, C gases, D metals, F cooking oils; electrical fires are treated as E until isolated.

Wrong medium kills: water on oil or live electricals spreads or electrocutes.

Diagram: /assets/webp/sm-extinguisher.webp

Practical video recording scheduled — follow the step-by-step illustrated checklist below.

Module 2 — Extinguishers, PASS & hose/blanket

Selecting and operating DCP, CO2, foam and wet chemical units, plus hose reels and fire blankets.

Key points

DCP for A/B/C and electrical; CO2 for electrical and liquid; foam for A/B; wet chemical for F.

PASS: Pull the pin, Aim at the base, Squeeze, Sweep — with wind at your back and an exit behind you.

Pre-use check: gauge, pin and seal, nozzle, cylinder damage — monthly and before use.

Hose reel for A-class solids; blanket smothers pan fires and burning clothing.

Diagram: /assets/webp/sm-extinguisher.webp

Practical video recording scheduled — follow the step-by-step illustrated checklist below.

Module 3 — Smoke, evacuation command & roll call

Smoke kills before flame; the fire marshal's drill from alarm to the handover to emergency services.

Key points

Smoke: keep low, close doors behind, never use lifts.

Marshal duties: sweep your zone, direct flow, count at assembly, report missing persons with last-seen location.

Roll call against the visitor and contractor registers, not just employees.

Handover to the fire service: what burns, who is missing, hazards and isolation status.

Diagram: /assets/webp/sm-extinguisher.webp

Practical video recording scheduled — follow the step-by-step illustrated checklist below.

ASSESSMENT

Knowledge check

The closed-book knowledge check draws 12 questions from the bank reproduced in Appendix A. Pass mark 70%. Your SafeMan credential is issued after the knowledge check and the practicum sign-off, and remains valid for 24 months from issue.

Assessor Practicum Checklist — Firefighting & Evacuation Command

Pass standard: Correct selection, inspection and discharge technique plus marshalling duties on live/simulated fire.

1	Correct extinguisher selected for a live/simulated Class A, B and electrical fire scenario.	
2	Pre-use inspection completed: gauge, pin and seal, nozzle, cylinder condition.	
3	Windward approach with PASS discharge sweep performed safely on the training fire.	
4	Fire blanket smothering drill demonstrated on the training pan.	
5	Roll-call register taken and a structured emergency services briefing delivered.	

Assessor name, role/qualification and company are captured on the sign-off screen of the SafeMan platform and bound into the QR-verified certificate record.

APPENDIX A — QUESTION BANK

Knowledge check bank

Q1. The fire tetrahedron comprises fuel, oxygen, heat and:

A. Smoke

B. Chain reaction

C. Water

D. CO2

Q2. Wet chemical extinguishers are for:

A. Class A only

B. Cooking oil (Class F) fires

C. Gas fires

D. Metal fires

Q3. PASS stands for:

A. Push, Align, Squeeze, Stop

B. Pull, Aim, Squeeze, Sweep

C. Press, Aim, Spray, Soak

D. Pull, Angle, Shoot, Stop

Q4. You approach a fire:

A. With the wind in your face

B. Upwind with an exit at your back

C. From any side

D. From above

Q5. Live electrical fires are best met with:

A. Water jet

B. CO2 or DCP

C. Foam

D. Wet chemical

Q6. Before using any extinguisher you check:

A. Colour only

B. Gauge, pin and seal, nozzle, cylinder body

C. The expiry decade

D. Its weight

Q7. Fire blankets work by:

A. Cooling

B. Smothering — cutting off oxygen

C. Chemical inhibition

D. Absorbing fuel

Q8. In smoke you should:

A. Stand upright and run

B. Stay low and close doors behind you

C. Use the lift

D. Open windows

Q9. Assembly roll call uses:

A. Memory

B. The attendance, visitor and contractor registers

C. The canteen list

D. A shout-out

Q10. Handover to fire services includes:

A. Only the address

B. What burns, who is missing, hazards, isolations

C. The insurance policy

D. The fire drill video

Q11. Hose reels suit:

A. Electrical panels

B. Class A solid fires

C. Oil fryers

D. Gas leaks

Q12. A fire marshal sweeping a zone:

A. Runs through

B. Checks rooms and closes doors while directing flow

C. Locks doors

D. Fights every fire found

Answer key

Q1=B Q2=B Q3=B Q4=B Q5=B Q6=B

Q7=B Q8=B Q9=B Q10=B Q11=B Q12=B