PUBLIC HEALTH ENGINEERING DEPARTMENT

PHED Haryana

STATE WATER TESTING LABORATORY ,KARNAL

Website :- https://phedharyana.gov.in/

Memo No:- **5646** Date:- **30/09/2026**

Subject : Physical / Chemical Examination Report of Water Sample

T0626HR18248

Sample ID/Classification :	KNL/08626/9/2026 / Private
Sender :	Principal, Brahmananad International School 2851
Location :	, Mundri, KTL
Sample Description :	Drinking Water
Latitute / Longitude :	76.989304 / 29.690605

Sample Details	Date & Time
Collected By	Staff
Collection Date	30/09/2026 at 11:28
Received at lab	30/09/2026 at 11:37
Analysis Start Date	30/09/2026
Analysis End Date	30/09/2026
Sample Quantity	1000ML

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2022)
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :1984 (RA 2022)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :1984 (RA 2018)
4	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part 4): 2021
5	Total Dissolved Solids @ 180°c ± 2°c	490	500 mg/lt.	2000 mg/lt.	IS 3025 (Part-16) : 2023
6	Total Hardness as CaCo3	300	200 mg/lt.	600 mg/lt.	IS 3025 (Part-21) : 2009 (RA 2023)
7	Calcium (as Ca)	60	75 mg/lt.	200 mg/lt.	IS 3025 (Part-40) :1991 (RA 2023)
8	Magnesium (as Mg)	36	30 mg/lt.	100 mg/lt.	IS 3025 (Part-46) (RA 2023)
9	Total Alkalinity	310	200 mg/lt.	600 mg/lt.	IS 3025 (Part-23) : 1986 (RA 2019)
10	Chloride (as Cl)	55	250 mg/lt.	1000 mg/lt.	IS 3025 (Part-32) :1988 (RA 2019)
11	Sulphate as So4	25	200 mg/lt.	400 mg/lt.	USEPA-8051:2017
12	Fluoride (as F)	0.440	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C
13	Iron (as Fe)	0.02	1.0 mg/lt.	1.0 mg/lt.	USEPA-8008:2017
14	Nitrate (as No3)	2.1	45 mg/lt.	45 mg/lt.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°c	7.49	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 2022

Remarks :-

* The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
* The test report can't be used for any publicity or any legal purpose.
* Reliability of water sample sample lies with sender/collector of water sample.
* To check the sample report online Scan the QR Code below.
* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless untill specifically requested by the customer for retaining over a longer period.

Sample analyzed by : Jagjinder Singh

State Water Testing Laboratory CHIEF CHEMIST KARNAL

AMIT KUMAR ,CHIEF CHEMIST 30/09/2026
STATE WATER TESTING LABORATORY,KARNAL
email:-chiefchemist.hr@phedharyana.gov.in