



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 12.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 11.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 11-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 11.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 12-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	56837	63789	47731	26136	3357	197850
Peak Shortage (MW)	0	0	0	258	0	258
Energy Met (MU)	1193	1394	1121	568	64	4340
Hydro Gen (MU)	239	106	169	105	36	656
Wind Gen (MU)	3	34	34	-	-	72
Solar Gen (MU)*	173.23	139.54	133.66	3.40	0.67	451
Energy Shortage (MU)	0.00	0.00	0.00	0.26	0.00	0.26
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59073	66395	51266	28826	3447	206278
Time Of Maximum Demand Met	18:41	18:38	15:20	19:10	18:03	18:40

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.00	0.00	4.50	4.50	83.24	12.26

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9694	0	182.1	89.6	-0.1	661	0.00
	Haryana	8452	0	173.3	150.8	0.1	342	0.00
	Rajasthan	11492	0	235.4	78.9	-3.0	997	0.00
	Delhi	4228	0	85.6	82.9	0.4	280	0.00
	UP	20576	0	386.9	139.3	-4.2	534	0.00
	Uttarakhand	2178	0	40.4	23.0	0.5	117	0.00
	HP	1641	0	31.4	7.5	-0.3	119	0.00
	J&K(UT) & Ladakh(UT)	2673	0	49.4	35.7	-0.6	287	0.00
	Chandigarh	219	0	3.9	3.8	0.1	42	0.00
	Railways_NR ISTS	208	0	4.3	3.9	0.4	39	0.00
WR	Chhattisgarh	4920	0	105.4	52.1	-1.5	229	0.00
	Gujarat	20668	0	433.8	222.4	-5.5	887	0.00
	MP	11338	0	233.7	121.9	0.0	417	0.00
	Maharashtra	25891	0	539.2	198.8	-3.5	482	0.00
	Goa	697	0	14.9	14.0	0.5	53	0.00
	DNHDDPDCL	1289	0	30.1	30.6	-0.5	57	0.00
	AMNSIL	775	0	17.6	11.1	0.4	258	0.00
	BALCO	562	0	13.4	13.4	0.0	9	0.00
	RIL JAMNAGAR	257	0	6.0	6.0	0.0	0	0.00
	Andhra Pradesh	9464	0	205.8	65.3	-1.8	396	0.00
SR	Telangana	12165	0	232.5	95.4	-1.6	642	0.00
	Karnataka	11059	0	223.6	65.7	-1.8	697	0.00
	Kerala	4521	0	87.7	56.1	-0.2	680	0.00
	Tamil Nadu	16550	0	361.2	210.0	-2.0	516	0.00
	Puducherry	455	0	10.7	9.8	-0.2	37	0.00
	Bihar	6516	0	133.4	123.7	-0.6	373	0.00
ER	DVC	3326	0	66.2	-30.2	-0.3	609	0.00
	Jharkhand	2186	0	42.8	31.1	-1.3	321	0.26
	Odisha	6081	0	117.8	39.9	-2.7	457	0.00
	West Bengal	9809	0	206.5	68.1	-2.1	452	0.00
	Sikkim	85	0	1.3	1.3	0.1	23	0.00
	Railways_ER ISTS	13	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	172	0	3.0	3.0	-0.3	31	0.00
	Assam	2200	0	42.0	33.7	0.6	128	0.00
	Manipur	226	0	3.1	3.1	0.0	31	0.00
	Meghalaya	344	0	5.8	-0.9	0.0	49	0.00
	Mizoram	132	0	2.0	0.9	-0.1	57	0.00
	Nagaland	152	0	2.6	2.4	-0.2	9	0.00
	Tripura	275	0	5.2	5.1	-0.1	31	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	44.7	24.6	-24.5	-29.9
Day Peak (MW)	1923.6	1174.4	-1032.9	-1374.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	164.8	-177.4	133.7	-122.1	0.9	0.0
Actual(MU)	182.3	-171.4	131.1	-154.8	-1.0	-13.9
O/D/U/D(MU)	17.5	6.0	-2.7	-32.7	-2.0	-13.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7342	11777	6028	2580	265	27991	43
State Sector	11489	13092	9443	2387	199	36609	57
Total	18831	24868	15471	4967	464	64600	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	605	1304	580	670	11	3170	68
Lignite	22	16	55	0	0	92	2
Hydro	239	106	169	105	36	656	14
Nuclear	31	65	66	0	0	161	3
Gas, Naptha & Diesel	6	26	5	0	21	58	1
RES (Wind, Solar, Biomass & Others)	183	175	189	6	1	554	12
Total	1085	1692	1063	781	69	4691	100

Share of RES in total generation (%)	16.85	10.34	17.79	0.81	0.98	11.81
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.70	20.48	39.87	14.26	53.27	29.23

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.013
Based on State Max Demands	1.034

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	191380	16:59	0
Non-Solar hr	206278	18:40	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)

Date of Reporting: 12-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	312	0.0	8.0	-8.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	260	1101	0.0	10.5	-10.5
4	765 kV	SASARAM-FATEHPUR	1	143	477	0.0	5.6	-5.6
5	765 kV	GAYA-BALIA	1	0	673	0.0	8.1	-8.1
6	400 kV	PUSAULI-VARANASI	1	0	125	0.0	1.6	-1.6
7	400 kV	PUSAULI -ALLAHABAD	1	23	81	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	883	0.0	13.7	-13.7
9	400 kV	PATNA-BALIA	2	70	788	0.0	10.4	-10.4
10	400 kV	NAUBATPUR-BALIA	2	88	383	0.0	3.0	-3.0
11	400 kV	BIHARSHARIFF-BALIA	2	261	263	0.0	1.2	-1.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	528	0.0	8.1	-8.1
13	400 kV	BIHARSARIFE SAHIUPURI	2	439	378	0.0	4.0	-4.0
14	220 kV	SAHUPURI-KARMANASA	1	0	49	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.1	-0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	79.0	-78.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1226	647	1.2	0.0	1.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1239	662	8.3	0.0	8.3
3	765 kV	JHARSUGUDA-DURG	2	27	687	0.0	9.4	-9.4
4	400 kV	JHARSUGUDA-RAIGARH	4	269	506	0.0	5.0	-5.0
5	400 kV	RANCHI-SIPAT	2	300	216	0.8	0.0	0.8
6	400 kV	JEYPORE-JAGDALPUR	2	361	292	0.3	0.0	0.3
7	220 kV	BUDHIPADAR-RAIGARH	1	42	121	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	199	61	1.1	0.0	1.1
ER-WR						11.6	15.5	-3.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	744	0.0	13.3	-13.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1622	0.0	40.9	-40.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2712	0.0	44.9	-44.9
4	400 kV	TALCHER-I/C	2	516	1031	0.0	7.6	-7.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	99.0	-99.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	77	213	0.3	1.0	-0.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	523	0.0	6.9	-6.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	94	0.0	1.0	-1.0
ER-NER						0.3	8.8	-8.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	402	0.0	9.7	-9.7
NER-NR						0.0	9.7	-9.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2017	0.0	33.8	-33.8
2	HVDC	VINDHYACHAL B/B	-	0	57	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	133	1631	0.0	18.1	-18.1
5	765 kV	GWALIOR-PHAGI	2	736	2172	1.8	27.5	-25.7
6	765 kV	JABALPUR-ORAI	2	105	883	0.0	20.9	-20.9
7	765 kV	GWALIOR-ORAI	1	1071	0	16.5	0.0	16.5
8	765 kV	SATNA-ORAI	1	0	838	0.0	14.2	-14.2
9	765 kV	BANASKANTHA-CHITORGARH	2	2548	0	43.7	0.0	43.7
10	765 kV	VINDHYACHAL-VARANASI	2	25	1425	0.0	21.8	-21.8
11	400 kV	ZERDA-KANKROLI	1	451	0	8.4	0.0	8.4
12	400 kV	ZERDA -BHINMAL	1	312	0	5.8	0.0	5.8
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	566	355	2.8	2.4	0.4
15	400 kV	NEEMUCH-Chittorgarh	2	418	444	1.4	3.6	-2.2
16	220 kV	BHANPURA-RANPUR	1	0	108	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	109	0	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	87	6	0.6	0.0	0.6
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						81.9	183.4	-101.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	580	0.0	11.0	-11.0
2	HVDC	RAIGARH-PUGALUR	2	0	5012	0.0	66.6	-66.6
3	765 kV	SOLAPUR-RAICHUR	2	1355	459	9.2	0.7	8.6
4	765 kV	WARDHA-NIZAMABAD	2	145	1918	0.1	24.0	-23.9
5	765 kV	WARORA-WARANGAL(NEW)	2	46	1411	0.0	18.5	-18.5
6	400 kV	KOLHAPUR-KUDGI	2	2002	0	37.8	0.0	37.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	82	0.1	0.0	0.1
WR-SR						47.2	120.8	-73.6
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1203	1073	1180	28.32		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	666	416	611	14.66		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	65	3	35	0.84		
	NER	132kV GELEPHU-SALAKATI	-9	-1	-6	-0.15		
	NER	132kV MOTANGA-RANGIA	51	0	42	1.00		
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	62	1.50		
	ER	NEPAL IMPORT (FROM BIHAR)	190	97	161	3.85		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	876	638	803	19.27		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-959	-892	-956	-22.95		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1374	-1052	-1246	-29.91		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-71	0	-63	-1.50		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 12-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.63	0.15	0.00	0.00	0.00	0.00	0.00	0.00	23.78
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.63	0.15	0.00	0.00	0.00	0.00	0.00	0.00	23.78

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	23.40	0.00	1.58	0.00	0.00	0.00	0.00	0.00	24.98
Nepal	9.14	4.77	5.83	0.00	0.00	4.00	0.00	0.00	23.74
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	32.54	4.77	7.41	0.00	0.00	4.00	0.00	0.00	48.72

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	23.40	0.00	1.58	0.00	0.00	0.00	0.00	0.00	24.98	
Nepal	9.14	4.77	5.83	0.00	0.00	0.00	4.00	0.00	0.00	23.74
Bangladesh	-23.63	-0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.78
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	8.91	4.62	7.41	0.00	0.00	0.00	4.00	0.00	0.00	24.94

