



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 09.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 08.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 8-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 08.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 09-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61926	64849	45561	23093	2727	198156
Peak Shortage (MW)	0	0	0	423	0	423
Energy Met (MU)	1281	1494	1197	472	48	4491
Hydro Gen (MU)	88	36	95	22	11	252
Wind Gen (MU)	4	93	60	-	-	157
Solar Gen (MU)*	163.12	106.40	135.11	3.15	0.47	408
Energy Shortage (MU)	0.00	0.00	0.00	0.64	0.00	0.64
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67855	74487	60835	23940	2843	227199
Time Of Maximum Demand Met	10:31	09:45	09:39	18:37	17:26	09:44

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.00	1.57	1.57	76.72	21.71

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8467	0	153.6	63.4	0.3	470	0.00
	Haryana	8322	0	158.0	107.8	-1.5	431	0.00
	Rajasthan	18355	0	336.8	115.7	0.6	612	0.00
	Delhi	5406	0	88.4	80.9	-1.6	485	0.00
	UP	21385	0	382.0	130.5	0.2	560	0.00
	Uttarakhand	2544	0	46.8	37.3	1.6	168	0.00
	HP	2164	0	38.5	32.2	-0.3	277	0.00
	J&K(UT) & Ladakh(UT)	3120	0	68.0	64.1	-0.3	933	0.00
	Chandigarh	291	0	4.7	4.5	0.2	58	0.00
WR	Railways_NR ISTS	201	0	4.0	3.7	0.4	46	0.00
	Chhattisgarh	5460	0	110.3	60.6	-0.7	197	0.00
	Gujarat	21240	0	406.2	170.1	-3.4	621	0.00
	MP	16569	0	313.7	192.9	-2.3	726	0.00
	Maharashtra	28144	0	586.6	192.8	-2.2	801	0.00
	Goa	703	0	14.0	13.3	0.2	76	0.00
	DNHDDPDCL	1342	0	30.8	30.9	-0.1	42	0.00
	AMNSIL	781	0	16.8	7.1	0.6	267	0.00
	BALCO	532	0	12.7	12.7	0.0	886	0.00
SR	RIL JAMNAGAR	110	0	2.6	2.6	0.0	0	0.00
	Andhra Pradesh	11303	0	206.8	53.3	-0.3	544	0.00
	Telangana	14476	0	267.5	144.1	0.4	1002	0.00
	Karnataka	16157	0	286.1	94.3	-1.3	472	0.00
	Kerala	4361	0	83.5	63.5	1.8	590	0.00
	Tamil Nadu	16633	0	344.2	207.9	-0.3	646	0.00
	Puducherry	393	0	8.5	8.3	-0.3	35	0.00
ER	Bihar	5672	0	107.3	97.0	-1.7	313	0.64
	DVC	3221	0	69.9	-40.5	0.2	282	0.00
	Jharkhand	2063	0	38.3	27.5	0.0	287	0.00
	Odisha	5283	0	103.9	31.4	-1.6	385	0.00
	West Bengal	7480	0	151.2	11.5	-1.0	149	0.00
	Sikkim	121	0	1.7	1.8	-0.2	29	0.00
	Railways_ER ISTS	21	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	176	0	3.0	3.0	-0.1	17	0.00
	Assam	1526	0	25.5	19.3	0.5	227	0.00
	Manipur	241	0	3.6	3.9	-0.3	29	0.00
	Meghalaya	364	0	6.5	5.5	-0.2	67	0.00
	Mizoram	159	0	2.5	1.9	-0.2	24	0.00
	Nagaland	150	0	2.4	2.4	0.0	16	0.00
	Tripura	234	0	4.1	3.5	0.1	47	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.9	-7.7	-22.3	-14.6
Day Peak (MW)	-433.0	-543.0	-1028.0	-764.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	260.8	-293.3	163.1	-136.0	5.4	0.0
Actual(MU)	259.6	-292.6	161.0	-137.3	4.1	-5.3
O/D/U/D(MU)	-1.2	0.7	-2.1	-1.4	-1.3	-5.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5191	6886	4548	5193	748	22566	43
State Sector	6958	11335	7443	3349	191	29275	57
Total	12149	18220	11991	8542	939	51841	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	766	1592	621	662	13	3655	75
Lignite	23	17	58	0	0	99	2
Hydro	88	36	95	22	11	252	5
Nuclear	32	54	71	0	0	157	3
Gas, Naptha & Diesel	13	15	14	0	24	65	1
RES (Wind, Solar, Biomass & Others)	193	203	235	6	0	638	13
Total	1115	1917	1093	691	48	4865	100

Share of RES in total generation (%)	17.28	10.60	21.48	0.93	0.97	13.11
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.08	15.29	36.61	4.12	23.63	21.51

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.035

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	227199	9:44	0
Non-Solar hr	205138	18:36	441

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 09-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	0	0.0	6.0	-6.0
3	765 kV	GAYA-VARANASI	2	262	816	0.0	8.9	-8.9
4	765 kV	SASARAM-FATEHPUR	1	72	498	0.0	6.1	-6.1
5	765 kV	GAYA-BALIA	1	0	853	0.0	12.8	-12.8
6	400 kV	PUSAULI-VARANASI	1	4	247	0.0	5.5	-5.5
7	400 kV	PUSAULI -ALLAHABAD	1	5	131	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	72	573	0.0	6.3	-6.3
9	400 kV	PATNA-BALIA	2	0	811	0.0	12.2	-12.2
10	400 kV	NAUBATPUR-BALIA	2	0	560	0.0	3.7	-3.7
11	400 kV	BIHARSHARIFF-BALIA	2	52	232	0.0	4.0	-4.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	455	0.0	6.9	-6.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	2.9	-2.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	75.5	-74.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	630	956	0.0	2.2	-2.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	787	614	2.5	0.0	2.5
3	765 kV	JHARSUGUDA-DURG	2	0	931	0.0	15.8	-15.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	621	0.0	8.3	-8.3
5	400 kV	RANCHI-SIPAT	2	209	206	0.1	0.0	0.1
6	220 kV	BUDHIPADAR-RAIGARH	1	0	119	0.0	1.8	-1.8
7	220 kV	BUDHIPADAR-KORBA	2	127	40	1.3	0.0	1.3
ER-WR						4.0	28.2	-24.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1249	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2705	0.0	50.7	-50.7
4	400 kV	TALCHER-I/C	2	534	40	1.7	0.0	1.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	86.0	-86.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	323	20	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	549	0	6.5	0.0	6.5
3	220 kV	ALIPURDUAR-SALAKATI	2	123	0	1.7	0.0	1.7
ER-NER						11.6	0.0	11.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	660	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3532	0.0	73.9	-73.9
2	HVDC	VINDHYACHAL B/B	-	270	102	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	981	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	0	2809	0.0	32.3	-32.3
5	765 kV	GWALIOR-PHAGI	2	320	1843	0.4	21.6	-21.2
6	765 kV	JABALPUR-ORAI	2	0	1383	0.0	30.5	-30.5
7	765 kV	GWALIOR-ORAI	1	825	0	13.4	0.0	13.4
8	765 kV	SATNA-ORAI	1	0	1228	0.0	20.9	-20.9
9	765 kV	BANASKANTHA-CHITORGARH	2	1202	936	5.6	4.2	1.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	3297	0.0	45.4	-45.4
11	400 kV	ZERDA-KANKROLI	1	231	138	1.3	0.6	0.7
12	400 kV	ZERDA -BHINMAL	1	159	95	0.9	0.4	0.5
13	400 kV	VINDHYACHAL -RIHAND	1	969	0	21.3	0.0	21.3
14	400 kV	RAPP-SHUJALPUR	2	490	478	3.3	1.6	1.6
15	400 kV	NEEMUCH-Chittorgarh	2	495	459	3.7	1.5	2.2
16	220 kV	BHANPURA-RANPUR	1	0	148	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	128	3	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	86	23	0.6	0.1	0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						51.5	262.7	-211.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	18.6	-18.6
2	HVDC	RAIGARH-PUGALUR	2	0	2506	0.0	47.4	-47.4
3	765 kV	SOLAPUR-RAICHUR	2	1499	1327	7.4	9.8	-2.4
4	765 kV	WARDHA-NIZAMABAD	2	439	2394	0.4	33.5	-33.1
5	765 kV	WARORA-WARANGAL(NEW)	2	229	2387	0.1	35.3	-35.2
6	400 kV	KOLHAPUR-KUDGI	2	1648	0	29.3	0.0	29.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	106	2.0	0.0	2.0
WR-SR						39.2	144.6	-105.4
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	231	-9	89	2.14		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-237	99	-77	-1.84		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-247	-141	-195	-4.68		
	NER	132kV GELEPHU-SALAKATI	-23	0	-19	-0.45		
	NER	132kV MOTANGA-RANGIA	-14	0	-4	-0.09		
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-1.25		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-1.15		
	ER	NEPAL IMPORT (FROM BIHAR)	-178	-33	-86	-2.07		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-297	108	-134	-3.21		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-934	-648	-876	-21.02		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-764	-405	-608	-14.59		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-94	0	-52	-1.25		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 09-Jan-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	5.92	0.00	0.00	0.00	0.00	0.00	6.22
Nepal	2.09	0.00	1.56	0.00	0.00	1.83	0.00	0.00	5.48
Bangladesh	21.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.96	0.30	7.48	0.00	0.00	1.83	0.00	0.00	33.57

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.86
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.86

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.86	-0.30	-5.92	0.00	0.00	0.00	0.00	0.00	-5.36
Nepal	-2.09	0.00	-1.56	0.00	0.00	-1.83	0.00	0.00	-5.48
Bangladesh	-21.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.10	-0.30	-7.48	0.00	0.00	-1.83	0.00	0.00	-32.71

