



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 17.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	75715	55735	44401	29801	3716	209368
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1694	1316	1001	644	73	4728
Hydro Gen (MU)	368	103	174	105	43	793
Wind Gen (MU)	10	63	302	-	-	374
Solar Gen (MU)*	182.12	101.09	110.01	3.30	0.99	398
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	76401	58318	47389	31378	3733	210682
Time Of Maximum Demand Met	22:47	10:30	09:54	22:30	18:45	19:48

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.062	0.19	1.94	13.25	15.38	69.91	14.71

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14136	0	289.6	183.1	-1.5	654	0.00
	Haryana	10357	0	221.7	178.8	-2.8	255	0.00
	Rajasthan	16070	0	348.0	167.6	-2.0	711	0.00
	Delhi	5558	0	116.5	108.0	-0.4	237	0.00
	UP	27784	0	579.5	247.4	0.0	873	0.00
	Uttarakhand	2256	0	45.6	23.6	1.4	235	0.00
	HP	1562	0	32.6	-7.6	-0.8	105	0.00
	J&K(UT) & Ladakh(UT)	2563	0	49.8	26.0	-0.5	154	0.00
	Chandigarh	295	0	5.9	5.7	0.3	27	0.00
	Railways NR ISTS	203	0	4.3	3.8	0.5	35	0.00
WR	Chhattisgarh	5654	0	128.3	68.3	1.5	480	0.00
	Gujarat	16735	0	372.7	188.6	-1.7	1149	0.00
	MP	11784	0	260.9	133.9	-0.6	593	0.00
	Maharashtra	21967	0	476.1	160.1	-5.3	751	0.00
	Goa	574	0	13.8	11.2	2.1	65	0.00
	DNHDDPDCL	1253	0	26.8	27.0	-0.2	83	0.00
	AMNSIL	819	0	18.7	11.9	0.2	292	0.00
	BALCO	530	0	12.6	12.7	-0.1	0	0.00
	RIL JAMNAGAR	249	0	6.0	6.0	0.0	0	0.00
	Andhra Pradesh	8959	0	194.8	8.9	-1.5	624	0.00
SR	Telangana	10500	0	208.7	68.0	-0.6	703	0.00
	Karnataka	9385	0	181.3	13.9	-3.2	523	0.00
	Kerala	3800	0	76.7	40.6	-2.5	238	0.00
	Tamil Nadu	15941	0	331.2	92.3	-7.0	872	0.00
	Puducherry	384	0	8.5	8.1	-0.1	49	0.00
ER	Bihar	8102	0	166.7	158.0	-0.1	401	0.00
	DVC	3135	0	68.4	-29.6	0.1	323	0.00
	Jharkhand	2210	0	44.8	35.2	0.9	122	0.00
	Odisha	6408	0	136.2	46.4	-1.8	544	0.00
	West Bengal	11391	0	227.1	101.0	-1.1	321	0.00
	Sikkim	63	0	0.9	1.1	-0.2	49	0.00
NER	Railways ER ISTS	19	0	0.2	0.1	0.1	4	0.00
	Arunachal Pradesh	208	0	4.0	3.7	-0.2	35	0.00
	Assam	2595	0	48.8	42.0	-0.2	163	0.00
	Manipur	215	0	3.4	3.2	0.2	36	0.00
	Meghalaya	365	0	6.2	1.8	0.1	127	0.00
	Mizoram	110	0	1.9	0.8	-0.5	0	0.00
	Nagaland	186	0	3.0	2.9	-0.2	13	0.00
	Tripura	333	0	5.7	4.3	0.1	69	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	55.0	10.6	-24.3	-24.9
Day Peak (MW)	2355.1	730.2	-1023.5	-1454.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	411.2	-205.4	-134.7	-73.0	2.0	0.0
Actual(MU)	393.2	-192.4	-133.2	-76.6	1.6	-7.3
O/D/U/D(MU)	-18.0	13.1	1.5	-3.6	-0.4	-7.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5861	16103	10368	4170	156	36658	51
State Sector	7659	12945	10670	3462	199	34935	49
Total	13520	29048	21038	7632	355	71592	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	749	1283	480	683	13	3208	63
Lignite	25	14	54	0	0	93	2
Hydro	368	103	174	105	43	793	16
Nuclear	38	49	47	0	0	134	3
Gas, Naptha & Diesel	15	13	2	0	20	50	1
RES (Wind, Solar, Biomass & Others)	198	165	437	5	1	806	16
Total	1393	1627	1194	793	77	5084	100

Share of RES in total generation (%)	14.20	10.12	36.59	0.66	1.32	15.85
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	43.35	19.47	55.06	13.95	57.62	34.09

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.031
Based on State Max Demands	1.066

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	207926	11:40	0
Non-Solar hr	210682	19:48	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 17-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	401	0.0	9.2	-9.2
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	460	906	0.0	8.6	-8.6
4	765 kV	SASARAM-FATEHPUR	1	227	447	0.0	4.0	-4.0
5	765 kV	GAYA-BALIA	1	0	853	0.0	14.8	-14.8
6	400 kV	PUSAULI-VARANASI	1	0	130	0.0	1.7	-1.7
7	400 kV	PUSAULI-ALLAHABAD	1	39	65	0.0	0.7	-0.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	880	0.0	12.4	-12.4
9	400 kV	PATNA-BALIA	2	16	899	0.0	12.9	-12.9
10	400 kV	NAUBATPUR-BALIA	2	5	389	0.0	3.4	-3.4
11	400 kV	BIHARSHARIFF-BALIA	2	281	334	0.0	1.3	-1.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	505	0.0	8.2	-8.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	111	390	0.0	4.5	-4.5
14	220 kV	SAHUPURI-KARAMNESA	1	0	70	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	85.2	-84.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	395	933	0.0	7.9	-7.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2265	0	36.0	0.0	36.0
3	765 kV	JHARSUGUDA-DURG	2	83	379	0.0	4.9	-4.9
4	400 kV	JHARSUGUDA-RAIGARH	4	332	147	1.9	0.0	1.9
5	400 kV	RANCHI-SIPAT	2	533	0	6.1	0.0	6.1
6	400 kV	JEYPORE-JAGDALPUR	2	0	595	0.0	8.6	-8.6
7	220 kV	BUDHIPADAR-RAIGARH	1	0	117	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	49	95	0.0	0.7	-0.7
ER-WR						43.9	23.7	20.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	677	0	17.2	0.0	17.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1616	0.0	31.2	-31.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1799	0.0	26.2	-26.2
4	400 kV	TALCHER-I/C	2	516	253	3.4	0.0	3.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						17.2	57.4	-40.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	174	255	1.0	1.4	-0.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	654	0.0	6.5	-6.5
3	220 kV	ALIPURDUAR-SALAKATI	2	0	136	0.0	1.6	-1.6
ER-NER						1.0	9.5	-8.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	303	0.0	7.2	-7.2
NER-NR						0.0	7.2	-7.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3040	0.0	71.7	-71.7
2	HVDC	VINDHYACHAL-B/B	-	0	106	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1265	0.0	25.4	-25.4
4	765 kV	GWALIOR-AGRA	2	0	2611	0.0	45.2	-45.2
5	765 kV	GWALIOR-PHAGI	2	123	2199	0.1	31.2	-31.1
6	765 kV	JABALPUR-ORAI	2	0	1436	0.0	48.0	-48.0
7	765 kV	GWALIOR-ORAI	1	763	0	13.5	0.0	13.5
8	765 kV	SATNA-ORAI	1	0	1160	0.0	20.8	-20.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1200	1178	10.3	2.9	7.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	3258	0.0	62.3	-62.3
11	400 kV	ZERDA-KANKROLI	1	227	103	1.7	0.2	1.5
12	400 kV	ZERDA-BHINMAL	1	156	71	1.2	0.2	1.0
13	400 kV	VINDHYACHAL-RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	156	671	0.4	7.3	-6.8
15	400 kV	NEEMUCH-Chittorgarh	2	18	823	0.0	11.0	-11.0
16	220 kV	BHANPURA-RANPUR	1	0	143	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.9	-2.9
18	220 kV	MEHGAON-AURAIYA	1	73	30	0.3	0.0	0.3
19	220 kV	MALANPUR-AURAIYA	1	46	46	0.0	0.1	-0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						27.6	334.5	-306.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	504	0	11.8	0.0	11.8
2	HVDC	RAIGARH-PUGAULUR	2	1930	0	34.1	0.0	34.1
3	765 kV	SOLAPUR-RAICHUR	2	2631	0	43.2	0.0	43.2
4	765 kV	WARDHAN-NIZAMABAD	2	1223	1050	7.0	5.0	2.0
5	765 kV	WARORA-WARANGAL(NEW)	2	1192	735	6.9	3.0	3.9
6	400 kV	KOLHAPUR-KUDGI	2	2182	0	38.3	0.0	38.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	114	2.0	0.0	2.0
WR-SR						143.2	8.0	135.2

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1.2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1352	687	1352	37.51	
	ER	400kV TALA-BINAGURI 1.2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	913	830	866	20.77	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	141	59	104	2.50	
	NER	132kV GELEPHU-SALAKATI	41	-8	22	0.52	
	NER	132kV MOTANGA-RANGIA	23	-13	-4	-0.09	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-46	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-46	0	-3	-0.08	
	ER	NEPAL IMPORT (FROM BIHAR)	139	105	119	2.85	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	454	170	328	7.87	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-975	-964	-969	-23.25	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1454	-809	-1035	-24.85	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-52	0	-43	-1.02	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 17-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.38
Bangladesh	23.93	0.13	0.00	0.00	0.00	0.00	0.00	0.00	24.06
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.31	0.13	0.00	0.00	0.00	0.00	0.00	0.00	24.44

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	52.97	0.00	1.76	0.00	0.00	0.15	0.00	0.00	54.88
Nepal	8.40	3.81	1.62	0.00	0.00	0.60	0.00	0.00	14.43
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	61.37	3.81	3.38	0.00	0.00	0.75	0.00	0.00	69.31

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	52.97	0.00	1.76	0.00	0.00	0.15	0.00	0.00	54.88
Nepal	8.02	3.81	1.62	0.00	0.00	0.60	0.00	0.00	14.05
Bangladesh	-23.93	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	-24.06
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	37.06	3.68	3.38	0.00	0.00	0.75	0.00	0.00	44.87

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.03	190290	5269	15740	0	29794	1931	137337	1567	174550	191638	1188
0:15	50.03	188912	5264	15818	0	29916	1935	135994	1570	173094	190497	1180
0:30	50.03	187697	5266	15751	0	29611	1934	135299	1547	171946	189408	1183
0:45	50.03	187023	5260	15892	0	29324	1915	134846	1553	171131	188790	1185
1:00	50.03	185371	5279	15645	0	29109	1934	133658	1562	169726	187187	1215
1:15	49.98	184084	5266	15643	0	28711	1929	133438	1566	168441	186553	1242
1:30	50.03	183144	5258	15731	0	28565	1937	132499	1585	167413	185575	1225
1:45	50.03	181995	5277	15767	0	28038	1926	131660	1603	166228	184271	1245
2:00	50.03	180901	5261	15762	0	28468	1864	130376	1560	165139	183291	1212
2:15	50.03	180418	5264	15804	0	28426	1841	129855	1528	164614	182718	1233
2:30	50.03	179792	5270	15785	0	28484	1926	129160	1492	164007	182117	1236
2:45	50.03	179327	5267	16054	0	28301	1928	128640	1465	163273	181655	1238
3:00	50.08	178534	5254	16137	0	27651	1947	128620	1480	162397	181089	1229
3:15	50.03	177938	5264	16038	0	27588	1936	127987	1466	161900	180279	1256
3:30	50.03	177502	5263	15948	0	27496	1941	127586	1476	161554	179710	1259
3:45	50.03	177081	5272	15963	0	27365	1942	127204	1567	161118	179313	1264
4:00	50.03	176717	5276	15742	0	27418	1934	127058	1483	160975	178911	1234
4:15	50.03	176997	5275	15465	0	27836	1929	127415	1525	161532	179445	854
4:30	50.03	177241	5266	15556	0	27880	1945	127553	1511	161685	179711	872
4:45	50.08	177608	5262	15519	0	27936	1949	128302	1465	162089	180433	868
5:00	50.03	178028	5269	15362	-4	27950	1952	128749	1481	162670	180759	872
5:15	50.03	179085	5273	15254	-5	27856	1932	129959	1468	163836	181737	914
5:30	50.03	179571	5261	15219	-6	27891	1938	130342	1521	164358	182166	916
5:45	50.03	179983	5268	15205	-5	27862	1930	130759	1493	164783	182512	939
6:00	50.03	180345	5260	14944	22	28073	1933	131346	1489	165379	183067	949
6:15	49.98	182278	5252	14910	36	28765	1916	132080	1523	167042	184772	976
6:30	49.98	184520	5252	14885	1258	29504	1907	132671	1505	168377	186982	966
6:45	49.93	186172	5222	14664	2918	29450	1920	132783	1518	168590	188475	981
7:00	49.98	186917	5229	14665	5577	29429	1919	130813	1551	166675	189183	966
7:15	49.92	188806	5259	14377	8729	29606	1915	129548	1527	165700	190961	960
7:30	49.98	190634	5369	14237	12238	29409	1924	128146	1563	164159	192886	974
7:45	50.03	191611	5366	14526	15889	28832	1933	125580	1606	161196	193732	974
8:00	50.03	191950	5370	15023	19121	28138	1915	123089	1618	157806	194274	973
8:15	50.03	193939	5363	15061	23757	27982	1845	121061	1629	155121	196698	991
8:30	50.03	195732	5353	14924	26883	28085	1837	119321	1650	153925	198053	981
8:45	50.03	197628	5342	15026	30577	27530	1839	118112	1688	152025	200114	978
9:00	49.98	199004	5343	15325	32841	27072	1824	117651	1665	150838	201721	934
9:15	49.83	201882	5330	15572	36029	27171	1835	117025	1705	150281	204667	964
9:30	49.88	202731	5318	15598	37870	27236	1840	116036	1651	149263	205549	948
9:45	49.89	203501	5310	15743	39795	26912	1830	114805	1701	147963	206096	997
10:00	49.89	204336	5311	15578	40688	26596	1833	115098	1685	148070	206789	956
10:15	49.89	204930	5301	15305	42436	26099	1820	114433	1721	147189	207115	948
10:30	49.99	206773	5283	15175	44505	25646	1718	114898	1722	147093	208947	918
10:45	50.09	206968	5306	14975	46451	25450	1860	113628	1732	145542	209402	908
11:00	50.19	207704	5305	14842	48326	24417	1947	113485	1770	144536	210092	891
11:15	50.14	206701	5308	14803	49399	24242	1927	112288	1748	142499	209715	916
11:30	50.04	206828	5300	14998	50888	24215	1933	110327	1721	140942	209382	883
11:45	50.04	207518	5300	15092	51768	24235	1935	109807	1791	140658	209928	875
12:00	50.04	207141	5298	15325	50165	24610	1848	109006	1755	141651	208007	867
12:15	49.99	206595	5300	15317	49735	24153	1922	109226	1745	141543	207398	893
12:30	49.99	205984	5287	15702	50166	24469	1742	108325	1723	140116	207414	933
12:45	49.94	204636	5292	15793	49056	24576	1659	107472	1758	139787	205606	961
13:00	49.94	203115	5286	16087	47727	24572	1656	108225	1720	139301	205273	914
13:15	49.94	200895	5311	16593	49226	24536	1511	105262	1747	135076	204186	846
13:30	49.89	201484	5313	17035	47071	25002	1661	106959	1681	137378	204722	885
13:45	49.99	202617	5311	16992	47147	25007	1503	107809	1680	138478	205449	888
14:00	49.99	203546	5288	16782	45811	25962	1679	109094	1661	140953	206277	919
14:15	49.99	204284	5293	16783	44160	26761	1700	110173	1655	143341	206525	1505
14:30	50.04	205406	5306	17128	42309	27940	1521	111487	1666	145969	207357	1488
14:45	50.04	205642	5303	16927	42575	29409	1676	110455	1688	146140	208033	1513
15:00	50.09	206098	5317	16844	41324	30214	1521	111190	1717	147930	208127	1510
15:15	50.04	205531	5315	17195	39916	30171	1531	112372	1719	148420	208219	1562
15:30	50.04	205017	5335	17491	37154	31174	1469	113169	1655	150372	207447	1546
15:45	49.94	205098	5323	17785	32567	31668	1508	116877	1662	154746	207390	1589
16:00	49.84	203585	5327	18558	28183	31400	1519	119521	1624	156844	206132	1558
16:15	49.94	203243	5337	18888	25218	31054	1530	122295	1592	159137	205914	1534
16:30	49.99	202568	5341	19033	21572	31594	1513	124016	1572	161963	204641	1544
16:45	49.84	201680	5350	19215	19507	31754	1520	124913	1554	162958	203813	1414
17:00	49.89	201487	5338	18629	16993	32160	1488	127280	1562	165865	203450	1563
17:15	49.99	200956	5355	17981	15456	32566	1520	128597	1548	167519	203023	1591
17:30	50.04	200407	5357	17695	13675	32604	1541	130011	1613	169037	202496	1538
17:45	50.09	198841	5344	17407	11180	32659	1770	131396	1535	170254	201291	1544
18:00	50.09	197634	5359	17472	8091	32780	2078	132746	1547	172071	200073	1575
18:15	50.04	198572	5359	17333	5752	33552	2437	134393	1516	175487	200342	1684
18:30	49.89	200964	5348	17057	3552	34157	2631	138234	1496	180355	202475	1691
18:45	49.99	203078	5359	16414	1828	35060	3106	140770	1521	184836	204058	1733
19:00	50.04	205894	5363	16671	750	35839	3585	143214	1536	188473	206958	1755
19:15	49.84	207768	5363	17050	347	36949	3649	143894	1598	190371	208850	1563
19:30	50.04	209263	5376	17165	266	37008	3663	145522	1628	191832	210628	1650
19:45	49.94	210544	5383	17257	255	37184	3797	146143	1625	193032	211644	1784
20:00	50.04	209785	5390	16979	247	36949	3831	145947	1632	192559	210975	1808
20:15	49.99	208872	5387	16784	0	37264	3828	145528	1607	192088	210398	1167
20:30	49.89	208472	5388	16508	0	37334	3868	145330	1575	191964	210003	1111
20:45	49.89	208034	5386	16106	0	37400	3879	145037	1624	191528	209432	1360
21:00	49.94	207327	5380	15193	0	37423	3813	145119	1602	192134	208530	1420
21:15	49.99	207281	5402	15082	0	37135	3850	145366	1639	192199	208474	1549
21:30	49.99	206615	5407	14595	0	36817	3842	145511	1614	192020	207786	1569
21:45	49.99	205836	5392	14721	0	36557	3828	145083	1592	191115	207173	1570
22:00	49.99	205310	5411	14332	0	36301	3820	144822	1628	190978	206314	1605
22:15	49.84	205954	5402	15054	0	36002	3846	144971	1670	190900	20694	