



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 26.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 25.03.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 25-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 25.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 26-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60489	71044	53335	25440	2969	213277
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1219	1662	1410	532	54	4876
Hydro Gen (MU)	135	54	90	23	11	313
Wind Gen (MU)	29	85	34	-	-	148
Solar Gen (MU)*	212.28	145.26	141.35	4.25	1.41	505
Energy Shortage (MU)	0.16	0.00	0.00	0.00	0.17	0.33
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	60489	73970	66761	25914	3478	221847
Time Of Maximum Demand Met	19:00	10:42	11:50	18:47	18:04	10:42

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.025	0.00	0.12	3.12	3.24	83.71	13.05

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8360	0	165.3	61.3	-1.1	310	0.00
	Haryana	7461	0	160.0	106.7	-0.9	374	0.00
	Rajasthan	14456	0	282.9	67.5	-7.1	241	0.00
	Delhi	4011	0	82.2	75.9	-1.5	180	0.00
	UP	21058	0	387.1	93.5	-0.2	347	0.16
	Uttarakhand	2103	0	42.4	32.7	0.3	92	0.00
	HP	1762	0	33.3	21.8	-1.2	610	0.00
	J&K(UT) & Ladakh(UT)	2831	0	57.5	49.3	-0.2	297	0.00
	Chandigarh	208	0	3.8	3.8	0.0	12	0.00
WR	Railways_NR ISTS	195	0	4.2	3.9	0.3	27	0.00
	Chhattisgarh	6345	0	143.4	78.1	-0.2	305	0.00
	Gujarat	23895	0	479.4	189.7	-3.4	647	0.00
	MP	14094	0	275.0	158.9	-2.0	553	0.00
	Maharashtra	30040	0	679.5	254.3	0.7	1551	0.00
	Goa	756	0	16.2	13.6	2.1	81	0.00
	DNHDDPDCL	1377	0	31.5	31.4	0.1	41	0.00
	AMNSIL	767	0	17.7	10.5	0.1	263	0.00
	BALCO	534	0	12.7	12.7	0.0	157	0.00
SR	RIL JAMNAGAR	255	0	6.1	6.2	-0.1	0	0.00
	Andhra Pradesh	12504	0	246.2	72.8	-0.8	467	0.00
	Telangana	15744	0	319.0	176.0	-1.4	1025	0.00
	Karnataka	16585	0	323.7	133.6	-1.9	495	0.00
	Kerala	4868	0	98.9	75.7	1.1	677	0.00
	Tamil Nadu	19143	0	412.0	262.5	-2.1	519	0.00
	Puducherry	459	0	10.5	9.8	0.1	62	0.00
ER	Bihar	5580	0	111.7	102.9	2.1	292	0.00
	DVC	3315	0	70.7	-40.5	0.3	238	0.00
	Jharkhand	2063	0	40.6	31.1	-0.6	115	0.00
	Odisha	5462	0	110.6	27.0	-1.1	556	0.00
	West Bengal	9546	0	194.4	48.7	-1.3	250	0.00
	Sikkim	106	0	1.7	1.8	-0.1	14	0.00
	Railways_ER ISTS	16	0	1.8	0.2	1.6	5	0.00
NER	Arunachal Pradesh	166	0	2.9	3.0	-0.2	30	0.00
	Assam	2201	0	32.9	26.1	0.7	301	0.00
	Manipur	207	0	2.9	2.7	0.2	61	0.17
	Meghalaya	343	0	5.9	5.1	-0.2	90	0.00
	Mizoram	151	0	1.9	1.9	-0.3	17	0.00
	Nagaland	169	0	2.5	2.5	0.0	27	0.00
	Tripura	278	0	4.8	4.5	0.1	67	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.6	-12.3	-23.9	-24.3
Day Peak (MW)	-458.0	-855.6	-1022.0	-1373.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	59.9	-219.0	285.0	-139.1	13.2	0.0
Actual(MU)	42.4	-207.7	295.3	-151.1	13.0	-8.0
O/D/U/D(MU)	-17.5	11.3	10.3	-11.9	-0.2	-8.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3523	9670	3998	3958	586	21735	49
State Sector	7639	6862	6036	1672	139	22348	51
Total	11162	16532	10034	5630	725	44083	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	805	1634	754	748	10	3951	75
Lignite	31	14	42	0	0	87	2
Hydro	135	54	90	23	11	313	6
Nuclear	26	50	76	0	0	151	3
Gas, Naptha & Diesel	10	21	7	0	23	61	1
RES (Wind, Solar, Biomass & Others)	262	232	214	6	1	716	14
Total	1268	2004	1183	778	46	5279	100

Share of RES in total generation (%)	20.69	11.56	18.07	0.82	3.11	13.56
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.34	16.76	32.11	3.79	26.74	22.36

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.033
Based on State Max Demands	1.079

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	221847	10:42	17
Non-Solar hr	211016	19:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 26-Mar-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	852	789	0.0	5.1	-5.1
4	765 kV	SASARAM-FATEHPUR	1	273	436	0.0	5.3	-5.3
5	765 kV	GAYA-BALIA	1	27	429	0.0	6.0	-6.0
6	400 kV	PUSAULI-VARANASI	1	0	155	0.0	2.5	-2.5
7	400 kV	PUSAULI -ALLAHABAD	1	63	26	0.3	0.0	0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	605	378	0.8	0.0	0.8
9	400 kV	PATNA-BALIA	2	243	703	0.0	8.7	-8.7
10	400 kV	NAUBATPUR-BALIA	2	110	225	0.0	2.1	-2.1
11	400 kV	BIHARSHARIFF-BALIA	2	477	129	2.4	0.0	2.4
12	400 kV	MOTIHARI-GORAKHPUR	2	187	346	0.0	3.4	-3.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	2.0	-2.0
14	220 kV	SAHUPURI-KARAMNASA	1	3	53	0.0	0.5	-0.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						4.1	37.9	-33.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	655	818	0.0	0.5	-0.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	505	1344	0.0	12.0	-12.0
3	765 kV	JHARSUGUDA-DURG	2	0	1389	0.0	27.1	-27.1
4	400 kV	JHARSUGUDA-RAIGARH	4	0	687	0.0	12.8	-12.8
5	400 kV	RANCHI-SIPAT	2	99	429	0.0	4.7	-4.7
6	220 kV	BUDHIPADAR-RAIGARH	1	0	146	0.0	2.2	-2.2
7	220 kV	BUDHIPADAR-KORBA	2	85	127	0.0	1.1	-1.1
ER-WR						0.0	60.4	-60.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	731	0.0	17.5	-17.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1014	0.0	24.2	-24.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	3224	0.0	59.6	-59.6
4	400 kV	TALCHER-I/C	2	401	109	7.8	0.0	7.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	101.3	-101.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	286	88	3.1	0.2	2.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	474	49	5.4	0.0	5.4
3	220 kV	ALIPURDUAR-SALAKATI	2	108	0	1.7	0.0	1.7
ER-NER						10.1	0.2	10.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	956	0	23.1	0.0	23.1
NER-NR						23.1	0.0	23.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2019	0.0	48.7	-48.7
2	HVDC	VINDHYACHAL B/B	-	49	2	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2372	0.0	40.7	-40.7
4	765 kV	GWALIOR-AGRA	2	679	1061	2.8	5.2	-2.4
5	765 kV	GWALIOR-PHAGI	2	1176	1135	4.7	11.1	-6.3
6	765 kV	JABALPUR-ORAI	2	543	520	1.3	0.0	1.3
7	765 kV	GWALIOR-ORAI	1	748	0	11.5	0.0	11.5
8	765 kV	SATNA-ORAI	1	0	877	0.0	15.6	-15.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1983	0	35.8	0.0	35.8
10	765 kV	VINDHYACHAL-VARANASI	2	29	1970	0.0	25.4	-25.4
11	400 kV	ZERDA-KANKROLI	1	462	0	7.9	0.0	7.9
12	400 kV	ZERDA -BHINMAL	1	319	0	5.5	0.0	5.5
13	400 kV	VINDHYACHAL -RIHAND	1	968	0	21.4	0.0	21.4
14	400 kV	RAPP-SHUJALPUR	2	765	0	9.0	0.0	9.0
15	400 kV	NEEMUCH-Chittorgarh	2	754	0	8.5	0.0	8.5
16	220 kV	BHANPURA-RANPUR	1	0	145	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	128	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	101	0	1.1	0.0	1.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						112.3	150.7	-38.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	23.0	-23.0
2	HVDC	RAIGARH-PUGALUR	2	0	6624	0.0	131.2	-131.2
3	765 kV	SOLAPUR-RAICHUR	2	1034	1215	2.0	8.7	-6.7
4	765 kV	WARDHA-NIZAMABAD	2	0	3079	0.0	46.7	-46.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2798	0.0	45.5	-45.5
6	400 kV	KOLHAPUR-KUDGI	2	1526	0	21.4	0.0	21.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	111	2.2	0.0	2.2
WR-SR						25.6	255.0	-229.4
INTERNATIONAL EXCHANGES								
State	Region		Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	441	-6	176	4.23	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-341	55	-176	-4.22	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-391	-129	-273	-6.56	
	NER		132kV GELEPHU-SALAKATI	-18	5	-5	-0.13	
	NER		132kV MOTANGA-RANGIA	15	-7	5	0.13	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-71	0	-50	-1.21	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-71	0	-39	-0.93	
	ER		NEPAL IMPORT (FROM BIHAR)	-280	0	-152	-3.66	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-576	0	-273	-6.54	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-942	-889	-931	-22.35	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1373	-543	-1010	-24.25	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-80	0	-64	-1.54	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	6.66	0.00	0.00	0.90	0.00	0.00	7.95
Nepal	3.80	0.00	3.90	0.00	0.00	2.87	0.00	0.00	10.57
Bangladesh	23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.90	0.39	10.56	0.00	0.00	3.77	0.00	0.00	41.62

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.70
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.70

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.70	-0.39	-6.66	0.00	0.00	-0.90	0.00	0.00	-7.25
Nepal	-3.80	0.00	-3.90	0.00	0.00	-2.87	0.00	0.00	-10.57
Bangladesh	-23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.20	-0.39	-10.56	0.00	0.00	-3.77	0.00	0.00	-40.92

