



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 26.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 25.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 25-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 25.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 26-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61197	66386	46865	23687	2665	200800
Peak Shortage (MW)	0	60	0	0	0	60
Energy Met (MU)	1305	1572	1174	485	51	4588
Hydro Gen (MU)	127	39	80	19	15	280
Wind Gen (MU)	3	60	51	-	-	113
Solar Gen (MU)*	177.86	163.13	156.16	3.01	0.84	501
Energy Shortage (MU)	0.00	0.06	0.00	0.00	0.00	0.06
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71269	79705	60849	24520	2475	236036
Time Of Maximum Demand Met	10:25	10:36	11:39	17:56	17:23	10:24

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.07	3.38	3.45	81.56	14.99

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9115	0	164.1	78.9	-2.1	311	0.00
	Haryana	9027	0	169.2	115.6	-1.2	272	0.00
	Rajasthan	18592	0	341.9	125.7	-2.2	863	0.00
	Delhi	4846	0	81.4	75.9	-0.5	384	0.00
	UP	21904	0	388.8	62.8	0.1	789	0.00
	Uttarakhand	2599	0	47.5	36.1	1.1	158	0.00
	HP	2143	0	39.1	32.2	-0.7	90	0.00
	J&K(UT) & Ladakh(UT)	3139	0	65.5	60.5	-0.7	242	0.00
	Chandigarh	235	0	4.2	4.2	0.0	22	0.00
	Railways_NR ISTS	162	0	3.5	3.6	-0.1	13	0.00
WR	Chhattisgarh	5248	0	108.1	39.0	0.6	308	0.00
	Gujarat	24167	0	452.8	187.1	-3.5	788	0.00
	MP	19789	0	353.8	242.1	-4.3	685	0.06
	Maharashtra	28034	0	574.9	178.9	-7.1	859	0.00
	Goa	621	0	12.3	9.7	2.1	43	0.00
	DNHDDPDCL	1353	0	30.9	30.7	0.2	52	0.00
	AMNSIL	891	0	19.5	12.6	-0.2	265	0.00
	BALCO	599	0	14.2	14.3	-0.1	22	0.00
	RIL JAMNAGAR	265	0	5.9	5.9	0	0	0.00
	Andhra Pradesh	11409	0	210.5	60.7	-1.2	743	0.00
SR	Telangana	14311	0	251.7	97.1	-1.3	545	0.00
	Karnataka	16819	0	290.3	119.4	-1.1	731	0.00
	Kerala	4009	0	71.6	54.7	-0.5	277	0.00
	Tamil Nadu	16514	0	341.2	212.4	-3.1	854	0.00
	Puducherry	412	0	8.9	8.3	-0.1	21	0.00
	Bihar	6047	0	109.8	105.1	-2.0	246	0.00
ER	DVC	3242	0	68.5	-33.6	-1.1	363	0.00
	Jharkhand	2224	0	41.6	33.1	-0.7	237	0.00
	Odisha	5463	0	109.6	23.3	-2.2	432	0.00
	West Bengal	7462	0	153.9	18.7	-0.9	469	0.00
	Sikkim	108	0	1.8	1.9	-0.1	6	0.00
	Railways_ER ISTS	14	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	179	0	3.3	3.2	-0.1	17	0.00
	Assam	1575	0	28.8	22.7	0.1	171	0.00
	Manipur	249	0	3.6	3.9	-0.2	20	0.00
	Meghalaya	319	0	6.2	5.4	-0.1	51	0.00
	Mizoram	126	0	2.0	1.9	-0.2	11	0.00
	Nagaland	153	0	2.6	2.6	-0.1	8	0.00
	Tripura	226	0	4.9	4.7	0.4	38	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-12.4	-1.0	-13.0	-24.9
Day Peak (MW)	-969.6	-406.1	-905.2	-1398.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	199.3	-181.8	168.6	-192.7	6.6	0.0
Actual(MU)	198.4	-178.7	155.1	-193.0	5.7	-12.4
O/D/U/D(MU)	-0.9	3.1	-13.4	-0.3	-0.9	-12.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5741	13128	6148	4185	64	29266	51
State Sector	7984	10086	7884	2327	205	28485	49
Total	13725	23213	14032	6512	269	57751	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	807	1505	654	741	13	3719	74
Lignite	26	16	58	0	0	100	2
Hydro	127	39	80	19	15	280	6
Nuclear	34	53	47	0	0	133	3
Gas, Naptha & Diesel	12	39	10	0	22	83	2
RES (Wind, Solar, Biomass & Others)	207	226	252	7	1	693	14
Total	1212	1878	1100	767	51	5008	100

Share of RES in total generation (%)	17.04	12.04	22.92	0.90	1.65	13.83
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.31	16.94	34.39	3.41	30.58	22.08

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.032

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	236036	10:24	0
Non-Solar hr	212452	17:55	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)

Date of Reporting: 26-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	84	1386	0.0	19.1	-19.1
4	765 kV	SASARAM-FAITEHPUR	1	16	677	0.0	9.5	-9.5
5	765 kV	GAYA-BALIA	1	0	765	0.0	11.4	-11.4
6	400 kV	PUSAULI-VARANASI	1	40	81	0.0	0.7	-0.7
7	400 kV	PUSAULI-ALLAHABAD	1	0	139	0.0	1.6	-1.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	245	691	0.0	6.5	-6.5
9	400 kV	PATNA-BALIA	2	0	1096	0.0	18.5	-18.5
10	400 kV	NAUBATPUR-BALIA	2	0	510	0.0	5.4	-5.4
11	400 kV	BIHARSHARIFF-BALIA	2	250	348	0.0	2.6	-2.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	594	0.0	9.7	-9.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	35	517	0.0	6.9	-6.9
14	220 kV	SAHUPURI-KARMANASA	1	0	48	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	29	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	20	0.0	0.8	-0.8
ER-NR						0.8	96.5	-95.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1127	0.0	12.2	-12.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	562	1342	0.0	14.3	-14.3
3	765 kV	JHARSUGUDA-DURG	2	0	1348	0.0	24.8	-24.8
4	400 kV	JHARSUGUDA-RAIGARH	4	190	242	0.0	0.7	-0.7
5	400 kV	RANCHI-SIPAT	2	137	385	0.0	3.9	-3.9
6	400 kV	JEYPORE-JACDALPUR	2	343	393	1.9	0.0	1.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	149	0.0	2.3	-2.3
8	220 kV	BUDHIPADAR-KORBA	2	77	92	0.0	0.3	-0.3
ER-WR						1.9	58.4	-56.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	523	0.0	6.8	-6.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1621	0.0	41.2	-41.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2895	0.0	48.4	-48.4
4	400 kV	TALCHER/IC	2	332	423	1.4	0.0	1.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	96.4	-96.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	442	136	2.1	0.6	1.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	763	60	5.7	0.0	5.7
3	220 kV	ALIPURDUAR-SALAKATI	2	149	0	1.4	0.0	1.4
ER-NER						9.2	0.6	8.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	660	0	16.4	0.0	16.4
NER-NR						16.4	0.0	16.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3525	0.0	61.0	-61.0
2	HVDC	VINDHYACHAL B/B	-	421	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1461	0.0	26.9	-26.9
4	765 kV	GWALIOR-AGRA	2	467	1850	0.6	18.3	-17.7
5	765 kV	GWALIOR-PHAGI	2	401	2201	0.3	31.7	-31.5
6	765 kV	JABALPUR-ORAI	2	37	1006	0.0	23.9	-23.9
7	765 kV	GWALIOR-ORAI	1	1029	0	17.0	0.0	17.0
8	765 kV	SATNA-ORAI	1	0	1110	0.0	30.3	-30.3
9	765 kV	BANASKANTHA-CHITTORGARH	1	2243	0	26.7	0.0	26.7
10	765 kV	VINDHYACHAL-VARANASI	2	265	2287	0.0	26.5	-26.5
11	400 kV	ZERDA-KANKROLI	1	340	0	4.6	0.0	4.6
12	400 kV	ZERDA -BHINMAL	1	234	0	3.2	0.0	3.2
13	400 kV	VINDHYACHAL -RIHAND	1	956	0	0.0	21.2	-21.2
14	400 kV	RAPP-SHUJALPUR	2	612	271	3.8	1.3	2.5
15	400 kV	NEEMUCH-Chittorgarh	2	654	409	4.0	2.0	2.0
16	220 kV	BHANPURA-RANPUR	1	0	135	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	167	4	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	128	16	1.0	0.0	0.9
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						68.7	237.0	-168.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	21.5	-21.5
2	HVDC	RAIGARH-PUGALUR	2	0	3006	0.0	50.0	-50.0
3	765 kV	SOLAPUR-RAICHUR	2	913	1382	4.1	8.3	-4.2
4	765 kV	WARDHA-NIZAMABAD	2	173	1943	0.1	19.6	-19.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2585	0.0	34.4	-34.4
6	400 kV	KOLHAPUR-KUDGI	2	1382	0	18.8	0.0	18.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	114	2.1	0.0	2.1
WR-SR						25.2	133.9	-108.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-247	23	-123	-2.96
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	345	-216	0	0.01
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-356	-268	-314	-7.53
	NER	132kV GELEPHU-SALAKATI	-69	0	-57	-1.36
	NER	132kV MOTANGA-RANGIA	-30	0	-24	-0.57
NEPAL	NR	NEPAL IMPORT (FROM UP)	-66	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-66	0	-24	-0.58
	ER	NEPAL IMPORT (FROM BIHAR)	-34	0	-4	-0.09
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	176	-202	-15	-0.36
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-828	-351	-457	-10.96
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1398	-818	-1036	-24.86
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-100	0	-85	-2.04

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 26-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.31	12.79	0.00	0.00	0.00	0.00	0.00	13.10	
Nepal	0.52	0.00	0.35	0.00	0.00	0.00	1.03	0.00	0.00	1.90
Bangladesh	11.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	11.77	0.31	13.14	0.00	0.00	0.00	1.03	0.00	0.00	26.25

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	1.23	0.00	0.00	1.23
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	1.23	0.00	0.00	1.23

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-12.79	0.00	0.00	0.00	0.00	0.00	-13.10
Nepal	-0.52	0.00	-0.35	0.00	0.00	0.20	0.00	0.00	-0.67
Bangladesh	-11.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-11.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.77	-0.31	-13.14	0.00	0.00	0.20	0.00	0.00	-25.02

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.05	156588	4861	7397	0	7324	2606	134798	3622	149191	160608	-1563
0:15	50.05	156290	4853	7256	0	7240	2617	134880	3626	149034	160472	-1696
0:30	50.00	155816	4863	7172	0	7167	2620	134369	3633	148644	159824	-1680
0:45	50.00	155264	4856	7055	0	7333	2630	133860	3631	148209	159365	-1652
1:00	50.00	154920	4867	6873	0	7286	2633	133719	3606	148047	158984	-1658
1:15	50.00	153804	4858	6811	0	7184	2626	133003	3605	146993	158087	-1660
1:30	50.00	153692	4867	6807	0	7357	2618	132595	3636	146885	157880	-1691
1:45	50.05	152902	4867	6723	0	7042	2624	132299	3615	146179	157170	-1671
2:00	50.05	151946	4867	6650	0	6954	2624	131417	3574	145296	156086	-1677
2:15	50.00	151809	4865	6637	0	6542	2655	131400	3645	145172	155744	-1532
2:30	50.00	151830	4863	6658	0	6740	2649	131255	3603	145172	155768	-1451
2:45	49.95	151765	4885	6552	0	6801	2652	130978	3599	145213	155467	-1328
3:00	50.00	151618	4859	6450	0	6788	2652	130913	3592	145168	155254	-1298
3:15	50.00	151653	4884	6404	0	6520	2652	131032	3645	145249	155137	-1261
3:30	49.95	151703	4862	6257	0	6142	2647	131970	3542	145446	155420	-1219
3:45	49.95	152015	4873	6087	0	6028	2655	132313	3616	145928	155572	-1141
4:00	50.00	152564	4863	6042	0	6001	2666	132908	3593	146522	156073	-1129
4:15	50.00	154928	4869	5925	0	6570	2720	134832	3594	149003	158510	-1150
4:30	50.00	156550	4883	5872	0	6722	2725	136441	3611	150678	160254	-1124
4:45	50.00	157975	4866	5881	0	6688	2730	138033	3598	152094	161796	-1109
5:00	50.10	160481	4868	5924	41	6967	2723	139897	3688	154516	164108	-1188
5:15	50.00	163914	4862	5966	42	7394	2817	143283	3616	157906	167980	-1239
5:30	50.05	167513	4875	5897	36	7941	3046	146073	3646	161580	171514	-1255
5:45	50.05	171488	4875	5774	47	9380	3620	148168	3704	165667	175568	-1308
6:00	50.15	174653	4865	5734	75	11034	4023	148925	3740	168844	178396	-984
6:15	50.00	178626	4859	5707	118	12330	4258	151074	3700	172801	182046	-695
6:30	50.05	185098	4855	5561	198	15968	4281	153914	3693	179339	188470	-453
6:45	49.95	190729	4871	5523	269	18514	4265	156510	3673	184937	193625	-519
7:00	50.05	195098	4867	5577	700	19776	4657	158820	3677	188821	198074	-520
7:15	50.05	199983	4872	5487	1639	21864	4531	161165	3721	192857	203279	-467
7:30	50.00	204543	4861	5466	3377	22267	5466	162508	3645	195700	207590	-474
7:45	50.05	207806	4861	5523	6329	22656	4882	162535	3658	195954	210444	-489
8:00	50.05	209577	4867	5505	11160	20720	3835	162536	3719	192912	212342	-508
8:15	50.00	214277	4853	5355	17309	20720	3115	162047	3745	191613	217144	-531
8:30	50.05	217948	4872	5184	23988	18652	2764	161212	3763	188776	220435	-514
8:45	50.05	221053	4863	4940	31081	16087	2648	159946	3712	185032	223277	-500
9:00	50.05	223632	4864	4658	38519	13573	2635	157770	3723	180455	225742	-646
9:15	50.00	228623	4853	4510	45001	11500	2583	158795	3721	179112	230963	-626
9:30	50.00	232560	4880	4365	50523	10690	2574	157459	3689	177672	234180	-675
9:45	50.00	234592	4862	4282	55067	10025	2615	155730	3656	175243	236237	-739
10:00	50.05	234698	4864	4240	58241	9260	2605	153307	3711	172217	236228	-752
10:15	50.05	235503	4843	4179	61720	8447	2569	151907	3638	169604	237303	-778
10:30	50.00	235808	4863	3990	64448	7889	2569	150286	3639	167370	237684	-1194
10:45	50.00	234444	4869	3810	66430	7740	2568	148250	3624	164204	237291	-1754
11:00	50.05	233335	4851	3655	68029	7332	2573	145468	3707	161651	235615	-1784
11:15	50.00	231104	4847	3342	68801	6757	2585	143339	3652	158961	233323	-1860
11:30	50.00	229960	4841	3118	70236	6718	2589	141122	3651	156606	232275	-1826
11:45	49.95	228202	4845	2874	70928	6971	2606	138706	3595	154400	230525	-1811
12:00	50.00	226520	4848	2699	71973	6856	2599	135931	3748	151848	228654	-1825
12:15	49.95	223865	4846	2555	72242	6244	2593	133864	3624	149068	225968	-1742
12:30	49.95	221931	4843	2399	72181	6494	2593	132041	3640	147351	224191	-1760
12:45	49.90	219274	4849	2346	71687	6619	2566	130353	3735	145241	222155	-1776
13:00	49.95	215661	4842	2297	70986	6603	2569	128396	3669	142378	219362	-1819
13:15	50.00	212128	4840	2272	70782	6533	2564	126627	3700	139074	217318	-1800
13:30	50.00	210840	4840	2216	69416	6472	2559	127157	3746	139208	216406	-1766
13:45	49.95	210801	4837	2194	67932	6394	2569	128955	3629	140675	216510	-1815
14:00	50.00	209875	4839	2149	67454	6385	2547	129198	3644	140272	216216	-1788
14:15	49.90	209611	4830	1471	63616	5448	2568	129995	3645	144524	211573	-1693
14:30	49.95	210767	4852	1322	62728	5940	2562	131897	3660	146717	212961	-1784
14:45	49.95	211571	4846	1258	59981	6356	2632	135026	3538	150332	213637	-1627
15:00	50.05	212122	4827	1135	56941	7097	2626	138052	3552	150446	214230	-1681
15:15	49.90	209444	4823	1108	52970	7119	2894	139339	3540	155366	211793	-1614
15:30	49.90	210276	4820	1054	48735	7815	3214	143483	3593	160487	212714	-1635
15:45	49.95	211362	4820	1057	44582	9040	3640	147009	3500	165723	213648	-1609
16:00	50.05	211126	4837	1095	40055	10624	4065	149313	3490	169976	213479	-1571
16:15	50.00	207894	4839	1083	34477	10790	4153	151204	3570	172334	210116	-1173
16:30	50.06	207980	4835	1149	27479	12830	4360	156021	3535	179352	210209	-787
16:45	50.05	208075	4831	1360	21040	15402	4515	159724	3516	185675	210388	-659
17:00	50.11	207652	4838	1476	14815	19626	4670	161526	3486	191361	210437	-628
17:15	50.05	205951	4824	1670	9574	21679	4931	162663	3457	194707	208798	-484
17:30	50.05	208212	4849	1856	5822	25323	5908	164018	3468	200534	211244	-522
17:45	49.90	211227	4837	2143	2497	28431	6172	166336	3482	206587	213898	-484
18:00	50.06	211922	4832	2545	1149	29190	6194	167506	3482	208228	214898	-507
18:15	50.01	211692	4843	2670	344	29949	5548	167440	3427	208678	214221	-548
18:30	50.06	211787	4910	3112	302	29668	5225	167628	3515	208373	214360	-547
18:45	50.06	210451	4985	3541	201	29447	4361	166914	3490	206709	212939	-549
19:00	50.06	207238	4997	3864	219	27785	3432	165889	3478	203155	209664	-524
19:15	50.06	203514	5023	4179	220	25135	3151	164643	3498	199115	205849	-547
19:30	50.01	200880	5033	4443	0	23368	3028	164013	3462	196437	203347	-556
19:45	50.01	196919	5037	4572	0	20908	2923	162786	3529	192347	199755	-612
20:00	50.01	193374	5048	4656	0	18047	2862	161801	3526	188718	195940	-597
20:15	50.06	190002	5060	4888	0	15817	2704	160478	3539	185114	192486	-593
20:30	50.01	187045	5057	5098	0	14120	2665	159099	3574	181947	189613	-599
20:45	50.01	184657	5052	5283	0	12629	2626	158117	3535	179374	187242	-549
21:00	49.96	181546	5070	5449	0	11433	2608	155964	3591	176097	184115	-537
21:15	49.96	178550	5097	5572	0	11007	2620	153274	3580	172978	181150	-523
21:30	50.01	175591	5125	5541	0	10863	2606	150992	3623	170050	178750	-827
21:45	50.03	173164	5138	5493	0	10368	2625	149290	3585	167671	176499	-1181
22:00	50.08	169553	5143	5398	0	8745	2579	147467	3614	164155	172946	-1153
22:15	50.03	169115	5152	5494	0	8849	2595	147030	3599	163621	172719	-1168
22:30	50.03	167320	5154	5657	0	8002	2616	145745	3655	161663	170829	-1162
22:45	50.03	165718	5177</									