



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 24.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 23.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 23-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 24-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	62085	67478	49172	22929	2755	204419
Peak Shortage (MW)	0	184	0	1148	0	1332
Energy Met (MU)	1301	1566	1189	470	51	4577
Hydro Gen (MU)	129	59	91	20	15	314
Wind Gen (MU)	12	101	46	-	-	159
Solar Gen (MU)*	128.70	162.50	156.60	2.34	0.92	451
Energy Shortage (MU)	0.67	0.91	0.00	1.21	0.00	2.79
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69802	78495	60510	23867	2949	231308
Time Of Maximum Demand Met	10:54	09:53	11:05	18:01	17:17	09:44

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.00	0.52	4.27	4.79	80.62	14.59

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8887	0	163.2	70.7	1.1	442	0.00
	Haryana	9062	0	172.6	113.0	-1.9	493	0.00
	Rajasthan	17432	0	336.0	125.1	4.0	1287	0.00
	Delhi	4974	0	84.9	79.0	-0.1	386	0.00
	UP	21302	0	389.8	81.1	-2.6	407	0.00
	Uttarakhand	2462	0	45.4	35.1	0.4	116	0.67
	HP	2150	0	38.2	30.9	-0.5	103	0.00
	J&K(UT) & Ladakh(UT)	3128	0	63.1	60.9	-3.9	322	0.00
	Chandigarh	255	0	4.2	4.1	0.1	15	0.00
	Railways_NR ISTS	214	0	3.8	3.6	0.3	65	0.00
WR	Chhattisgarh	5296	0	104.6	38.4	-1.7	340	0.00
	Gujarat	23671	0	448.8	168.3	-6.9	564	0.00
	MP	18865	0	345.7	240.5	0.0	1060	0.91
	Maharashtra	28578	0	582.3	168.5	-8.4	749	0.00
	Goa	704	0	13.8	11.1	2.1	59	0.00
	DNHDDPDCL	1361	0	31.1	31.1	0.0	35	0.00
	AMNSIL	867	0	19.6	12.7	-0.1	289	0.00
	BALCO	597	0	14.2	14.3	-0.1	28	0.00
	RIL JAMNAGAR	243	0	5.4	5.6	-0.2	0	0.00
	Andhra Pradesh	11091	0	212.5	53.7	1.8	741	0.00
SR	Telangana	14226	0	246.5	105.0	-1.0	606	0.00
	Karnataka	16931	0	296.6	125.5	-0.4	562	0.00
	Kerala	4375	0	78.6	56.3	0.0	366	0.00
	Tamil Nadu	17112	0	345.7	214.7	-2.4	935	0.00
	Puducherry	419	0	8.8	8.3	-0.1	28	0.00
	Bihar	6061	502	107.6	103.7	-1.9	547	0.70
ER	DVC	3143	0	67.6	-32.0	-0.5	381	0.00
	Jharkhand	2226	152	39.8	29.3	0.1	526	0.51
	Odisha	4974	0	95.0	11.2	-2.0	387	0.00
	West Bengal	7877	0	158.1	24.3	-1.1	238	0.00
	Sikkim	111	0	1.8	1.8	0.1	33	0.00
	Railways_ER ISTS	22	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	187	0	3.3	3.2	0.0	96	0.00
	Assam	1630	0	28.5	22.8	0.1	746	0.00
	Manipur	261	0	3.9	3.8	0.1	101	0.00
	Meghalaya	351	0	6.5	5.4	0.0	209	0.00
	Mizoram	159	0	2.3	2.1	-0.1	80	0.00
	Nagaland	159	0	2.8	2.7	0.0	83	0.00
	Tripura	239	0	4.1	5.0	0.0	177	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-11.5	-1.3	-22.8	-22.1
Day Peak (MW)	-902.2	-380.7	-1043.7	-1333.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	237.0	-239.6	183.8	-190.8	9.6	0.0
Actual(MU)	246.7	-254.5	174.6	-192.0	6.0	-19.2
O/D/U/D(MU)	9.7	-15.0	-9.2	-1.2	-3.6	-19.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6741	13777	8338	4185	80	33122	50
State Sector	8119	12520	8934	3227	205	33004	50
Total	14860	26297	17272	7412	285	66126	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	801	1499	645	729	14	3688	74
Lignite	25	17	62	0	0	105	2
Hydro	129	59	91	20	15	314	6
Nuclear	32	53	46	0	0	131	3
Gas, Naptha & Diesel	13	47	11	0	22	94	2
RES (Wind, Solar, Biomass & Others)	167	267	238	6	1	679	14
Total	1167	1943	1094	755	51	5010	100

Share of RES in total generation (%)	14.29	13.76	21.76	0.79	1.79	13.55
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.06	19.52	34.36	3.44	30.46	22.44

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.044

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	231308	9:44	255
Non-Solar hr	211973	17:57	292

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 24-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.3	-2.3
3	765 kV	GAYA-VARANASI	2	298	1364	0.0	20.3	-20.3
4	765 kV	SASARAM-FATEHPUR	1	151	580	0.0	7.4	-7.4
5	765 kV	GAYA-BALIA	1	0	837	0.0	13.3	-13.3
6	400 kV	PUSAULI-VARANASI	1	23	112	0.0	1.0	-1.0
7	400 kV	PUSAULI-ALLAHABAD	1	17	113	0.0	1.4	-1.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	451	631	0.0	5.2	-5.2
9	400 kV	PATNA-BALIA	2	0	1060	0.0	18.2	-18.2
10	400 kV	NAUBATPUR-BALIA	2	0	498	0.0	5.5	-5.5
11	400 kV	BIHARSHARIEF-BALIA	2	322	243	0.0	1.4	-1.4
12	400 kV	MOTIHARI-GORAKHPUR	2	22	585	0.0	8.1	-8.1
13	400 kV	BIHARSARIEF-SAHUPURI	2	113	508	0.0	6.6	-6.6
14	220 kV	SAHUPURI-KARMANASA	1	10	48	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	28	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	20	0.0	0.0	0.0
						ER-NR	0.6	91.6
								-91.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1438	0.0	15.6	-15.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	770	1171	0.0	4.2	-4.2
3	765 kV	JHARSUGUDA-DURG	2	0	1268	0.0	22.5	-22.5
4	400 kV	JHARSUGUDA-RAIGARH	4	352	99	2.7	0.0	2.7
5	400 kV	RANCHI-SIPAT	2	201	345	0.0	1.6	-1.6
6	400 kV	JEYPORE-JAGDALPUR	2	251	301	0.7	0.0	0.7
7	220 kV	BUDHIPADAR-RAIGARH	1	0	134	0.0	1.8	-1.8
8	220 kV	BUDHIPADAR-KORBA	2	74	51	0.2	0.0	0.2
						ER-WR	3.6	45.7
								-42.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	115	0.0	2.7	-2.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1619	0.0	45.6	-45.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	3178	0.0	50.0	-50.0
4	400 kV	TALCHER-I/C	2	436	697	0.0	2.5	-2.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	0.0	98.3
								-98.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	144	370	0.3	4.5	-4.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	307	439	0.0	3.6	-3.6
3	220 kV	ALIPURDUAR-SALAKATI	2	75	38	0.1	0.0	0.1
						ER-NER	0.4	8.0
								-7.6
Import/Export of <null> (With <null>)								
No Records Found								
						NER-NR	0.0	0.0
								0.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4019	0.0	54.6	-54.6
2	HVDC	VINDHYACHAL B/B	-	489	0	9.8	0.0	9.8
3	HVDC	MUNDRA-MOHINDERGARH	2	0	985	0.0	20.7	-20.7
4	765 kV	GWALIOR-AGRA	2	524	1827	0.5	21.4	-20.9
5	765 kV	GWALIOR-PHAGI	2	584	2082	0.8	28.5	-27.7
6	765 kV	JABALPUR-ORAI	2	0	1072	0.0	31.1	-31.1
7	765 kV	GWALIOR-ORAI	1	1136	0	19.5	0.0	19.5
8	765 kV	SATNA-ORAI	1	0	1250	0.0	23.6	-23.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1632	1032	7.9	4.0	3.9
10	765 kV	VINDHYACHAL-VARANASI	2	170	2661	0.0	34.4	-34.4
11	400 kV	ZERDA-KANKROLI	1	251	154	1.5	0.4	1.1
12	400 kV	ZERDA-BHINMAL	1	173	106	1.0	0.3	0.7
13	400 kV	VINDHYACHAL -RIHAND	1	479	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	525	357	2.2	2.2	0.1
15	400 kV	NEEMUCH-Chittorgarh	2	607	371	2.9	1.9	1.0
16	220 kV	BHANPURA-RANPUR	1	0	131	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	167	2	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	131	17	0.8	0.0	0.8
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	58.7	226.7
								-168.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	20.9	-20.9
2	HVDC	RAIGARH-PUGALUR	2	0	4519	0.0	53.3	-53.3
3	765 kV	SOLAPUR-RAICHUR	2	1401	2173	3.3	13.9	-10.6
4	765 kV	WARDHA-NIZAMABAD	2	298	2755	0.1	26.2	-26.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3129	0.0	38.2	-38.2
6	400 kV	KOLHAPUR-KUDGI	2	1495	0	18.4	0.0	18.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.2	0.0	2.2
						WR-SR	24.0	152.4
								-128.4
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-216	31	-108	-2.60		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	322	-248	1	0.02		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-346	-249	-301	-7.22		
	NER	132kV GELEPHU-SALAKATI	-57	0	-48	-1.14		
	NER	132kV MOTANGA-RANGIA	-49	0	-22	-0.53		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-66	0	-16	-0.38		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-66	0	-20	-0.47		
	ER	NEPAL IMPORT (FROM BIHAR)	-34	0	-8	-0.19		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-236	141	-10	-0.24		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-918	-637	-848	-20.35		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1333	-814	-920	-22.08		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-119	0	-100	-2.40		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 24-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	12.65	0.00	0.00	0.00	0.00	0.00	12.96
Nepal	0.54	0.00	0.00	0.00	0.00	1.28	0.00	0.00	1.82
Bangladesh	21.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.13
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.67	0.31	12.65	0.00	0.00	1.28	0.00	0.00	35.91

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	1.31	0.00	0.00	1.31
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.05	0.00	0.00	0.00	0.00	0.00	1.31	0.00	0.00	1.36

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.05	-0.31	-12.65	0.00	0.00	0.00	0.00	0.00	-12.91
Nepal	-0.54	0.00	0.00	0.00	0.00	0.02	0.00	0.00	-0.52
Bangladesh	-21.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.13
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.62	-0.31	-12.65	0.00	0.00	0.02	0.00	0.00	-34.56

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.00	145378	4825	9434	0	6327	2410	131925	3539	144944	158460	-1501
0:15	50.00	153846	4841	9258	0	6212	2397	131599	3494	144588	157801	-1679
0:30	50.00	152869	4849	9276	0	6173	2377	130209	3526	143593	156410	-1639
0:45	49.95	152728	4847	9265	0	6143	2421	130096	3566	143463	156338	-1621
1:00	50.00	151591	4843	9200	0	6142	2408	129463	3553	142391	155609	-1600
1:15	49.94	150842	4833	8975	0	6541	2390	128390	3517	141867	154646	-1578
1:30	49.94	149926	4839	8736	0	6555	2361	127754	3561	141190	153806	-1563
1:45	49.95	148826	4845	8662	0	6514	2349	126709	3527	140164	152606	-1569
2:00	49.95	147526	4842	8486	0	6508	2347	125691	3555	139040	151429	-1570
2:15	49.95	147644	4843	8380	0	6504	2367	125975	3551	139264	151620	-1561
2:30	50.00	147417	4862	8273	0	6492	2354	125774	3529	139144	151284	-1563
2:45	50.00	147381	4847	8137	0	6279	2362	126046	3597	139244	151268	-1509
3:00	50.00	147137	4837	8015	0	6272	2345	126050	3530	139122	151049	-1458
3:15	50.00	147598	4850	7882	0	5974	2432	126960	3557	139716	151655	-1434
3:30	49.95	148024	4843	7744	0	5614	2409	128121	3502	140280	152233	-1470
3:45	50.00	148638	4857	7646	0	5730	2404	128551	3540	140992	152728	-1502
4:00	50.05	149467	4848	7651	0	5713	2426	129487	3557	141816	153682	-1492
4:15	49.95	151976	4840	7557	0	5889	2629	131793	3631	144419	156339	-1433
4:30	50.00	153557	4858	7482	0	6046	2709	133330	3540	146075	157965	-1368
4:45	50.00	155318	4829	7362	0	6289	2737	134856	3528	147956	159601	-1402
5:00	50.05	156568	4847	7311	40	7023	2665	135623	3539	149217	161048	-1438
5:15	49.90	161854	4838	7183	41	8245	2803	139778	3574	154630	166462	-1480
5:30	50.05	166293	4828	7188	25	9214	3004	143334	3572	159080	171165	-1533
5:45	50.05	171165	4853	7117	48	10245	3303	146871	3652	164000	176089	-1490
6:00	50.10	174950	4849	7083	60	10667	3614	149889	3641	167807	179803	-1141
6:15	50.00	180809	4841	7065	91	13450	3830	152263	3617	173653	185157	-661
6:30	50.05	187963	4848	7036	145	17433	4165	155486	3637	180782	192750	-650
6:45	49.90	194254	4848	7120	267	20390	4906	157711	3609	186867	198851	-723
7:00	50.05	199943	4853	6872	727	23998	4243	160254	3632	192344	204579	-771
7:15	49.95	204632	4947	6834	1663	25880	5417	161490	3627	196135	209698	-824
7:30	50.00	208544	4857	6841	3226	26862	5571	162179	3619	198477	213155	-872
7:45	50.05	211187	4848	6886	5759	26877	5528	161985	3629	198542	215512	-934
8:00	50.05	211553	4852	7108	9114	24472	5556	161330	3604	195331	216036	-941
8:15	50.05	214295	4848	7022	13126	22934	5579	161207	3680	194147	218396	-957
8:30	50.05	216498	4853	6850	17678	21680	5346	160130	3676	191970	220213	-926
8:45	50.05	219788	4868	6576	22070	19792	4657	161643	3690	191142	223296	-984
9:00	50.05	222121	4852	6130	26955	17855	4622	161084	3748	189036	225246	-1083
9:15	49.90	226531	4854	5631	31636	17146	4683	162020	3735	189264	229705	-1073
9:30	50.00	229372	4846	5089	35959	16507	5066	161395	3691	188324	232553	-1079
9:45	50.00	231098	4844	4730	40324	15035	4845	160859	3684	186044	234321	-1149
10:00	50.00	229908	4843	4446	44530	12724	3650	160080	3602	180932	233875	-1719
10:15	50.05	230525	4835	4264	47868	10825	3495	159125	3611	178393	234023	-2038
10:30	50.05	230361	4780	4194	51046	8885	3186	158138	3621	175121	233850	-2089
10:45	50.05	230541	4838	4161	54347	8129	2879	156192	3570	172033	234116	-2296
11:00	50.05	229320	4842	4244	57274	7742	2724	152268	3647	167802	232741	-2306
11:15	49.84	228035	4834	4257	59269	7037	2438	149821	3676	164509	231332	-2280
11:30	49.94	227345	4841	4368	61911	6819	2573	146524	3596	161066	230632	-2299
11:45	49.99	227105	4832	4469	64867	6287	2559	143597	3607	157769	230218	-2277
12:00	50.10	224527	4833	4493	67365	6068	2448	138834	3686	152669	227727	-2270
12:15	49.99	221803	4822	4513	68576	5965	2521	134921	3634	148714	224952	-2210
12:30	50.00	219838	4816	4532	69164	6039	2381	132063	3610	146142	222605	-2194
12:45	49.99	218818	4832	4580	69519	6038	2416	129983	3655	144719	221023	-2190
13:00	50.05	215624	4805	4672	69167	5914	2431	128262	3722	141785	218973	-2219
13:15	49.94	211874	4815	4694	68843	5941	2400	125420	3688	138337	215801	-2089
13:30	50.00	210860	4819	4661	68126	5914	2418	125797	3661	138073	215396	-2062
13:45	49.94	211284	4817	4611	66783	5591	2402	127056	3718	139890	214978	-2100
14:00	49.99	211379	4799	4439	65572	5807	2403	127958	3695	141368	214673	-2095
14:15	49.94	211591	4806	4365	64169	5991	2362	129391	3725	143057	214809	-2131
14:30	49.94	212980	4810	4261	61999	6425	2378	132309	3738	146720	215920	-2128
14:45	49.94	214118	4803	4213	59350	6516	2365	136025	3711	150555	216983	-2109
15:00	49.94	214885	4803	4086	56598	7077	2388	138990	3737	154201	217679	-2133
15:15	49.94	212310	4799	3965	53623	6943	2485	139975	3766	154722	215556	-2132
15:30	49.94	213259	4795	3928	50371	7662	2716	143203	3745	158960	216420	-2142
15:45	50.00	212529	4799	3788	45100	8646	3196	146340	3718	163641	215587	-2071
16:00	50.05	211884	4804	3726	39486	9864	3543	150130	3698	168672	215251	-1996
16:15	49.95	209415	4792	3616	33430	10668	4039	151817	3698	172369	212060	-1565
16:30	49.89	208601	4798	3645	26767	13001	4361	156505	3705	178189	212782	-1294
16:45	49.95	209192	4806	3711	19983	16268	4745	159294	3745	185498	212552	-975
17:00	50.05	210732	4802	3500	13491	20352	4907	157487	3594	193741	208133	-978
17:15	49.99	207823	4801	3952	8458	23571	5338	161774	3702	195413	211596	-994
17:30	50.04	208574	4809	4138	4512	27365	6153	162219	3690	199924	212886	-994
17:45	49.94	210546	4797	4444	2113	30110	6509	163256	3681	203989	214910	-1040
18:00	49.94	211772	4801	4978	694	31038	6554	163447	3627	206100	215139	-992
18:15	49.94	211338	4808	5400	383	31091	6445	163139	3625	205555	214891	-1057
18:30	49.94	211175	4813	5865	351	31046	6630	162458	3664	204959	214827	-1053
18:45	50.04	210785	4810	6254	226	31241	5937	162119	3650	204305	214237	-1056
19:00	49.94	209209	4811	6664	163	30052	5033	162085	3672	202382	212480	-1025
19:15	49.94	207343	4815	7099	145	28525	3870	162227	3629	200099	210310	-1046
19:30	49.99	204364	4819	7562	0	25780	3748	161822	3679	196802	207410	-1042
19:45	50.04	201661	4819	7947	0	24107	3686	160719	3649	193714	204927	-1034
20:00	50.09	196854	4826	8242	0	21202	3526	159395	3649	188612	200840	-994
20:15	50.04	194153	4832	8488	0	18096	3337	158800	3673	185665	197226	-973
20:30	50.04	191014	4823	8730	0	16292	3234	157554	3648	182284	194281	-1053
20:45	49.99	188158	4820	8875	0	14647	3220	156221	3647	179283	191430	-1009
21:00	50.04	185264	4830	8913	0	14131	3120	153864	3639	176351	188497	-1016
21:15	50.04	182045	4830	8778	0	12718	2999	152212	3669	173267	185206	-980
21:30	49.99	178488	4814	8652	0	11596	2964	150310	3692	169836	182028	-1325
21:45	50.04	175817	4818	8563	0	10944	2857	149059	3679	167254	179920	-1699
22:00	50.09	171460	4821	8517	0	10051	2731	145762	3688	162943	175570	-1681
22:15	49.94	171023	4839	8709	0	9340	2754	145967	3693	162314	175302	-1704
22:30	49.94	169250	4827	8585	0	9201	2651	144386	3638	160665	173288	-1689
22:45	49.94</											