



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 21.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 20-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58744	62778	45083	0	2707	169312
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1277	1525	1153	431	49	4436
Hydro Gen (MU)	114	60	101	16	13	305
Wind Gen (MU)	47	150	13	-	-	210
Solar Gen (MU)*	120.76	85.61	97.07	2.24	1.01	307
Energy Shortage (MU)	1.35	0.00	0.00	0.00	0.00	1.35
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68769	77436	57381	21420	2830	224169
Time Of Maximum Demand Met	10:21	09:58	11:46	17:55	17:21	10:30

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.35	2.25	5.93	8.52	75.91	15.58

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9394	0	166.8	68.6	-0.5	389	0.00
	Haryana	9260	0	168.8	111.9	-0.8	895	0.00
	Rajasthan	18338	0	336.6	101.5	-3.4	647	0.00
	Delhi	4906	0	83.1	74.2	0.0	506	0.00
	UP	20004	0	362.2	111.8	-5.2	365	0.00
	Uttarakhand	2463	0	46.0	35.3	0.1	64	0.00
	HP	2250	0	41.3	34.6	-0.9	172	0.00
	J&K(UT) & Ladakh(UT)	3088	0	63.4	57.9	0.4	773	1.35
	Chandigarh	257	0	4.8	4.6	0.2	50	0.00
WR	Railways_NR ISTS	198	0	3.9	3.7	0.2	31	0.00
	Chhattisgarh	5089	0	103.4	42.5	0.6	231	0.00
	Gujarat	22444	0	419.3	170.4	-6.0	664	0.00
	MP	18888	0	349.3	221.4	-2.1	797	0.00
	Maharashtra	28294	0	578.0	211.4	0.4	649	0.00
	Goa	680	0	13.5	12.8	0.1	43	0.00
	DNHDDPDCL	1288	0	29.7	29.9	-0.2	42	0.00
	AMNSIL	762	0	17.1	9.4	-0.2	240	0.00
	BALCO	528	0	12.6	12.7	-0.1	10	0.00
SR	RIL JAMNAGAR	100	0	2.4	2.3	0.1	0	0.00
	Andhra Pradesh	9729	0	194.8	58.9	0.4	555	0.00
	Telangana	14009	0	267.9	165.0	0.4	741	0.00
	Karnataka	15312	0	269.1	80.2	1.7	1070	0.00
	Kerala	4331	0	86.5	62.5	1.9	418	0.00
	Tamil Nadu	15785	0	325.7	202.9	2.0	956	0.00
	Puducherry	448	0	9.2	9.1	0.0	40	0.00
ER	Bihar	4970	0	93.2	82.2	-2.4	0	0.00
	DVC	3293	0	69.0	-46.5	1.4	0	0.00
	Jharkhand	1961	0	38.2	28.3	-1.7	0	0.00
	Odisha	4592	0	85.7	19.2	-2.1	0	0.00
	West Bengal	6969	0	143.4	3.7	-1.3	0	0.00
	Sikkim	119	0	1.8	2.0	-0.1	0	0.00
	Railways_ER ISTS	8	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	168	0	2.3	2.9	-0.7	75	0.00
	Assam	1564	0	27.3	20.5	0.2	281	0.00
	Manipur	242	0	3.7	3.7	0.1	36	0.00
	Meghalaya	375	0	6.5	5.7	-0.2	128	0.00
	Mizoram	147	0	2.1	1.7	-0.2	15	0.00
	Nagaland	164	0	2.6	2.5	0.0	40	0.00
	Tripura	231	0	4.4	3.2	0.3	41	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-8.4	-5.0	-20.0	-11.9
Day Peak (MW)	-474.0	-331.0	-992.0	-669.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	229.0	-294.6	249.0	-186.0	2.5	0.0
Actual(MU)	224.1	-321.0	274.1	-235.2	-0.1	-58.1
O/D/U/D(MU)	-4.9	-26.4	25.1	-49.3	-2.6	-58.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5204	6592	8978	4363	268	25405	46
State Sector	6033	13828	7374	1869	191	29294	54
Total	11237	20420	16352	6232	459	54699	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	761	1564	599	678	15	3617	75
Lignite	30	10	36	0	0	76	2
Hydro	114	60	101	16	13	305	6
Nuclear	31	67	70	0	0	169	4
Gas, Naptha & Diesel	14	32	5	0	24	75	2
RES (Wind, Solar, Biomass & Others)	193	240	141	5	1	580	12
Total	1143	1975	952	699	53	4823	100

Share of RES in total generation (%)	16.88	12.16	14.81	0.70	1.89	12.03
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.62	18.62	32.75	3.04	26.66	21.85

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.037

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	224169	10:30	2
Non-Solar hr	202569	18:25	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 21-Dec-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	6.2	-6.2
3	765 kV	GAYA-VARANASI	2	0	886	0.0	12.3	-12.3
4	765 kV	SASARAM-FATEHPUR	1	0	520	0.0	8.1	-8.1
5	765 kV	GAYA-BALIA	1	0	640	0.0	11.4	-11.4
6	400 kV	PUSAULI-VARANASI	1	0	194	0.0	3.9	-3.9
7	400 kV	PUSAULI -ALLAHABAD	1	0	116	0.0	2.1	-2.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	607	0.0	9.5	-9.5
9	400 kV	PATNA-BALIA	2	0	732	0.0	13.1	-13.1
10	400 kV	NAUBATPUR-BALIA	2	0	243	0.0	4.1	-4.1
11	400 kV	BIHARSHARIFF-BALIA	2	0	236	0.0	6.3	-6.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	474	0.0	8.6	-8.6
13	400 kV	BIHARSHARIFF-VARANASI	2	0	340	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	64	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	86.5	-85.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	446	587	0.0	6.5	-6.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	254	988	0.0	4.7	-4.7
3	765 kV	JHARSUGUDA-DURG	2	0	668	0.0	12.7	-12.7
4	400 kV	JHARSUGUDA-RAIGARH	4	0	723	0.0	9.4	-9.4
5	400 kV	RANCHI-SIPAT	2	0	2	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	108	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	95	77	0.3	0.0	0.3
ER-WR						0.3	34.9	-34.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	534	0.0	12.7	-12.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1984	0.0	79.2	-79.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	3335	0.0	58.0	-58.0
4	400 kV	TALCHER-I/C	2	601	678	0.0	46.5	-46.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	149.8	-149.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	274	142	2.4	0.6	1.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	466	109	4.3	0.0	4.3
3	220 kV	ALIPURDUAR-SALAKATI	2	93	18	0.9	0.0	0.9
ER-NER						7.6	0.6	7.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	7.6	0.0	7.6
NER-NR						7.6	0.0	7.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2030	0.0	33.8	-33.8
2	HVDC	VINDHYACHAL B/B	-	0	55	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	31.3	-31.3
4	765 kV	GWALIOR-AGRA	2	0	1716	0.0	23.4	-23.4
5	765 kV	GWALIOR-PHAGI	2	0	1327	0.0	17.9	-17.9
6	765 kV	JABALPUR-ORAI	2	0	782	0.0	23.4	-23.4
7	765 kV	GWALIOR-ORAI	1	796	0	13.3	0.0	13.3
8	765 kV	SATNA-ORAI	1	0	986	0.0	19.1	-19.1
9	765 kV	BANASKANTHA-CHITORGARH	2	311	1013	0.6	9.3	-8.7
10	765 kV	VINDHYACHAL-VARANASI	2	0	2216	0.0	36.9	-36.9
11	400 kV	ZERDA-KANKROLI	1	141	119	0.8	0.6	0.2
12	400 kV	ZERDA -BHINMAL	1	97	83	0.6	0.5	0.1
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	486	118	3.9	0.3	3.6
15	400 kV	NEEMUCH-Chittorgarh	2	580	88	5.4	0.1	5.3
16	220 kV	BHANPURA-RANPUR	1	0	206	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	156	0	1.8	0.0	1.8
19	220 kV	MALANPUR-AURAIYA	1	118	5	0.6	0.0	0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						48.7	203.2	-154.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1006	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	3506	0.0	84.1	-84.1
3	765 kV	SOLAPUR-RAICHUR	2	65	2256	0.0	18.7	-18.7
4	765 kV	WARDHA-NIZAMABAD	2	0	3084	0.0	43.7	-43.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3182	0.0	47.5	-47.5
6	400 kV	KOLHAPUR-KUDGI	2	1147	69	15.1	0.0	15.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.2	0.0	2.2
WR-SR						17.2	217.9	-200.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	234	-148	-21	-0.49	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-217	154	-54	-1.30	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-244	-131	-199	-4.78	
	NER	132kV GELEPHU-SALAKATI	-35	2	-71	-1.71	
	NER	132kV MOTANGA-RANGIA	-37	9	-6	-0.14	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-47	-1.12	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-331	4	-163	-3.91	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-928	-542	-793	-19.03	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-669	-397	-494	-11.85	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-43	-1.02	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	7.67	0.00	0.00	0.39	0.00	0.00	8.06
Nepal	0.38	0.00	2.42	0.00	0.00	1.61	0.00	0.00	4.41
Bangladesh	19.72	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.72
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.10	0.00	10.09	0.00	0.00	2.00	0.00	0.00	32.19

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.60	0.00	-7.67	0.00	0.00	-0.39	0.00	0.00	-7.46
Nepal	-0.38	0.00	-2.42	0.00	0.00	-1.61	0.00	0.00	-4.41
Bangladesh	-19.72	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-19.72
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.50	0.00	-10.09	0.00	0.00	-2.00	0.00	0.00	-31.59

Date of Reporting: 21-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I)=(A)-(G)-(H)	(J)=(B)+(C)+(D)+(E)+(F)+(G)+(H)	(K)
0:00	50.09	152088	6608	11651	0	8024	2319	127262	2933	140437	158797	-1635
0:15	49.99	152012	6595	11606	0	7796	2314	126879	2935	140406	158125	-1481
0:30	49.99	150176	6594	11644	0	7968	2312	124733	2977	138532	156228	-1378
0:45	49.99	149391	6598	11677	0	7567	2316	124453	2968	137714	155579	-1409
1:00	49.99	148263	6607	11630	0	6931	2309	123933	3057	136633	154467	-1385
1:15	50.04	146922	6606	11503	-2	6682	2317	123004	2997	135421	153107	-1391
1:30	50.04	146258	6609	11512	-2	6634	2305	122509	3004	134748	152571	-1370
1:45	50.04	145497	6604	11595	-2	6652	2314	121542	3043	133904	151748	-1398
2:00	50.04	144473	6601	11683	-3	6498	2298	120868	2944	132793	150889	-1360
2:15	49.99	144168	6609	11685	-2	6293	2314	120792	2964	132485	150655	-1374
2:30	49.99	143703	6609	11608	-2	6202	2314	120835	2979	132097	150545	-1414
2:45	49.94	143843	6604	11450	-2	6139	2318	121459	2962	132395	150930	-1320
3:00	49.99	143550	6614	11445	-2	6342	2317	120745	2969	132107	150430	-1237
3:15	49.99	143456	6628	11473	-2	6256	2303	120861	2953	131985	150472	-1225
3:30	49.99	143614	6630	11451	-2	6468	2319	120675	3003	132165	150544	-1197
3:45	49.99	144153	6612	11468	-2	6481	2340	121280	2987	132687	151166	-1217
4:00	50.04	144108	6610	11425	-3	6665	2357	121361	2973	132686	151388	-1219
4:15	49.99	146841	6620	11471	-1	7034	2375	123229	3005	135371	153733	-1217
4:30	49.99	148793	6624	11482	-2	7593	2414	124681	2930	137313	155722	-1222
4:45	50.04	151053	6624	11601	-1	8138	2558	126280	2977	139453	158177	-1237
5:00	49.99	153430	6624	11523	-1	8711	2648	127890	2964	141908	160359	-1266
5:15	49.89	158047	6609	11262	3	9521	2703	132125	2990	146782	165213	-1288
5:30	49.94	162583	6600	11194	4	10562	2778	135595	2980	151385	169713	-1192
5:45	49.99	167128	6607	11099	4	12198	2876	138214	3037	156025	174035	-1112
6:00	50.09	170426	6613	10982	-6	13750	3047	139653	3008	159450	177047	-1081
6:15	49.99	175760	6627	10803	242	15120	3453	143402	2994	164715	182641	-1072
6:30	50.04	182786	6629	10767	292	16744	3562	149006	2969	171727	189969	-1090
6:45	50.04	189090	6616	10768	348	19155	3633	152818	3027	177974	196365	-1065
7:00	49.99	194695	6629	10657	587	20685	3855	156309	3011	183451	201733	-1071
7:15	49.89	200072	6623	10582	1222	23039	4017	158720	2918	188268	207121	-1078
7:30	49.94	204064	6612	10497	2286	24215	4321	160034	2977	191281	210942	-1028
7:45	50.04	207385	6636	10452	3963	25253	4296	160201	3003	192970	213804	-972
8:00	50.01	208859	6630	10647	6441	24364	4029	159952	2958	191771	215021	-947
8:15	50.01	210870	6639	10502	9637	22419	4247	160267	2979	190731	216690	-913
8:30	49.96	212695	6635	10305	13481	20198	4006	160767	3014	188909	218406	-923
8:45	50.01	214387	6631	9865	17202	18589	3903	160743	3046	187320	219979	-829
9:00	50.01	216477	6641	9210	21347	18183	3897	159946	3046	185920	222270	-921
9:15	49.76	219657	6617	8518	25049	17089	3669	161514	3088	186090	225544	-936
9:30	49.81	221498	6612	7513	28353	16276	3868	161792	3073	185632	227487	-930
9:45	49.81	222975	6590	6900	31371	14924	4093	162089	3046	184704	229013	-1017
10:00	49.96	223666	6602	6667	34113	13710	4081	161128	3061	182886	229362	-1151
10:15	49.91	224130	6584	6551	36941	12726	4072	160083	3080	180638	230037	-1180
10:30	50.06	224169	6603	6601	39622	11377	4061	159222	3103	177946	230589	-1386
10:45	49.96	223508	6618	6742	41444	10822	4091	154407	3047	175322	227171	-1693
11:00	50.01	223056	6608	6970	42629	10463	4089	156131	3061	173457	229951	-1925
11:15	50.03	222381	6617	7296	44121	9435	3894	154559	3044	170964	228966	-1910
11:30	50.03	220565	6633	7532	45362	9076	3535	152468	3088	167671	227694	-1915
11:45	50.03	220636	6627	7928	46532	8946	2735	151578	3123	166176	227469	-1969
12:00	50.08	218552	6615	8239	47005	8726	2735	149057	3098	163308	225475	-1962
12:15	50.03	216251	6612	8457	47173	8853	2746	146265	3102	160621	223208	-2000
12:30	50.03	214896	6608	8508	47418	8722	2662	144957	3100	158970	221975	-1987
12:45	49.93	212920	6618	8384	46890	8462	2523	143850	3098	157646	219825	-1922
13:00	50.03	210723	6591	8444	45853	8707	2377	142144	3040	156426	217156	-1945
13:15	49.97	208137	6600	8440	45382	8379	2294	139909	3129	154315	214133	-1916
13:30	50.02	203711	6595	8517	43951	8065	2304	137901	3092	151243	210425	-1955
13:45	49.98	203788	6608	8530	43471	8246	2312	138202	3072	151787	210441	-1991
14:00	49.98	203110	6599	8505	42115	8425	2314	138764	3041	152490	209763	-1952
14:15	49.98	202632	6593	8473	40370	8666	2307	139930	3081	153789	209420	-1888
14:30	49.93	203525	6588	8459	38503	9100	2296	141672	3076	156563	209694	-1746
14:45	49.93	202875	6602	8384	35869	9570	2306	143269	3075	158622	209075	-1706
15:00	49.98	202923	6584	8246	32749	10706	2528	146027	3020	161928	209860	-1781
15:15	49.93	202163	6593	8243	30055	10586	2631	147436	2992	163865	208536	-1764
15:30	49.98	202022	6602	8319	27124	10944	2583	149762	3115	166579	208449	-1783
15:45	49.98	200245	6587	8296	23668	11383	3040	150647	3101	168281	206722	-1777
16:00	50.03	198216	6587	8121	20643	11672	3141	151588	3109	169452	204861	-1793
16:15	50.03	196348	6613	8199	17328	11765	3354	151910	3068	170821	202237	-1617
16:30	49.98	197160	6591	8007	13402	13716	3435	154926	3132	175751	203209	-1480
16:45	49.98	198127	6581	7827	10216	15945	3676	156511	3074	180084	203830	-1210
17:00	50.03	198594	6596	7788	6921	18530	3764	157640	3083	183885	204322	-1264
17:15	49.98	197975	6573	7584	4346	19938	3715	158162	3060	186045	203378	-1067
17:30	50.03	198517	6586	7300	2366	21558	3693	159491	3031	188851	204025	-1194
17:45	49.88	199802	6582	7093	1097	23517	3742	160449	3017	191612	205497	-1164
18:00	50.03	200181	6585	7208	548	24159	3711	160757	3008	192425	205976	-1220
18:15	49.98	201834	6594	7609	381	25087	3702	160828	3074	193844	207275	-1140
18:30	49.98	202324	6590	8107	291	25245	3698	160929	3049	193926	207909	-1154
18:45	50.03	201425	6597	8625	299	24387	3591	160219	3051	192501	206769	-1202
19:00	50.08	198525	6597	9241	294	23279	3580	157946	3073	188990	204010	-1063
19:15	50.08	195522	6612	9775	291	22467	3076	155756	2991	185456	200968	-1203
19:30	50.03	192764	6597	10306	289	20325	2856	154532	2985	182169	197890	-1091
19:45	50.03	189255	6600	10771	287	18085	2796	153274	3000	178197	194813	-1022
20:00	50.08	184902	6602	11044	288	16289	2608	150474	2961	173570	190266	-1013
20:15	49.98	181640	6601	11401	55	15098	2491	148158	3003	170184	186807	-982
20:30	50.03	179592	6596	11678	28	14464	2465	146479	3024	167886	184734	-1001
20:45	50.03	177371	6603	11866	-3	13901	2470	144747	3003	165508	182587	-983
21:00	49.98	174399	6594	11948	-4	13117	2463	142650	2939	162455	179707	-1030
21:15	49.98	172166	6599	12138	-5	12941	2505	140894	2984	160033	178056	-1336
21:30	49.98	169391	6606	12222	-2	12714	2479	138710	3054	157171	175783	-1641
21:45	49.98	167289	6616	12241	-10	12120	2516	137087	2985	155058	173555	-1655
22:00	50.08	163760	6606	12218	-6	11741	2505	134418	2954	151548	170436	-1595
22:15	49.93	163358	6606	12079	-1	11174	2509	134375	2965	151280	169707	-1595
22:30	49.93	162267	6611	12092	-2	11052						