



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.06.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.06.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-जून-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.06.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-Jun-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	83498	65470	48153	30173	3473	230767
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1944	1570	1162	687	78	5440
Hydro Gen (MU)	386	39	96	41	28	590
Wind Gen (MU)	48	191	212	-	-	451
Solar Gen (MU)*	223.36	151.50	120.01	4.00	1.01	500
Energy Shortage (MU)	0.73	0.00	0.00	0.00	0.00	0.73
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	87313	70148	53847	32463	3638	242345
Time Of Maximum Demand Met	22:21	15:23	14:56	23:10	19:15	14:52

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.039	0.00	0.00	3.21	3.21	71.84	24.95

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	16440	0	342.2	199.9	-0.7	745	0.00
	Haryana	12560	0	262.2	205.2	1.1	587	0.73
	Rajasthan	17139	0	374.9	143.3	-5.4	333	0.00
	Delhi	7369	0	150.7	138.9	-4.3	274	0.00
	UP	30265	0	643.2	282.2	-0.3	499	0.00
	Uttarakhand	2852	0	60.8	28.9	1.3	252	0.00
	HP	1866	0	40.6	5.3	-0.3	205	0.00
	J&K(UT) & Ladakh(UT)	2677	0	56.6	32.3	-1.5	235	0.00
	Chandigarh	427	0	8.4	8.5	-0.1	29	0.00
	Railways NR ISTS	209	0	4.3	3.9	0.4	60	0.00
WR	Chhattisgarh	5377	0	116.0	60.4	-2.0	270	0.00
	Gujarat	25110	0	513.8	178.0	-3.1	792	0.00
	MP	12843	0	285.1	144.2	-2.6	404	0.00
	Maharashtra	25282	0	572.2	177.6	-2.0	958	0.00
	Goa	639	0	15.6	13.2	1.9	51	0.00
	DNHDDPDCL	1361	0	31.8	31.8	0.0	253	0.00
	AMNSIL	888	0	18.9	8.7	0.5	289	0.00
	BALCO	534	0	12.7	12.7	0.0	9	0.00
	RIL JAMNAGAR	200	0	3.7	3.8	-0.1	0	0.00
	Andhra Pradesh	11282	0	239.3	71.9	0.1	636	0.00
SR	Telangana	9559	0	201.7	87.3	0.6	689	0.00
	Karnataka	12609	0	242.1	80.7	-1.8	638	0.00
	Kerala	4310	0	88.9	44.6	0.5	366	0.00
	Tamil Nadu	17620	0	379.5	137.9	-3.5	1369	0.00
	Puducherry	453	0	10.2	10.2	-0.5	33	0.00
	DVC	3178	0	70.8	-43.3	0.0	308	0.00
ER	Jharkhand	2332	0	49.9	41.5	0.2	160	0.00
	Odisha	6078	0	125.2	51.8	-1.5	792	0.00
	West Bengal	12889	0	264.0	121.0	-1.9	224	0.00
	Sikkim	91	0	1.6	1.3	0.3	42	0.00
	Railways ER ISTS	3	0	0.2	0.2	0.0	2	0.00
	Arunachal Pradesh	189	0	4.1	3.2	0.7	14	0.00
NER	Assam	2469	0	51.7	43.0	1.0	135	0.00
	Manipur	210	0	3.5	3.2	0.3	13	0.00
	Meghalaya	285	0	5.5	0.5	0.0	43	0.00
	Mizoram	101	0	3.0	0.8	1.0	12	0.00
	Nagaland	172	0	3.5	3.2	0.2	25	0.00
	Tripura	311	0	6.8	5.4	0.7	37	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	16.2	-4.3	-23.3	-14.3
Day Peak (MW)	869.0	407.3	-994.0	-767.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	430.5	-398.6	-39.7	-6.6	14.4	0.0
Actual(MU)	393.7	-393.8	-31.4	15.2	16.0	-0.3
OD/UD(MU)	-36.9	4.8	8.3	21.8	1.6	-0.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	1836	7004	4232	3235	331	16637	45
State Sector	4399	7162	6941	1564	199	20265	55
Total	6235	14165	11173	4799	530	36902	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	1103	1583	669	713	12	4081	67
Lignite	22	17	48	0	0	87	1
Hydro	386	39	96	41	28	590	10
Nuclear	37	39	66	0	0	142	2
Gas, Naptha & Diesel	49	83	9	0	24	162	3
RES (Wind, Solar, Biomass & Others)	280	344	360	6	1	991	16
Total	1877	2104	1248	759	63	6052	100

Share of RES in total generation (%)	14.94	16.33	28.86	0.74	0.02	16.37
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.48	20.03	41.83	6.13	45.57	28.46

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.020
Based on State Max Demands	1.058

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	242345	14:52	0
Non-Solar hr	235188	22:18	390

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 11-Jun-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.2	-7.2
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	1387	348	6.6	0.0	6.6
4	765 kV	SASARAM-FATEHPUR	1	688	115	4.0	0.0	4.0
5	765 kV	GAYA-BALIA	1	0	776	0.0	10.9	-10.9
6	400 kV	PUSAULI-VARANASI	1	0	264	0.0	3.2	-3.2
7	400 kV	PUSAULI-ALLAHABAD	1	172	4	0.9	0.0	0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	591	369	1.2	0.0	1.2
9	400 kV	PATNA-BALIA	2	438	483	0.0	3.5	-3.5
10	400 kV	NAUBATPUR-BALIA	2	210	298	0.0	0.0	0.0
11	400 kV	BIHARSHARIFF-BALIA	2	771	0	9.3	0.0	9.3
12	400 kV	MOTIHARI-GORAKHPUR	2	381	375	0.0	1.1	-1.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	475	180	1.4	0.0	1.4
14	220 kV	SAHUPURI-KARAMNASHA	1	0	114	0.0	0.0	0.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.8	0.0	0.8
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	24.2	-28.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	484	1430	0.0	12.7	-12.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2856	0	50.8	0.0	50.8
3	765 kV	JHARSUGUDA-DURG	2	203	365	0.0	1.1	-1.1
4	400 kV	JHARSUGUDA-RAIGARH	4	439	56	5.2	0.0	5.2
5	400 kV	RANCHI-SIPAT	2	675	0	11.4	0.0	11.4
6	400 kV	JEYPORE-JAGDALPUR	2	133	264	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-RAIGARH	1	32	61	0.0	0.3	-0.3
8	220 kV	BUDHIPADAR-KORBA	2	135	0	1.9	0.0	1.9
						ER-WR	69.3	15.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	510	0	12.2	0.0	12.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1612	0.0	34.9	-34.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2162	0.0	28.5	-28.5
4	400 kV	TALCHER-I/C	2	891	447	5.3	0.0	5.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	12.2	63.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	582	0.0	8.0	-8.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	964	0.0	14.1	-14.1
3	220 kV	ALIPURDUAR-SALAKATI	2	0	167	0.0	2.4	-2.4
						ER-NER	0.0	24.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	403	0.0	9.7	-9.7
						NER-NR	0.0	9.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4554	0.0	101.6	-101.6
2	HVDC	VINDHYACHAL-B/B	-	0	512	1.1	4.1	-3.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2365	0.0	55.3	-55.3
4	765 kV	GWALIOR-AGRA	2	0	3109	0.0	50.9	-50.9
5	765 kV	GWALIOR-PHAGI	2	939	1520	4.5	17.3	-12.8
6	765 kV	JABALPUR-ORAI	2	0	1403	0.0	40.9	-40.9
7	765 kV	GWALIOR-ORAI	1	584	0	7.8	0.0	7.8
8	765 kV	SATNA-ORAI	1	0	1229	0.0	20.6	-20.6
9	765 kV	BANASKANTHA-CHITORGARH	2	271	1404	0.2	22.3	-22.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3998	0.0	76.2	-76.2
11	400 kV	ZERDA-KANKROLI	1	93	243	0.3	2.0	-1.7
12	400 kV	ZERDA-BHINMAL	1	493	324	3.1	1.8	1.4
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	301	658	1.8	5.9	-4.1
15	400 kV	NEEMUCH-Chittorgarh	2	251	782	1.2	7.2	-6.1
16	220 kV	BHANPURA-RANPUR	1	0	170	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.6	-2.6
18	220 kV	MEHGAON-AURAIYA	1	83	33	0.6	0.1	0.5
19	220 kV	MALANPUR-AURAIYA	1	55	40	0.3	0.2	0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	20.8	412.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1002	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGAULUR	2	0	2003	0.0	32.0	-32.0
3	765 kV	SOLAPUR-RAICHUR	2	2388	212	29.6	0.2	29.5
4	765 kV	WARDHAN-NIZAMABAD	2	1141	1719	3.8	11.4	-7.6
5	765 kV	WARORA-WARANGAL(NEW)	2	1146	1699	4.4	10.5	-6.2
6	400 kV	KOLHAPUR-KUDGI	2	1904	0	32.4	0.0	32.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	107	2.1	0.0	2.1
						WR-SR	96.3	54.0

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	718	378	597	14.33
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	180	-27	61	1.46
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-98	21	-41	-0.99
	NER	132kV GELEPHU-SALAKATI	37	-5	20	0.48
	NER	132kV MOTANGA-RANGIA	46	0	37	0.88
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-47	-1.13
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-45	-1.09
	ER	NEPAL IMPORT (FROM BIHAR)	207	0	-89	-2.13
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	200	-26	4	0.09
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-952	-874	-936	-22.47
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	-403	-595	-14.27
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-42	0	-36	-0.86

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 11-Jun-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	1.94	0.00	0.00	0.00	0.00	0.00	4.69	0.00	0.00	6.63
Bangladesh	23.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.23
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.17	0.00	0.00	0.00	0.00	0.00	4.69	0.00	0.00	29.86

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	15.43	0.00	0.77	0.00	0.00	0.09	0.00	0.00	16.29
Nepal	4.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.28
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	19.71	0.00	0.77	0.00	0.00	0.09	0.00	0.00	20.57

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	15.43	0.00	0.77	0.00	0.00	0.09	0.00	0.00	16.29
Nepal	2.34	0.00	0.00	0.00	0.00	-4.69	0.00	0.00	-2.35
Bangladesh	-23.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.23
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-5.46	0.00	0.77	0.00	0.00	-4.60	0.00	0.00	-9.29

