



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 09.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 08.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 8-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 08.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 09-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	67543	67829	50804	24504	2935	213615
Peak Shortage (MW)	0	0	0	10	0	10
Energy Met (MU)	1387	1580	1213	498	53	4731
Hydro Gen (MU)	111	42	82	21	14	270
Wind Gen (MU)	37	124	113	-	-	274
Solar Gen (MU)*	148.30	157.41	146.98	2.94	1.00	457
Energy Shortage (MU)	0.27	0.00	0.00	0.30	0.00	0.57
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72360	81207	61831	25288	3096	238817
Time Of Maximum Demand Met	11:14	10:13	09:42	18:02	17:44	10:27

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.025	0.00	0.00	1.01	1.01	79.30	19.70

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9950	0	180.3	80.3	-0.1	744	0.00
	Haryana	9856	0	181.5	126.1	-1.6	405	0.00
	Rajasthan	18664	0	343.9	112.0	-2.6	566	0.00
	Delhi	5671	0	95.9	88.1	-0.7	496	0.00
	UP	22946	0	419.3	110.0	0.3	569	0.00
	Uttarakhand	2624	0	49.5	39.8	0.4	177	0.27
	HP	2213	0	40.8	34.1	-0.5	110	0.00
	J&K(UT) & Ladakh(UT)	3256	0	66.8	63.2	-1.0	376	0.00
	Chandigarh	291	0	4.9	5.0	0.0	20	0.00
	Railways_NR ISTS	200	0	4.3	3.4	1.0	61	0.00
WR	Chhattisgarh	5524	0	109.0	51.4	-0.6	341	0.00
	Gujarat	24392	0	446.1	192.1	-4.5	1535	0.00
	MP	19498	0	351.1	215.6	0.0	438	0.00
	Maharashtra	28889	0	589.2	164.7	-8.7	473	0.00
	Goa	730	0	14.0	11.3	2.1	40	0.00
	DNHDDPDCL	1376	0	31.4	31.2	0.2	69	0.00
	AMNSIL	911	0	19.7	12.4	0.3	315	0.00
	BALCO	599	0	14.3	14.5	-0.2	10	0.00
	RIL JAMNAGAR	225	0	5.1	5.1	0	0	0.00
	Andhra Pradesh	11713	0	216.0	49.6	-1.0	831	0.00
SR	Telangana	15141	0	268.3	108.4	-0.5	697	0.00
	Karnataka	16295	0	292.7	96.5	-3.6	462	0.00
	Kerala	4414	0	81.4	63.2	0.1	319	0.00
	Tamil Nadu	17085	0	346.1	211.0	-6.0	756	0.00
	Puducherry	415	0	8.8	8.3	-0.1	47	0.00
	Bihar	6785	0	120.5	106.7	0.4	576	0.30
ER	DVC	3301	0	69.1	-39.4	0.2	339	0.00
	Jharkhand	2297	0	42.5	31.4	-0.3	231	0.00
	Odisha	5251	0	98.2	10.2	-2.5	335	0.00
	West Bengal	8079	0	165.4	36.3	-1.6	134	0.00
	Sikkim	120	0	1.9	1.9	0.0	15	0.00
	Railways_ER ISTS	17	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	188	0	3.4	3.4	-0.1	30	0.00
	Assam	1667	0	29.5	23.6	-0.1	104	0.00
	Manipur	280	0	4.1	4.0	0.1	33	0.00
	Meghalaya	377	0	6.5	6.0	-0.2	35	0.00
	Mizoram	166	0	2.6	2.3	-0.1	29	0.00
	Nagaland	165	0	2.7	2.7	-0.1	29	0.00
	Tripura	241	0	4.2	5.3	0.2	21	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-12.5	-6.2	-11.4	-27.9
Day Peak (MW)	-905.2	-621.7	-551.2	-1429.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	271.4	-228.4	125.6	-178.9	10.2	0.0
Actual(MU)	275.3	-235.4	112.5	-164.4	7.9	-4.0
O/D/U/D(MU)	3.9	-7.1	-13.1	14.4	-2.3	-4.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5990	11784	6718	5482	295	30269	52
State Sector	7034	10629	7470	2219	205	27556	48
Total	13024	22412	14188	7701	500	57825	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	812	1510	687	722	14	3747	73
Lignite	22	15	55	0	0	93	2
Hydro	111	42	82	21	14	270	5
Nuclear	53	52	47	0	0	152	3
Gas, Naptha & Diesel	13	23	10	0	22	67	1
RES (Wind, Solar, Biomass & Others)	210	284	309	7	1	811	16
Total	1221	1927	1191	750	51	5140	100

Share of RES in total generation (%)	17.17	14.75	25.98	0.95	1.96	15.79
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.63	19.66	36.78	3.69	29.31	24.00

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.020
Based on State Max Demands	1.054

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	238817	10:27	0
Non-Solar hr	217365	17:55	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godha (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 09-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.3	-2.3
3	765 kV	GAYA-VARANASI	2	0	1268	0.0	19.4	-19.4
4	765 kV	SASARAM-FATEHPUR	1	73	464	0.0	5.6	-5.6
5	765 kV	GAYA-BALIA	1	0	975	0.0	14.0	-14.0
6	400 kV	PUSAULI-VARANASI	1	17	74	0.0	0.7	-0.7
7	400 kV	PUSAULI-ALLAHABAD	1	0	115	0.0	1.5	-1.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	61	652	0.0	6.6	-6.6
9	400 kV	PATNA-BALIA	2	0	882	0.0	11.9	-11.9
10	400 kV	NAUBATPUR-BALIA	2	0	378	0.0	3.6	-3.6
11	400 kV	BIHARSHARIFF-BALIA	2	194	311	0.0	1.0	-1.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	557	0.0	7.9	-7.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	432	0.0	6.3	-6.3
14	220 kV	SAHUPURI-KARAMNANA	1	10	29	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	46	0.0	0.8	-0.8
ER-NR						0.1	82.3	-82.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	2303	0.0	29.1	-29.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1015	781	1.0	0.0	1.0
3	765 kV	JHARSUGUDA-DURG	2	0	1359	0.0	22.7	-22.7
4	400 kV	JHARSUGUDA-RAIGARH	4	217	423	0.0	2.2	-2.2
5	400 kV	RANCHI-SIPAT	2	313	244	0.2	0.0	0.2
6	400 kV	JEYPORE-JAGDALPUR	2	445	311	3.3	0.0	3.3
7	220 kV	BUDHIPADAR-RAIGARH	1	0	129	0.0	1.9	-1.9
8	220 kV	BUDHIPADAR-KORBA	2	76	111	0.0	0.3	-0.3
ER-WR						4.5	56.2	-51.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	742	0.0	12.5	-12.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1615	0.0	32.4	-32.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	2884	0.0	35.6	-35.6
4	400 kV	TALCHER-I/C	2	805	263	12.0	0.0	12.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	3	2	0.0	0.0	0.0
ER-SR						0.0	80.5	-80.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOIN	2	207	95	0.7	0.7	0.0
2	400 kV	ALIPURDUAR-BONGAIGAOIN	2	746	172	4.5	0.0	4.5
3	220 kV	ALIPURDUAR-SALAKATI	2	0	215	0.0	2.3	-2.3
ER-NER						5.2	3.1	2.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	462	0	11.2	0.0	11.2
NER-NR						11.2	0.0	11.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3526	0.0	71.2	-71.2
2	HVDC	VINDHYACHAL B/B	-	244	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1928	0.0	29.3	-29.3
4	765 kV	GWALIOR-AGRA	2	0	2580	0.0	33.5	-33.5
5	765 kV	GWALIOR-PHAGI	2	404	2127	0.4	28.2	-27.8
6	765 kV	JABALPUR-ORAI	2	0	1264	0.0	33.7	-33.7
7	765 kV	GWALIOR-ORAI	1	1000	0	16.0	0.0	16.0
8	765 kV	SATNA-ORAI	1	0	1333	0.0	23.9	-23.9
9	765 kV	BANASKANTHA-CHITTOORGARH	2	1635	741	8.8	2.7	6.1
10	765 kV	VINDHYACHAL VARANASI	2	0	2819	0.0	40.0	-40.0
11	400 kV	ZERDA-KANKROLI	1	280	22	2.6	0.0	2.6
12	400 kV	ZERDA BHINMAL	1	194	15	1.8	0.0	1.8
13	400 kV	VINDHYACHAL -RIHAND	1	953	0	21.5	0.0	21.5
14	400 kV	RAPP-SHUJALPUR	2	640	264	5.0	0.8	4.2
15	400 kV	NEEMUCH-Chittoorgarh	2	549	487	3.1	2.2	0.9
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	128	38	0.9	0.1	0.8
19	220 kV	MALANPUR-AURAIYA	1	95	49	0.5	0.2	0.3
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						66.6	269.4	-202.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	22.0	-22.0
2	HVDC	RAIGARH-PUGALUR	2	0	3009	0.0	54.0	-54.0
3	765 kV	SOLAPUR-RAICHUR	2	2081	1413	12.9	7.7	5.2
4	765 kV	WARDHA-NIZAMABAD	2	981	2088	2.9	19.6	-16.7
5	765 kV	WARORA-WARANGAL(NEW)	2	489	2546	0.8	28.7	-27.9
6	400 kV	KOLHAPUR-KUDGI	2	1978	0	29.4	0.0	29.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	108	1.9	0.0	1.9
WR-SR						48.0	132.0	-84.0

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-325	25	-176	-4.23	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-242	159	-94	-2.25	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-280	-111	-204	-4.90	
	NER	132kV GELEPHU-SALAKATI	-56	0	-38	-0.91	
	NER	132kV MOTANGA-RANGIA	-25	15	-10	-0.24	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-66	0	-8	-0.19	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-66	0	-48	-1.16	
	ER	NEPAL IMPORT (FROM BIHAR)	-172	0	-86	-2.07	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-341	61	-116	-2.78	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-421	-186	-375	-8.99	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1429	-825	-1162	-27.89	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-129	0	-100	-2.41	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 09-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.31	14.42	0.00	0.00	0.00	0.00	0.00	14.73	
Nepal	2.27	0.00	1.17	0.00	0.00	0.00	2.52	0.00	0.00	5.96
Bangladesh	9.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.41
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	11.68	0.31	15.59	0.00	0.00	0.00	2.52	0.00	0.00	30.10

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.43
Nepal	0.00	0.00	0.00	0.00	0.00	0.20	0.00	0.00	0.20
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.43	0.00	0.00	0.00	0.00	0.20	0.00	0.00	0.63

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	-0.31	-14.42	0.00	0.00	0.00	0.00	0.00	-14.30
Nepal	-2.27	0.00	-1.17	0.00	0.00	-2.32	0.00	0.00	-5.76
Bangladesh	-9.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-9.41
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.25	-0.31	-15.59	0.00	0.00	-2.32	0.00	0.00	-29.47

