



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 17.06.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.06.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-जून-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.06.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Jun-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79248	59745	46687	28587	3460	217727
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1783	1413	1045	650	66	4957
Hydro Gen (MU)	398	44	118	62	30	652
Wind Gen (MU)	12	143	296	-	-	452
Solar Gen (MU)*	129.37	96.71	105.57	2.85	0.41	335
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	83225	60146	47810	30266	3560	221625
Time Of Maximum Demand Met	22:42	00:00	09:41	23:09	19:34	22:24

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.043	0.00	0.27	7.31	7.58	69.44	22.98

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15812	0	350.4	227.0	-0.7	479	0.00
	Haryana	12795	0	265.4	209.6	-1.0	914	0.00
	Rajasthan	15282	0	314.8	137.0	-7.7	427	0.00
	Delhi	7176	0	149.1	131.0	-0.3	452	0.00
	UP	29135	0	548.1	238.2	-4.2	506	0.00
	Uttarakhand	2528	0	50.5	24.5	0.3	199	0.00
	HP	1848	0	38.7	3.9	-1.1	111	0.00
	J&K(UT) & Ladakh(UT)	2665	0	54.2	33.6	-1.0	149	0.00
	Chandigarh	428	0	8.0	8.1	-0.1	27	0.00
	Railways NR ISTS	209	0	4.1	4.0	0.2	41	0.00
WR	Chhattisgarh	5179	0	116.8	58.9	0.0	321	0.00
	Gujarat	20831	0	442.6	189.2	-6.6	549	0.00
	MP	11837	0	251.2	151.5	-2.4	503	0.00
	Maharashtra	23193	0	523.6	152.9	-2.0	777	0.00
	Goa	609	0	13.9	12.2	1.6	33	0.00
	DNHDDPDCL	1339	0	30.2	30.8	-0.6	67	0.00
	AMNSIL	861	0	17.5	8.2	0.1	211	0.00
	BALCO	537	0	12.8	12.7	0.1	39	0.00
	RIL JAMNAGAR	200	0	4.8	4.8	0.0	0	0.00
	Andhra Pradesh	9688	0	204.2	18.2	-1.0	1008	0.00
SR	Telangana	9920	0	205.2	96.4	2.0	783	0.00
	Karnataka	9916	0	190.3	-0.9	1.1	804	0.00
	Kerala	3863	0	73.4	35.5	-1.7	324	0.00
	Tamil Nadu	17247	0	361.6	120.7	-1.6	723	0.00
	Puducherry	494	0	10.5	10.1	-0.1	48	0.00
	Bihar	7982	0	166.0	160.7	-5.8	354	0.00
ER	DVC	3205	0	68.7	-29.1	-2.2	206	0.00
	Jharkhand	2213	0	48.5	40.9	-1.4	312	0.00
	Odisha	5984	0	123.3	67.0	0.0	1456	0.00
	West Bengal	11424	0	241.5	115.5	-1.5	194	0.00
	Sikkim	87	0	1.3	1.4	-0.1	30	0.00
	Railways ER ISTS	25	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	180	0	3.3	3.3	-0.2	38	0.00
	Assam	2377	0	42.4	35.2	0.5	150	0.00
	Manipur	212	0	3.3	3.2	0.0	25	0.00
	Meghalaya	330	0	5.6	0.5	-0.2	52	0.00
	Mizoram	119	0	1.7	1.4	-0.4	37	0.00
	Nagaland	158	0	3.1	2.8	-0.1	20	0.00
	Tripura	302	0	6.2	6.1	0.5	89	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	34.9	12.0	-23.9	-28.5
Day Peak (MW)	1662.0	666.1	-1027.0	-1455.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	450.5	-335.2	-128.2	7.9	4.9	0.0
Actual(MU)	436.8	-333.3	-140.0	21.6	5.2	-9.7
O/D/UD(MU)	-13.7	1.9	-11.9	13.7	0.3	-9.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2839	8116	5162	4020	504	20640	44
State Sector	4339	11752	7482	2759	300	26632	56
Total	7178	19867	12644	6779	804	47271	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	819	1506	559	635	12	3532	66
Lignite	21	14	43	0	0	79	1
Hydro	398	44	118	62	30	652	12
Nuclear	37	43	71	0	0	151	3
Gas, Naptha & Diesel	27	33	7	0	22	89	2
RES (Wind, Solar, Biomass & Others)	151	241	433	4	0	830	16
Total	1453	1881	1232	702	64	5331	100

Share of RES in total generation (%)	10.37	12.82	35.17	0.60	0.67	15.56
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	40.32	17.41	50.51	9.48	47.84	30.62

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.074

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215604	15:28	0
Non-Solar hr	221625	22:24	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 17-Jun-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	500	0.0	10.4	-10.4
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	694	534	0.0	0.7	-0.7
4	765 kV	SASARAM-FATEHPUR	1	310	236	0.0	0.5	-0.5
5	765 kV	GAYA-BALIA	1	0	760	0.0	10.6	-10.6
6	400 kV	PUSAULI-VARANASI	1	0	159	0.0	2.6	-2.6
7	400 kV	PUSAULI-ALLAHABAD	1	68	29	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	461	508	0.0	3.2	-3.2
9	400 kV	PATNA-BALIA	2	476	416	0.0	0.6	-0.6
10	400 kV	NAUBATPUR-BALIA	2	369	128	1.2	0.0	1.2
11	400 kV	BIHARSHARIFF-BALIA	2	572	0	5.9	0.0	5.9
12	400 kV	MOTIHARI-GORAKHPUR	2	228	348	0.0	1.9	-1.9
13	400 kV	BIHARSHARIFF-SAHUPURI	2	263	243	0.0	0.4	-0.4
14	220 kV	SAHUPURI-KARAMNASHA	1	0	113	0.0	2.6	-2.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASHA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASHA-CHANDAULI	1	0	0	0.0	1.0	-1.0
						ER-NR	8.1	-28.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1168	382	6.4	0.0	6.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2936	0	48.1	0.0	48.1
3	765 kV	JHARSUGUDA-DURG	2	360	179	1.0	0.0	1.0
4	400 kV	JHARSUGUDA-RAIGARH	4	483	0	6.0	0.0	6.0
5	400 kV	RANCHI-SIPAT	2	745	0	11.4	0.0	11.4
6	400 kV	JEYPORE-JAGDALPUR	2	164	181	0.1	0.0	0.1
7	220 kV	BUDHIPADAR-RAIGARH	1	100	28	0.5	0.0	0.5
8	220 kV	BUDHIPADAR-KORBA	2	173	8	1.7	0.0	1.7
						ER-WR	75.1	75.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	701	0	10.5	0.0	10.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1187	0.0	28.5	-28.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	1669	0.0	18.4	-18.4
4	400 kV	TALCHER-I/C	2	407	372	0.3	0.0	0.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	10.5	-36.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	514	0.0	4.6	-4.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	762	0.0	11.3	-11.3
3	220 kV	ALIPURDUAR-SALAKATI	2	0	122	0.0	1.4	-1.4
						ER-NER	17.3	-17.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	1005	0.0	13.9	-13.9
						NER-NR	13.9	-13.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3541	0.0	81.3	-81.3
2	HVDC	VINDHYACHAL-B/B	-	0	515	0.0	11.9	-11.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2368	0.0	53.9	-53.9
4	765 kV	GWALIOR-AGRA	2	0	3123	0.0	55.2	-55.2
5	765 kV	GWALIOR-PHAGI	2	0	1831	0.0	30.9	-30.9
6	765 kV	JABALPUR-ORAI	2	0	1456	0.0	52.2	-52.2
7	765 kV	GWALIOR-ORAI	1	600	0	11.1	0.0	11.1
8	765 kV	SATNA-ORAI	1	0	1187	0.0	23.4	-23.4
9	765 kV	BANASKANTHA-CHITORGARH	2	532	1339	1.0	10.1	-9.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3759	0.0	72.2	-72.2
11	400 kV	ZERDA-KANKROLI	1	95	205	0.4	1.5	-1.1
12	400 kV	ZERDA-BHINMAL	1	65	142	0.3	1.1	-0.8
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	0	577	0.0	7.2	-7.2
15	400 kV	NEEMUCH-Chittorgarh	2	0	652	0.0	9.5	-9.5
16	220 kV	BHANPURA-RANPUR	1	0	168	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	64	63	0.3	0.3	-0.1
19	220 kV	MALANPUR-AURAIYA	1	45	74	0.1	0.5	-0.4
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	13.1	-402.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1002	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGAULUR	2	1451	1202	4.0	10.0	-6.1
3	765 kV	SOLAPUR-RAICHUR	2	3391	0	56.5	0.0	56.5
4	765 kV	WARDHAN-NIZAMABAD	2	1337	681	12.3	2.1	-10.2
5	765 kV	WARORA-WARANGAL(NEW)	2	1347	804	14.0	2.1	-11.9
6	400 kV	KOLHAPUR-KUDGI	2	2466	0	46.2	0.0	46.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	1.8	0.0	1.8
						WR-SR	158.9	14.2
								144.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1400	-83	1131	27.14
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	384	56	234	5.62
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-128	-23	-83	-1.99
	NER	132kV GELEPHU-SALAKATI	64	-36	48	1.14
	NER	132kV MOTANGA-RANGIA	69	-10	50	1.20
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-0.88
	ER	NEPAL IMPORT (FROM BIHAR)	124	102	111	2.66
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	542	306	428	10.27
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-983	-798	-959	-23.02
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1455	-911	-1185	-28.45
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-44	0	-36	-0.86

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 17-Jun-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.34	0.00	0.00	0.34
Bangladesh	23.60	0.16	0.00	0.00	0.00	0.00	0.00	0.00	23.76
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.60	0.16	0.00	0.00	0.00	0.34	0.00	0.00	24.10

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	33.87	0.00	0.83	0.00	0.00	0.17	0.00	0.00	34.87
Nepal	8.05	0.15	0.00	0.00	0.00	3.82	0.00	0.00	12.02
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	41.92	0.15	0.83	0.00	0.00	3.99	0.00	0.00	46.89

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	33.87	0.00	0.83	0.00	0.00	0.17	0.00	0.00	34.87
Nepal	8.05	0.15	0.00	0.00	0.00	3.48	0.00	0.00	11.68
Bangladesh	-23.60	-0.16	0.00	0.00	0.00	0.00	0.00	0.00	-23.76
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	18.32	-0.01	0.83	0.00	0.00	3.65	0.00	0.00	22.79

