



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 23.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 22.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 22-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 22.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 23-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	51450	61324	44148	20177	2604	179703
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1147	1479	1067	419	49	4161
Hydro Gen (MU)	113	38	97	28	16	291
Wind Gen (MU)	4	39	44	-	-	87
Solar Gen (MU)*	148.18	85.81	122.95	2.83	0.98	361
Energy Shortage (MU)	1.77	0.00	0.00	0.18	0.00	1.95
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59622	71222	52191	21783	2816	203813
Time Of Maximum Demand Met	10:23	09:54	09:41	17:46	17:10	09:41

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.029	0.00	0.31	3.68	3.99	80.41	15.60

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7840	0	146.9	65.2	-0.1	460	0.00
	Haryana	7354	0	146.1	110.7	-1.5	209	0.00
	Rajasthan	17177	0	320.3	114.2	-0.5	558	0.00
	Delhi	3952	0	71.7	70.9	-1.3	239	0.00
	UP	16353	66	318.9	119.0	1.5	754	0.83
	Uttarakhand	2234	0	41.8	32.5	0.4	93	0.00
	HP	2040	0	36.2	27.8	-1.2	54	0.00
	J&K(UT) & Ladakh(UT)	2705	0	57.3	51.4	0.7	400	0.94
	Chandigarh	208	0	3.6	3.4	0.2	77	0.00
WR	Railways_NR ISTS	200	0	4.2	3.9	0.3	33	0.00
	Chhattisgarh	4352	0	87.1	42.0	-0.8	314	0.00
	Gujarat	21098	0	413.3	207.4	-0.5	507	0.00
	MP	17354	0	329.5	196.0	-3.5	835	0.00
	Maharashtra	27143	0	574.1	213.4	4.7	599	0.00
	Goa	705	0	14.5	13.6	0.3	39	0.00
	DNHDDPDCL	1319	0	30.3	30.4	-0.1	49	0.00
	AMNSIL	799	0	17.5	6.5	1.1	310	0.00
	BALCO	530	0	12.6	12.7	-0.1	7	0.00
SR	Andhra Pradesh	10061	0	200.3	53.0	-0.9	480	0.00
	Telangana	10502	0	198.7	96.1	0.5	509	0.00
	Karnataka	14085	0	249.4	80.5	1.5	533	0.00
	Kerala	4345	0	85.1	66.0	1.1	307	0.00
	Tamil Nadu	16084	0	323.7	184.3	1.5	1282	0.00
	Puducherry	440	0	9.5	9.1	-0.2	25	0.00
ER	Bihar	4557	0	83.7	71.7	0.6	239	0.00
	DVC	3093	0	65.5	-48.8	-0.4	465	0.00
	Jharkhand	2022	0	37.7	26.1	0.3	351	0.18
	Odisha	4885	0	90.2	19.5	-2.1	413	0.00
	West Bengal	7174	0	140.5	15.2	-1.7	226	0.00
	Sikkim	104	0	1.7	1.7	0.0	30	0.00
	Railways_ER ISTS	21	0	0.1	0.1	0.0	3	0.00
NER	Arunachal Pradesh	135	0	2.7	2.6	-0.1	22	0.00
	Assam	1626	0	28.6	21.2	0.5	134	0.00
	Manipur	212	0	2.9	2.9	0.0	42	0.00
	Meghalaya	362	0	6.4	5.5	-0.1	81	0.00
	Mizoram	135	0	1.9	1.8	-0.5	26	0.00
	Nagaland	155	0	2.3	2.2	-0.1	17	0.00
	Tripura	230	0	4.1	4.9	0.1	26	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	0.0	3.6	-23.2	-13.3
Day Peak (MW)	11.0	391.7	-975.0	-773.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	245.5	-146.3	103.8	-206.4	3.4	0.0
Actual(MU)	228.8	-135.3	102.5	-206.1	2.8	-7.3
O/D/U/D(MU)	-16.6	10.9	-1.3	0.3	-0.5	-7.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4742	10951	5798	4346	651	26488	47
State Sector	10043	9779	8269	859	339	29289	53
Total	14785	20730	14067	5205	990	55777	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	645	1502	612	672	9	3440	76
Lignite	28	7	55	0	0	90	2
Hydro	113	38	97	28	16	291	6
Nuclear	31	51	76	0	0	158	3
Gas, Naptha & Diesel	5	14	5	0	24	48	1
RES (Wind, Solar, Biomass & Others)	173	128	189	5	1	496	11
Total	994	1741	1034	705	51	4524	100
Share of RES in total generation (%)	17.39	7.36	18.30	0.71	1.94	10.97	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.85	12.48	35.02	4.65	33.74	20.90	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.047

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	203813	9:41	70
Non-Solar hr	193683	17:56	637

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 23-Nov-2024								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.3	-7.3
2	HVDC	PUSAULI B/B	-	0	303	0.0	7.2	-7.2
3	765 kV	GAYA-VARANASI	2	126	1044	0.0	16.2	-16.2
4	765 kV	SASARAM-FATEHPUR	1	40	491	0.0	7.0	-7.0
5	765 kV	GAYA-BALIA	1	0	712	0.0	13.3	-13.3
6	400 kV	PUSAULI-VARANASI	1	0	209	0.0	3.9	-3.9
7	400 kV	PUSAULI -ALLAHABAD	1	0	161	0.0	3.2	-3.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	118	475	0.0	6.3	-6.3
9	400 kV	PATNA-BALIA	2	0	730	0.0	11.1	-11.1
10	400 kV	NAUBATPUR-BALIA	2	15	243	0.0	4.0	-4.0
11	400 kV	BIHARSHARIFF-BALIA	2	181	151	0.0	1.1	-1.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	431	0.0	7.0	-7.0
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	12	92	0.0	0.3	-0.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	87.8	-87.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	9	776	0.0	10.6	-10.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	803	575	0.0	0.5	-0.5
3	765 kV	JHARSUGUDA-DURG	2	0	1196	0.0	23.1	-23.1
4	400 kV	JHARSUGUDA-RAIGARH	4	0	681	0.0	11.1	-11.1
5	400 kV	RANCHI-SIPAT	2	176	281	0.0	2.2	-2.2
6	220 kV	BUDHIPADAR-RAIGARH	1	137	86	0.0	0.5	-0.5
7	220 kV	BUDHIPADAR-KORBA	2	157	137	0.0	0.3	-0.3
ER-WR						0.0	48.4	-48.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	366	0.0	8.7	-8.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1992	0.0	36.6	-36.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	2592	0.0	52.2	-52.2
4	400 kV	TALCHER-I/C	2	644	342	6.0	0.0	6.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	97.5	-97.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	395	0.0	6.6	-6.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	882	0.0	10.4	-10.4
3	220 kV	ALIPURDUAR-SALAKATI	2	0	142	0.0	1.4	-1.4
ER-NER						0.0	18.3	-18.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	654	0.0	15.8	-15.8
NER-NR						0.0	15.8	-15.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1031	0.0	23.9	-23.9
2	HVDC	VINDHYACHAL B/B	-	97	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1446	0.0	26.5	-26.5
4	765 kV	GWALIOR-AGRA	2	0	1573	0.0	24.0	-24.0
5	765 kV	GWALIOR-PHAGI	2	320	2211	0.5	28.3	-27.8
6	765 kV	JABALPUR-ORAI	2	0	906	0.0	24.6	-24.6
7	765 kV	GWALIOR-ORAI	1	968	0	13.0	0.0	13.0
8	765 kV	SATNA-ORAI	1	0	1235	0.0	22.6	-22.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1398	0	16.6	0.0	16.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2413	0.0	42.7	-42.7
11	400 kV	ZERDA-KANKROLI	1	269	16	3.1	0.0	3.1
12	400 kV	ZERDA -BHINMAL	1	189	5	2.1	0.0	2.1
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	22.2	0.0	22.2
14	400 kV	RAPP-SHUJALPUR	2	589	324	2.8	2.1	0.7
15	400 kV	NEEMUCH-Chittorgarh	2	587	304	2.9	2.3	0.6
16	220 kV	BHANPURA-RANPUR	1	0	180	0.0	3.5	-3.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	145	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	109	0	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						68.2	202.6	-134.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	307	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	607	0.0	14.6	-14.6
3	765 kV	SOLAPUR-RAICHUR	2	1051	774	4.4	3.5	1.0
4	765 kV	WARDHA-NIZAMABAD	2	0	1403	0.0	23.8	-23.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1827	0.0	31.0	-31.0
6	400 kV	KOLHAPUR-KUDGI	2	1393	0	24.2	0.0	24.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	128	2.4	0.0	2.4
WR-SR						31.0	80.1	-49.0
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	116	-40	65	1.55		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	185	21	111	2.66		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-220	-164	-194	-4.66		
	NER	132kV GELEPHU-SALAKATI	10	1	4	0.10		
	NER	132kV MOTANGA-RANGIA	23	7	13	0.30		
NEPAL	NR	NEPAL IMPORT (FROM UP)	62	0	29	0.70		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.00		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	330	2	120	2.89		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-927	-925	-926	-22.22		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-773	-398	-554	-13.30		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-48	0	-41	-0.98		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 23-Nov-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	1.07	0.00	0.00	1.07
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.10	0.00	0.00	0.00	0.00	1.07	0.00	0.00	24.17

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.85
Nepal	0.00	0.00	0.00	0.00	0.00	3.29	0.00	0.00	3.29
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.85	0.00	0.00	0.00	0.00	3.29	0.00	0.00	4.14

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.85	0.00	0.00	0.00	0.00	-1.07	0.00	0.00	-0.22
Nepal	0.00	0.00	0.00	0.00	0.00	3.29	0.00	0.00	3.29
Bangladesh	-23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.10
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.25	0.00	0.00	0.00	0.00	2.22	0.00	0.00	-20.03

Date of Reporting: 23-Nov-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.03	146256	6252	4169	30	8347	1752	126911	1992	142057	149453	-496
0:15	49.98	145767	6238	4174	30	8212	1749	126597	1944	141563	148944	-492
0:30	49.93	145077	6255	4131	30	8507	1764	125558	1971	140916	148216	-469
0:45	49.98	143972	6259	4180	26	8314	1762	124780	1963	139766	147284	-476
1:00	50.03	143266	6270	4212	25	8121	1760	124176	1998	139029	146562	-486
1:15	49.98	141922	6259	4134	26	7838	1758	123435	1952	137762	145402	-504
1:30	49.98	141476	6267	4155	25	7871	1756	122869	1945	137296	144888	-502
1:45	49.98	140807	6243	4161	26	7756	1761	122513	1981	136620	144441	-585
2:00	49.98	140071	6261	4105	26	7816	1767	121683	1964	135940	143622	-593
2:15	49.97	139486	6254	3951	25	7797	1811	121311	1989	135510	143138	-585
2:30	49.97	139367	6270	3891	25	7738	1862	121190	1963	135451	142939	-587
2:45	50.02	139222	6245	3764	25	7800	1847	121270	1955	135433	142906	-603
3:00	50.03	138871	6257	3823	25	7825	1854	120782	1981	135023	142547	-583
3:15	50.03	138904	6254	3797	26	7640	1835	121013	2021	135081	142586	-580
3:30	50.03	138936	6257	3895	25	7676	1836	121069	1978	135016	142736	-579
3:45	50.03	139171	6248	4055	25	7601	1830	121213	1969	135091	142941	-576
4:00	50.08	139568	6233	4197	24	7711	1848	121524	1967	135347	143504	-613
4:15	50.03	140919	6257	4378	25	7691	1843	122826	1983	136516	145003	-641
4:30	50.03	143151	6243	4454	25	7992	1847	124558	1991	138672	147110	-716
4:45	49.98	145122	6246	4501	25	8261	1843	126323	1946	140596	149145	-713
5:00	50.03	147527	6251	4508	25	8617	1843	128396	1978	142994	151618	-795
5:15	50.03	151644	6256	4508	29	9404	1836	131560	1944	147107	155537	-700
5:30	50.03	155528	6223	4567	30	10048	1849	134635	1999	150931	159351	-763
5:45	49.98	159235	6238	4701	30	11328	1857	137124	1949	154504	163227	-804
6:00	50.08	163213	6241	4774	40	12992	1844	139292	2021	158399	167204	-886
6:15	50.03	167697	6238	4660	187	15506	1829	141285	1891	162850	171596	-893
6:30	49.93	174203	6224	4776	259	18210	1813	144886	1916	169168	178084	-887
6:45	50.03	179570	6218	4694	647	19669	1805	148277	1902	174229	183212	-837
7:00	50.03	183226	6243	4640	1538	20687	1814	150230	1963	177048	187115	-944
7:15	49.88	187261	6228	4578	2870	21012	1812	151966	1951	179813	190417	-893
7:30	49.95	190102	6239	4427	5223	20466	1818	152725	1991	180452	192889	-869
7:45	50.00	191681	6240	4301	8273	17871	1822	154026	2007	179107	194540	-838
8:00	50.05	191313	6240	4306	11985	15109	1818	152624	2024	175022	194106	-871
8:15	50.05	193169	6237	4248	15961	13283	1824	152156	2118	172960	195827	-843
8:30	50.05	195358	6252	4109	20697	12437	1821	150523	2132	170552	197971	-849
8:45	50.05	196961	6252	3900	25374	10899	1832	149230	2170	167687	199657	-909
9:00	50.10	197910	6238	3764	29466	10037	1826	147093	2216	164680	200640	-902
9:15	50.00	201740	6238	3627	33475	10674	1762	146438	2220	164638	204434	-929
9:30	50.05	202780	6225	3489	36963	10347	1758	144343	2291	162328	205416	-828
9:45	50.05	203384	6202	3288	39899	9643	1744	143860	2228	160197	206864	-882
10:00	50.05	203150	6191	3078	42495	9030	1757	141774	2231	157577	206556	-855
10:15	49.95	202429	6201	3016	44847	8246	1748	139507	2260	154566	205825	-882
10:30	50.00	201918	6206	2973	47399	7781	1760	137013	2278	151546	205410	-905
10:45	50.00	201095	6214	2898	48809	7018	1745	135628	2213	149388	204525	-892
11:00	50.00	200548	6231	2801	50139	6996	1737	133620	2283	147608	203807	-905
11:15	49.95	199433	6216	2753	51290	7049	1741	131174	2283	145390	202506	-886
11:30	49.95	198548	6209	2724	51829	7651	1745	129368	2237	143995	201763	-896
11:45	49.95	198505	6198	2675	52245	7448	1745	129288	2299	143585	201898	-870
12:00	49.93	196869	6209	2628	52357	7193	1739	127601	2256	141884	199983	-913
12:15	49.97	194838	6210	2566	52578	7243	1759	1202057	2291	139694	174704	-1812
12:30	50.00	194356	6216	2536	52717	7442	1757	124651	2290	139103	197609	-958
12:45	50.00	193318	6211	2493	52307	7102	1749	124116	2277	138518	196255	-958
13:00	50.01	191958	6172	2445	51675	6794	1725	122941	2317	137838	194069	-943
13:15	49.98	187206	6225	2429	50957	6530	1754	120189	2276	133820	190360	-997
13:30	49.88	186697	6229	2396	49949	6656	1743	120126	2315	134352	189414	-996
13:45	49.98	186617	6216	2331	48699	6988	1759	121408	2304	135587	189705	-993
14:00	50.08	186095	6201	2148	47044	7112	1766	122686	2289	136903	189246	-1018
14:15	50.08	186319	6213	2161	45067	7071	1800	124957	2280	139091	189549	-1016
14:30	50.03	187542	6177	2103	42876	7846	1793	127942	2225	142563	190962	-952
14:45	50.03	187767	6173	2041	40530	8013	1779	130184	2251	145196	190971	-848
15:00	50.08	188709	6166	1973	37637	8374	1766	133581	2275	149099	191772	-832
15:15	50.03	187705	6180	1887	35162	8988	1794	135214	1636	150656	190861	-973
15:30	50.03	188445	6186	1757	32039	9642	1801	138247	2250	154649	191922	-1016
15:45	49.98	188561	6199	1726	28716	10134	1877	140889	2214	158119	191755	-1019
16:00	49.98	188649	6185	1581	23769	11935	2224	144158	2257	163299	192109	-981
16:15	49.94	187327	6185	1486	19658	13369	2521	145578	2170	166183	190967	-1006
16:30	49.93	187668	6179	1401	15086	15208	2933	148455	2171	171181	191433	-1027
16:45	49.93	188520	6179	1343	10692	16897	3368	151389	2176	176485	192044	-969
17:00	50.03	189452	6164	1352	7015	19702	3317	153633	2179	181085	193362	-971
17:15	49.98	188924	6175	1398	3957	20920	3371	154618	2162	183569	192601	-874
17:30	49.98	189877	6172	1609	1861	23085	3365	155390	2141	186407	193623	-921
17:45	49.88	192008	6165	1795	698	25246	3404	156681	2156	189515	196145	-894
18:00	50.08	192840	6178	2189	423	26356	3336	155648	2195	190228	214315	-899
18:15	50.03	191593	6175	2554	376	25714	3349	154747	2191	188663	202912	-927
18:30	49.98	191364	6177	2992	327	25893	2148	155222	2167	188045	198031	-900
18:45	50.03	189959	6184	3271	241	24787	1802	155183	2187	186447	193655	-876
19:00	50.03	187974	6180	3603	233	23928	1819	153826	2147	184138	191736	-871
19:15	50.03	185916	6172	3817	234	22386	1818	152966	2174	181865	189567	-896
19:30	50.08	182640	6195	3998	235	21496	1803	150298	2138	178407	186163	-878
19:45	50.09	178130	6203	4134	130	18531	1806	148872	2121	173866	181797	-828
20:00	50.04	174262	6199	4312	160	16129	1783	147239	2085	169790	177907	-777
20:15	50.04	170808	6212	4437	92	14845	1793	145028	2130	166279	174537	-768
20:30	50.04	168092	6200	4501	90	13874	1799	143820	2158	163501	172442	-816
20:45	49.99	165979	6205	4514	70	13024	1799	141930	2126	161395	169668	-741
21:00	49.99	163133	6202	4657	57	12075	1800	139898	2161	158419	166850	-731
21:15	49.98	161196	6188	4731	52	11037	1765	138927	2207	156413	164907	-706
21:30	50.03	158649	6200	4783	54	10858	1757	136754	2151	153812	162557	-670
21:45	50.03	156865	6198	4772	54	10090	1764	135677	2178	152039	160733	-603
22:00	50.14	154507	6214	4760	54	9455	1777	134495	2147	149693	158902	-644
22:15	49.93	154788	6197	4738	55	9439	1774	134843	2173	149995	159219	-614
22:30	49.98	153708	6190	4796	57	9472	1770	134248	2165	148855	158698	-564
22:45	49.93	152875	6205									