



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 24.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 23.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 23-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 24-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	75572	60614	46719	31328	4065	218298
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1670	1448	1121	704	82	5024
Hydro Gen (MU)	291	87	173	111	35	696
Wind Gen (MU)	54	202	294	-	-	551
Solar Gen (MU)*	193.41	105.01	86.52	3.11	0.93	389
Energy Shortage (MU)	0.00	0.00	0.00	0.19	0.00	0.19
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	75899	63187	51710	32880	4101	218081
Time Of Maximum Demand Met	22:30	09:26	09:23	22:59	19:35	19:52

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.00	1.11	1.11	78.46	20.43

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13718	0	275.2	151.6	-1.8	670	0.00
	Haryana	11433	0	252.2	179.0	-0.9	413	0.00
	Rajasthan	13181	0	284.7	83.6	-7.0	51	0.00
	Delhi	6024	0	128.3	116.5	-1.0	243	0.00
	UP	29043	0	587.1	256.1	-0.5	430	0.00
	Uttarakhand	2242	0	48.7	16.4	-0.1	115	0.00
	HP	1835	0	37.4	-2.2	0.7	199	0.00
	J&K(UT) & Ladakh(UT)	2387	0	45.6	20.8	-0.2	142	0.00
	Chandigarh	332	0	6.5	6.3	0.2	27	0.00
WR	Railways_NR ISTS	201	0	3.9	3.6	0.3	32	0.00
	Chhattisgarh	5477	0	123.1	70.9	0.0	287	0.00
	Gujarat	18897	0	429.5	113.3	-5.1	373	0.00
	MP	12349	0	258.2	138.2	-0.1	919	0.00
	Maharashtra	24951	0	554.2	221.2	-3.0	859	0.00
	Goa	552	0	13.8	11.4	1.9	51	0.00
	DNHDDPDCL	1401	0	32.6	32.5	0.1	110	0.00
	AMNSIL	837	0	18.6	9.0	0.8	265	0.00
	BALCO	531	0	12.6	12.7	-0.1	3	0.00
SR	RIL JAMNAGAR	243	0	5.2	5.2	0.0	0	0.00
	Andhra Pradesh	9154	0	202.4	16.3	-0.2	598	0.00
	Telangana	11473	0	233.5	94.4	-0.2	655	0.00
	Karnataka	11590	0	220.9	18.6	-2.0	504	0.00
	Kerala	3862	0	76.9	33.5	-1.6	277	0.00
	Tamil Nadu	17622	0	376.8	132.1	-9.6	613	0.00
	Puducherry	476	0	10.4	9.9	-0.2	45	0.00
ER	Bihar	8741	0	183.5	173.4	-1.5	579	0.19
	DVC	3145	0	69.5	-42.9	-0.1	243	0.00
	Jharkhand	2135	0	46.2	37.4	-0.1	189	0.00
	Odisha	6704	0	140.6	60.0	-1.7	386	0.00
	West Bengal	12940	0	262.6	130.5	-1.1	329	0.00
	Sikkim	70	0	1.2	1.3	-0.1	10	0.00
	Railways_ER ISTS	17	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	219	0	4.3	3.6	0.3	41	0.00
	Assam	2798	0	55.9	47.4	1.4	251	0.00
	Manipur	239	0	3.8	3.6	0.2	60	0.00
	Meghalaya	313	0	5.1	1.9	0.1	104	0.00
	Mizoram	124	0	1.9	0.7	-0.2	51	0.00
	Nagaland	197	0	3.6	3.1	0.0	47	0.00
	Tripura	378	0	7.0	5.3	0.3	120	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	58.9	13.6	-23.1	-33.5
Day Peak (MW)	2634.0	776.7	-998.0	-1474.5

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	341.4	-247.5	-101.1	-7.1	14.3	0.0
Actual(MU)	321.2	-236.2	-118.9	6.7	19.5	-7.7
O/D/U/D(MU)	-20.2	11.3	-17.8	13.8	5.3	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	8422	15546	6378	5180	785	36311	55
State Sector	6714	11618	8847	2562	220	29961	45
Total	15136	27164	15225	7742	1005	66271	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	811	1315	590	650	12	3378	63
Lignite	18	14	39	0	0	70	1
Hydro	291	87	173	111	35	696	13
Nuclear	37	41	65	0	0	143	3
Gas, Naptha & Diesel	37	43	4	0	18	103	2
RES (Wind, Solar, Biomass & Others)	256	308	426	5	1	996	18
Total	1450	1808	1297	767	66	5387	100

Share of RES in total generation (%)	17.64	17.04	32.86	0.71	1.44	18.49
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	40.28	24.12	51.17	15.17	54.30	34.08

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.044
Based on State Max Demands	1.090

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215649	10:10	0
Non-Solar hr	218081	19:52	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 24-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.5	-7.5
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	1328	488	6.3	0.0	6.3
4	765 kV	SASARAM-FATEHPUR	1	622	222	3.9	0.0	3.9
5	765 kV	GAYA-BALIA	1	0	813	0.0	12.3	-12.3
6	400 kV	PUSAULI-VARANASI	1	0	165	0.0	2.8	-2.8
7	400 kV	PUSAULI -ALLAHABAD	1	62	26	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	396	682	0.0	5.1	-5.1
9	400 kV	PATNA-BALIA	2	536	589	0.0	2.7	-2.7
10	400 kV	NAUBATPUR-BALIA	2	242	121	0.0	0.2	-0.2
11	400 kV	BIHARSHARIFF-BALIA	2	541	93	4.3	0.0	4.3
12	400 kV	MOTIHARI-GORAKHPUR	2	152	239	0.0	1.7	-1.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	425	222	0.0	0.7	-0.7
14	220 kV	SAHUPURI-KARAMNASA	1	0	116	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						15.1	37.2	-22.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	875	577	5.5	0.0	5.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2734	0	46.7	0.0	46.7
3	765 kV	JHARSUGUDA-DURG	2	284	361	0.0	0.5	-0.5
4	400 kV	JHARSUGUDA-RAIGARH	4	310	303	1.1	0.0	1.1
5	400 kV	RANCHI-SIPAT	2	658	0	10.1	0.0	10.1
6	400 kV	JEYPORE-JAGDALPUR	2	53	722	0.0	7.8	-7.8
7	220 kV	BUDHIPADAR-RAIGARH	1	64	88	0.0	0.3	-0.3
8	220 kV	BUDHIPADAR-KORBA	2	151	69	0.7	0.0	0.7
ER-WR						64.1	8.6	55.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	729	0	13.7	0.0	13.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1165	0.0	22.5	-22.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2315	0.0	21.2	-21.2
4	400 kV	TALCHER-I/C	2	584	276	6.6	0.0	6.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						13.7	43.7	-30.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	5	486	0.0	6.5	-6.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	1049	0.0	17.1	-17.1
3	220 kV	ALIPURDUAR-SALAKATI	2	0	191	0.0	3.1	-3.1
ER-NER						0.0	26.7	-26.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.5	-8.5
NER-NR						0.0	8.5	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3532	0.0	72.3	-72.3
2	HVDC	VINDHYACHAL B/B	-	46	0	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	2555	0.0	40.0	-40.0
5	765 kV	GWALIOR-PHAGI	2	1525	1339	8.6	15.7	-7.1
6	765 kV	JABALPUR-ORAI	2	0	1376	0.0	37.2	-37.2
7	765 kV	GWALIOR-ORAI	1	649	119	9.0	0.2	8.7
8	765 kV	SATNA-ORAI	1	0	972	0.0	16.6	-16.6
9	765 kV	BANASKANTHA-CHITORGARH	2	572	1549	0.8	17.3	-16.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	3793	0.0	72.8	-72.8
11	400 kV	ZERDA-KANKROLI	1	166	169	0.3	1.5	-1.1
12	400 kV	ZERDA -BHINMAL	1	115	117	0.2	1.0	-0.8
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	563	445	4.1	4.2	0.0
15	400 kV	NEEMUCH-Chittorgarh	2	477	548	3.2	5.3	-2.1
16	220 kV	BHANPURA-RANPUR	1	0	143	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.6	-2.6
18	220 kV	MEHGAON-AURAIYA	1	113	24	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	84	42	0.4	0.1	0.4
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						28.8	325.8	-297.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1002	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	0	602	0.0	12.1	-12.1
3	765 kV	SOLAPUR-RAICHUR	2	3363	0	56.1	0.0	56.1
4	765 kV	WARDHA-NIZAMABAD	2	1066	1708	7.0	7.6	-0.6
5	765 kV	WARORA-WARANGAL(NEW)	2	670	0	1.5	0.0	1.5
6	400 kV	KOLHAPUR-KUDGI	2	2274	0	45.8	0.0	45.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	115	2.1	0.0	2.1
WR-SR						136.5	19.7	116.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1513	1160	1449	34.77	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	871	781	820	19.67	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	154	60	114	2.73	
	NER	132kV GELEPHU-SALAKATI	35	0	27	0.64	
	NER	132kV MOTANGA-RANGIA	60	0	46	1.11	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-46	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-46	0	-8	-0.18	
	ER	NEPAL IMPORT (FROM BIHAR)	137	60	115	2.76	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	594	375	460	11.05	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-913	-918	-22.03	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1475	-1239	-1398	-33.54	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-57	0	-43	-1.02	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.09
Bangladesh	22.85	0.07	0.00	0.00	0.00	0.00	0.00	0.00	22.92
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.94	0.07	0.00	0.00	0.00	0.00	0.00	0.00	23.01

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	55.45	0.00	1.66	0.00	0.00	0.18	0.00	0.00	57.29
Nepal	8.45	0.07	4.97	0.00	0.00	0.80	0.00	0.00	14.29
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	63.90	0.07	6.63	0.00	0.00	0.98	0.00	0.00	71.58

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	55.45	0.00	1.66	0.00	0.00	0.18	0.00	0.00	57.29
Nepal	8.36	0.07	4.97	0.00	0.00	0.80	0.00	0.00	14.20
Bangladesh	-22.85	-0.07	0.00	0.00	0.00	0.00	0.00	0.00	-22.92
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	40.96	0.00	6.63	0.00	0.00	0.98	0.00	0.00	48.57

