



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 04.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 03.02.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 3-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 03.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली



Report for previous day

Date of Reporting: 04-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57467	66573	47766	22807	2684	197297
Peak Shortage (MW)	0	126	0	0	0	126
Energy Met (MU)	1241	1594	1262	477	51	4624
Hydro Gen (MU)	94	56	88	22	11	270
Wind Gen (MU)	34	39	54	-	-	126
Solar Gen (MU)*	164.67	104.92	149.82	3.15	0.67	423
Energy Shortage (MU)	0.00	1.86	0.00	0.00	0.00	1.86
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66240	78994	63356	23615	2827	231373
Time Of Maximum Demand Met	09:55	10:41	10:53	18:02	17:44	10:42

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.041	0.00	0.89	5.57	6.46	76.48	17.06

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8785	0	157.3	60.2	-3.8	201	0.00
	Haryana	8386	0	155.0	111.8	-1.7	650	0.00
	Rajasthan	18143	0	353.8	112.2	1.3	729	0.00
	Delhi	4557	0	75.7	68.6	-1.9	327	0.00
	UP	18708	0	346.9	90.2	-0.3	819	0.00
	Uttarakhand	2373	0	42.3	33.3	-0.8	80	0.00
	HP	2109	0	37.5	32.2	-1.2	72	0.00
	J&K(UT) & Ladakh(UT)	2957	0	64.9	62.9	-1.7	718	0.00
	Chandigarh	263	0	4.2	4.2	-0.1	26	0.00
	Railways NR ISTS	187	0	3.9	3.9	0.0	20	0.00
WR	Chhattisgarh	5786	76	128.0	73.2	-0.2	593	0.29
	Gujarat	23507	0	429.1	189.7	-1.4	836	0.00
	MP	18472	203	350.0	224.4	-0.4	757	1.57
	Maharashtra	28714	0	607.3	232.2	-2.8	2913	0.00
	Goa	732	0	14.7	14.0	0.4	61	0.00
	DNHDDPDCL	1334	0	30.0	30.2	-0.2	36	0.00
	AMNSIL	799	0	17.3	7.6	0.6	310	0.00
	BALCO	533	0	12.7	12.7	0.0	527	0.00
	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	11803	0	220.7	47.9	-1.3	373	0.00
SR	Telangana	15262	0	288.1	163.2	-1.2	717	0.00
	Karnataka	17117	0	309.2	111.6	-1.4	1097	0.00
	Kerala	4520	0	90.5	69.6	1.9	505	0.00
	Tamil Nadu	16955	0	344.6	200.9	-0.3	546	0.00
	Puducherry	413	0	8.8	8.6	-0.3	22	0.00
	Bihar	5836	0	102.2	88.5	1.2	326	0.00
ER	DVC	3288	0	67.6	-47.7	-0.4	280	0.00
	Jharkhand	2087	0	39.1	27.6	-0.6	147	0.00
	Odisha	5626	0	111.9	38.5	-0.2	407	0.00
	West Bengal	7416	0	153.5	26.8	-1.5	161	0.00
	Sikkim	122	0	2.0	2.0	0.0	32	0.00
	Railways ER ISTS	23	0	0.3	0.3	0.0	8	0.00
NER	Arunachal Pradesh	190	0	3.4	3.5	-0.2	21	0.00
	Assam	1541	0	28.1	22.8	0.6	198	0.00
	Manipur	246	0	3.7	3.6	0.1	40	0.00
	Meghalaya	342	0	6.5	5.1	-0.1	90	0.00
	Mizoram	153	0	2.9	1.9	-0.1	16	0.00
	Nagaland	156	0	2.3	2.4	-0.2	34	0.00
	Tripura	217	0	4.1	3.7	0.4	58	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.3	-11.3	-22.1	-15.3
Day Peak (MW)	-684.8	-582.7	-1018.0	-1150.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	181.6	-220.4	186.2	-155.2	7.7	0.0
Actual(MU)	160.5	-181.9	181.9	-155.0	7.0	12.6
O/D/U/D(MU)	-21.1	38.5	-4.4	0.3	-0.7	12.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4015	6903	4278	4481	777	20454	42
State Sector	6628	12608	5639	2909	161	27945	58
Total	10643	19511	9917	7390	938	48399	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	776	1641	692	692	15	3815	76
Lignite	28	14	53	0	0	95	2
Hydro	94	56	88	22	11	270	5
Nuclear	32	55	71	0	0	158	3
Gas, Naptha & Diesel	11	19	11	0	22	64	1
RES (Wind, Solar, Biomass & Others)	225	146	236	6	1	613	12
Total	1165	1931	1151	719	49	5015	100
Share of RES in total generation (%)	19.30	7.56	20.48	0.78	1.38	12.22	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.06	13.31	34.32	3.78	23.51	20.76	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.036

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	231373	10:42	98
Non-Solar hr	204848	18:45	111

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 04-Feb-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.3	-1.3
3	765 kV	GAYA-VARANASI	2	0	946	0.0	15.6	-15.6
4	765 kV	SASARAM-FATEHPUR	1	0	579	0.0	9.9	-9.9
5	765 kV	GAYA-BALIA	1	0	675	0.0	9.8	-9.8
6	400 kV	PUSAULI-VARANASI	1	0	73	0.0	1.0	-1.0
7	400 kV	PUSAULI -ALLAHABAD	1	25	29	0.0	0.2	-0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	230	558	0.0	4.2	-4.2
9	400 kV	PATNA-BALIA	2	0	684	0.0	11.8	-11.8
10	400 kV	NAUBATPUR-BALIA	2	0	231	0.0	3.5	-3.5
11	400 kV	BIHARSHARIFF-BALIA	2	193	299	0.0	1.4	-1.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	379	0.0	5.5	-5.5
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	5.0	-5.0
15	220 kV	SAHUPURI-KARAMNASA	1	0	63	0.0	0.7	-0.7
16	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
17	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
18	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
19	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	69.9	-69.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1085	547	6.8	0.0	6.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	328	967	0.0	6.4	-6.4
3	765 kV	JHARSUGUDA-DURG	2	0	1024	0.0	18.8	-18.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	795	0.0	14.0	-14.0
5	400 kV	RANCHI-SIPAT	2	0	407	0.0	6.2	-6.2
6	220 kV	BUDHIPADAR-RAIGARH	1	23	86	0.0	0.9	-0.9
7	220 kV	BUDHIPADAR-KORBA	2	65	94	0.0	0.1	-0.1
ER-WR						6.8	46.3	-39.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	362	0.0	8.6	-8.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1247	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2746	0.0	49.9	-49.9
4	400 kV	TALCHER-I/C	2	159	6	2.3	0.0	2.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	88.7	-88.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	217	69	2.3	0.1	2.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	385	0	4.7	0.0	4.7
3	220 kV	ALIPURDUAR-SALAKATI	2	89	0	1.2	0.0	1.2
ER-NER						8.2	0.1	8.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2020	0.0	23.8	-23.8
2	HVDC	VINDHYACHAL B/B	-	127	145	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	980	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	374	1929	0.5	17.2	-16.7
5	765 kV	GWALIOR-PHAGI	2	65	1826	0.0	21.8	-21.8
6	765 kV	JABALPUR-ORAI	2	65	1039	0.0	20.4	-20.4
7	765 kV	GWALIOR-ORAI	1	812	0	15.2	0.0	15.2
8	765 kV	SATNA-ORAI	1	0	1075	0.0	18.0	-18.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1291	224	11.8	0.2	11.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2279	0.0	25.5	-25.5
11	400 kV	ZERDA-KANKROLI	1	261	45	2.7	0.0	2.7
12	400 kV	ZERDA -BHINMAL	1	181	31	1.9	0.0	1.9
13	400 kV	VINDHYACHAL -RIHAND	1	969	0	21.7	0.0	21.7
14	400 kV	RAPP-SHUJALPUR	2	592	318	5.0	0.8	4.2
15	400 kV	NEEMUCH-Chittorgarh	2	629	364	5.1	0.9	4.2
16	220 kV	BHANPURA-RANPUR	1	0	192	0.0	3.1	-3.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	135	0	1.9	0.0	1.9
19	220 kV	MALANPUR-AURAIYA	1	100	0	1.2	0.0	1.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						67.0	160.5	-93.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1010	0.0	21.0	-21.0
2	HVDC	RAIGARH-PUGALUR	2	0	4005	0.0	56.9	-56.9
3	765 kV	SOLAPUR-RAICHUR	2	1108	1210	5.6	8.3	-2.7
4	765 kV	WARDHA-NIZAMABAD	2	0	2382	0.0	33.9	-33.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2587	0.0	38.8	-38.8
6	400 kV	KOLHAPUR-KUDGI	2	1336	0	22.8	0.0	22.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.6	0.0	2.6
WR-SR						31.0	158.8	-127.8
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	177	-149	53	1.28		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-293	100	-122	-2.92		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-275	-125	-215	-5.16		
	NER	132kV GELEPHU-SALAKATI	-24	-12	-19	-0.45		
	NER	132kV MOTANGA-RANGIA	-8	5	-1	-0.01		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	-47	-1.12		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-45	-1.07		
	ER	NEPAL IMPORT (FROM BIHAR)	-197	0	-156	-3.75		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-386	-32	-223	-5.36		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-944	-640	-862	-20.69		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1150	-202	-638	-15.30		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-74	0	-57	-1.37		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	7.54	0.00	0.00	0.61	0.00	0.00	8.48
Nepal	3.56	0.00	4.25	0.00	0.00	1.30	0.00	0.00	9.11
Bangladesh	21.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.89	0.33	11.79	0.00	0.00	1.91	0.00	0.00	38.92

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	-0.33	-7.54	0.00	0.00	-0.61	0.00	0.00	-7.69
Nepal	-3.56	0.00	-4.25	0.00	0.00	-1.30	0.00	0.00	-9.11
Bangladesh	-21.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.10	-0.33	-11.79	0.00	0.00	-1.91	0.00	0.00	-38.13

Date of Reporting: 04-Feb-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	156011	5967	7493	23	7812	1887	134864	3297	148495	161343	-1867
0:15	50.02	156514	5965	7605	5	7161	1893	135657	3312	148904	161598	-1878
0:30	49.97	155882	5977	7534	6	6790	1892	135490	3323	148342	161012	-1859
0:45	49.97	155948	5969	7502	46	6594	1892	135621	3292	148400	160916	-1822
1:00	49.97	155343	5962	7474	47	6478	1879	135229	3249	147822	160318	-1804
1:15	49.97	154560	5968	7388	47	6184	1900	134895	3275	147125	159657	-1818
1:30	50.02	153503	5975	7144	47	5783	1885	134458	3257	146312	158549	-1819
1:45	49.97	153172	5984	7035	47	5255	1889	134812	3272	146090	158294	-1799
2:00	50.02	151742	5965	7002	5	4875	1870	134151	3274	144735	157142	-1820
2:15	49.97	151849	5981	6884	6	4760	1892	134126	3336	144959	156985	-1685
2:30	49.97	151383	5983	6757	6	4754	1871	133640	3321	144620	156332	-1639
2:45	49.97	151255	5982	6709	6	4711	1888	133443	3315	144540	156054	-1605
3:00	49.97	150907	5975	6643	6	4879	1877	133212	3323	144258	155915	-1650
3:15	49.97	151117	5988	6560	5	4949	1884	133461	3301	144552	156148	-1645
3:30	49.97	151274	5989	6420	6	5294	1875	133551	3270	144848	156405	-1634
3:45	49.92	151735	5980	6419	6	5520	1874	133770	3290	145310	156859	-1623
4:00	50.02	152127	5979	6318	5	5508	1917	134411	3274	145804	157412	-1665
4:15	49.97	154341	5983	6251	6	6045	1875	136055	3267	148084	159482	-1667
4:30	49.97	155706	5984	6172	5	6322	1874	137358	3239	149529	160954	-1694
4:45	49.97	157121	5981	6029	6	6653	1873	138508	3228	151086	162278	-1705
5:00	49.97	159856	5966	5788	5	7004	1873	141255	3239	154063	165130	-1769
5:15	50.02	164276	5964	5598	9	7617	1900	145264	3275	158669	169627	-1751
5:30	50.07	167553	5981	5593	9	8139	1881	148096	3250	161951	172949	-1743
5:45	49.97	172169	5977	5584	9	9029	1883	151307	3258	166576	177047	-1433
6:00	50.07	175132	5986	5550	2	9567	1946	153634	3319	169580	180004	-1391
6:15	50.02	179685	5978	5581	376	10677	2038	156917	3368	173728	184935	-1349
6:30	50.02	187310	5971	5468	545	13309	2494	161110	3319	181297	192216	-1256
6:45	50.02	192755	5983	5367	582	16742	2811	163014	3357	186806	197856	-1210
7:00	49.97	198038	5984	5413	790	20344	3050	164513	3366	191835	203460	-1380
7:15	49.86	203599	5995	5394	1544	22670	3256	166387	3358	196661	208604	-1004
7:30	50.01	206727	5972	5420	3136	23287	3502	166653	3384	198171	211354	-991
7:45	50.07	210164	5988	5438	5713	23841	3717	166496	3362	199013	214555	-891
8:00	50.17	211424	5991	5212	9230	22496	3736	165313	3369	196982	215347	-826
8:15	50.12	214717	5988	5141	13347	21860	3453	165412	3405	196229	218606	-763
8:30	50.07	217373	5975	4962	17881	19927	3024	165774	3406	194530	220949	-769
8:45	50.12	218945	5988	4618	22500	18096	3035	164873	3453	191827	222563	-908
9:00	50.07	222071	5981	4297	27363	16486	3033	164990	3505	190411	225655	-1095
9:15	50.02	228223	5974	3850	32144	15981	3043	167292	3524	192229	231808	-1172
9:30	50.02	229059	5959	3338	36454	15325	2847	165427	3511	189267	232861	-1370
9:45	49.97	230969	5951	2736	40323	14059	2221	165963	3569	187910	234822	-1432
10:00	50.02	230692	5949	2289	43901	12568	2017	164281	3524	184502	234529	-1479
10:15	49.86	229971	5940	2238	46488	10873	2017	162721	3566	181245	233843	-1491
10:30	50.01	230925	5949	2397	49036	10364	2020	161480	3518	179492	234764	-1513
10:45	50.07	231183	5958	2394	52062	9605	1890	159607	3488	176727	235004	-1517
11:00	50.07	230496	5960	2530	53889	9071	1860	156422	3488	174077	233220	-1495
11:15	50.02	228964	5960	2633	55912	7828	1861	154986	3553	170419	232733	-1627
11:30	50.02	227372	5948	2723	57118	7701	1852	152570	3496	167531	231408	-1833
11:45	50.02	225604	5956	2799	58006	7460	1846	150322	3516	164799	229905	-2161
12:00	50.12	224334	5951	2797	59019	7104	1858	148517	3426	162518	228672	-2123
12:15	49.96	222264	5952	2757	59377	6322	1852	146886	3448	160130	226594	-2300
12:30	50.01	221436	5937	2790	59592	6225	1844	145607	3485	159054	225480	-2129
12:45	49.96	219638	5935	2849	59696	5960	1856	143969	3467	157093	223732	-2006
13:00	50.07	217218	5931	2910	59874	5568	1851	142071	3454	154434	221659	-2177
13:15	50.01	212924	5947	3024	59722	5153	1859	138131	3448	150178	217284	-2161
13:30	50.06	211414	5928	3083	59489	5174	1857	136378	3440	148842	215349	-2167
13:45	49.96	210835	5950	3107	58695	5224	1864	136877	3481	149033	215198	-2175
14:00	49.91	209866	5918	3059	57771	5379	1859	136834	3443	149036	214263	-2192
14:15	49.86	209178	5908	3075	56846	5411	1861	137070	3437	149257	213608	-2163
14:30	49.86	209504	5876	3086	54801	5760	1857	139261	3413	151617	214054	-2131
14:45	49.81	210320	5919	3105	52990	6440	1866	141427	3413	154225	215160	-2169
15:00	49.86	210670	5893	3103	50306	6609	1863	144392	3403	157261	215569	-2194
15:15	49.91	210558	5905	3064	48118	6937	1861	146151	3421	159376	215457	-2102
15:30	49.96	210820	5915	3114	44760	7400	1866	148182	3387	162946	214624	-2078
15:45	50.01	209653	5918	3099	41365	7610	1981	150799	3414	165189	214186	-2133
16:00	50.01	208503	5927	3124	37905	8144	1983	153200	3357	167474	213640	-2120
16:15	50.01	206234	5923	3090	34081	8629	1980	153944	3340	169063	210987	-2053
16:30	49.96	206527	5920	3082	29713	9347	1987	157836	3310	173732	211195	-1873
16:45	49.96	207215	5921	3124	24987	11179	1980	160980	3350	179104	211521	-1639
17:00	50.06	206098	5917	3064	19936	12911	1990	162140	3376	183098	209334	-1622
17:15	50.07	202282	5918	3034	15057	14921	1996	160919	3363	184191	205208	-1178
17:30	50.07	203207	5917	3140	9955	19035	1974	163444	3272	190112	206737	-1207
17:45	50.02	203453	5912	3183	5814	22266	1994	164758	3247	194456	207174	-1080
18:00	50.07	202133	5925	3335	2930	23286	2064	165140	3261	195868	205941	-1107
18:15	50.02	201835	5924	3537	1304	23300	2094	166293	3216	196994	205668	-900
18:30	49.97	204217	5924	3964	376	24066	2094	167713	3246	199615	207645	-712
18:45	49.97	204848	5926	4390	476	24524	2207	167623	3268	199982	208414	-712
19:00	50.02	203870	5923	4742	387	23282	2083	166828	3269	198741	206514	-698
19:15	50.02	201354	5926	5044	382	20776	2087	166553	3290	195928	204058	-680
19:30	50.02	198747	5935	5309	370	19507	2125	165229	3315	193068	201790	-664
19:45	50.02	196717	5943	5591	371	17501	1914	164942	3303	190755	199565	-680
20:00	50.02	193479	5934	5772	369	14723	1859	164321	3395	187338	196373	-717
20:15	49.97	190418	5950	5826	383	12768	1885	163378	3352	184209	193542	-947
20:30	50.02	188449	5927	5833	375	11933	1868	162487	3339	182241	191762	-1026
20:45	50.02	186129	5947	5922	376	10592	1872	161418	3293	179831	189420	-1031
21:00	50.02	183121	5946	5816	352	10205	1862	159115	3321	176953	186617	-1067
21:15	50.02	180452	5941	5813	348	10052	1864	156876	3317	174291	184211	-1475
21:30	50.02	178435	5955	5813	36	9542	1875	156041	3311	172586	182573	-1664
21:45	50.02	177047	5954	6000	107	9073	1852	154669	3406	170940	181061	-1856
22:00	50.07	173873	5962	6009	83	8186	1864	152640	3352	167781	178096	-1861
22:15	50.02	175606	5756	6114	84	8874	1864	153343	3340	169408	179375	-1863
22:30	50.02	174745	5934	6248	84	8509	1867	152989	3330	168413	178961	