



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	56368	63470	47652	21976	2767	192233
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1252	1516	1094	449	51	4362
Hydro Gen (MU)	117	51	98	25	12	304
Wind Gen (MU)	19	129	66	-	-	214
Solar Gen (MU)*	184.42	149.66	92.60	3.12	1.01	431
Energy Shortage (MU)	0.41	0.00	0.00	0.00	0.02	0.43
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67056	72242	53543	22749	2943	214100
Time Of Maximum Demand Met	10:17	10:18	09:25	17:48	17:00	10:17

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.036	0.00	0.07	3.55	3.62	74.95	21.43

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9795	0	175.3	79.9	1.5	1123	0.00
	Haryana	9101	0	166.6	125.0	-1.5	501	0.00
	Rajasthan	17748	0	331.4	112.8	-0.8	1221	0.00
	Delhi	4224	0	79.4	72.2	1.3	484	0.00
	UP	18986	0	345.9	82.8	-0.9	335	0.00
	Uttarakhand	2308	0	42.6	33.4	0.0	68	0.41
	HP	2166	0	38.2	28.9	-0.7	88	0.00
	J&K(UT) & Ladakh(UT)	3166	0	64.2	59.3	-0.7	130	0.00
	Chandigarh	231	0	3.9	3.9	0.0	13	0.00
	Railways_NR ISTS	197	0	4.0	3.8	0.2	32	0.00
WR	Chhattisgarh	4698	0	91.8	30.8	-1.0	344	0.00
	Gujarat	22544	0	433.5	167.1	-5.3	963	0.00
	MP	18464	0	337.9	204.4	0.0	546	0.00
	Maharashtra	27110	0	570.3	187.2	-1.1	1343	0.00
	Goa	760	0	15.2	12.0	2.6	98	0.00
	DNHDDPDCL	1325	0	30.5	30.4	0.1	202	0.00
	AMNSIL	794	0	17.6	10.2	0.7	275	0.00
	BALCO	566	0	13.5	13.3	0.2	72	0.00
	RIL JAMNAGAR	261	0	5.8	5.8	0.0	55	0.00
	Andhra Pradesh	9402	0	194.5	49.9	-0.4	689	0.00
SR	Telangana	11942	0	215.7	83.6	-1.0	561	0.00
	Karnataka	15642	0	279.5	112.7	-1.7	596	0.00
	Kerala	4294	0	83.5	64.6	-0.4	304	0.00
	Tamil Nadu	16112	0	312.4	206.5	-4.0	678	0.00
	Puducherry	407	0	8.7	8.2	-0.1	38	0.00
	Bihar	5098	0	91.6	77.5	-1.0	212	0.00
ER	DVC	3226	0	65.0	-49.9	-0.8	349	0.00
	Jharkhand	2079	0	40.8	28.1	-0.4	323	0.00
	Odisha	4962	0	95.9	15.9	-3.3	433	0.00
	West Bengal	7721	0	153.5	32.5	-2.3	294	0.00
	Sikkim	102	0	1.7	1.7	0.0	39	0.00
	Railways_ER ISTS	20	0	0.2	0.1	0.0	6	0.00
NER	Arunachal Pradesh	179	0	3.2	2.9	0.1	32	0.00
	Assam	1693	0	29.1	22.6	0.3	153	0.00
	Manipur	240	0	3.7	3.7	0.0	47	0.00
	Meghalaya	348	18	6.1	4.8	-0.1	55	0.02
	Mizoram	153	0	2.2	1.7	-0.2	20	0.00
	Nagaland	159	0	2.8	2.7	0.0	8	0.00
	Tripura	239	0	4.1	4.6	0.1	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.9	8.5	-21.2	-25.3
Day Peak (MW)	-738.2	698.6	-971.5	-1338.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	224.4	-221.4	175.1	-189.9	11.9	0.0
Actual(MU)	205.0	-202.4	168.2	-192.7	11.5	-10.4
O/D/U/D(MU)	-19.4	19.1	-6.9	-2.8	-0.4	-10.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5584	15530	7788	6840	530	36272	52
State Sector	11124	11875	8454	1977	205	33634	48
Total	16708	27404	16242	8817	735	69906	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	710	1423	640	682	9	3463	73
Lignite	25	11	47	0	0	83	2
Hydro	117	51	98	25	12	304	6
Nuclear	37	46	46	0	0	130	3
Gas, Naptha & Diesel	8	26	4	0	23	61	1
RES (Wind, Solar, Biomass & Others)	228	281	183	6	1	699	15
Total	1125	1838	1018	713	46	4740	100

Share of RES in total generation (%)	20.25	15.29	18.00	0.85	2.21	14.75
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.00	20.58	32.16	4.36	29.41	23.90

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.020
Based on State Max Demands	1.067

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	214100	10:17	0
Non-Solar hr	200089	18:17	288

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 05-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	82	1284	0.0	19.3	-19.3
4	765 kV	SASARAM-FATEHPUR	1	0	650	0.0	9.9	-9.9
5	765 kV	GAYA-BALIA	1	0	706	0.0	11.2	-11.2
6	400 kV	PUSAULI-VARANASI	1	32	80	0.0	0.2	-0.2
7	400 kV	PUSAULI-ALLAHABAD	1	0	133	0.0	2.1	-2.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	203	781	0.0	8.5	-8.5
9	400 kV	PATNA-BALIA	2	0	1025	0.0	14.1	-14.1
10	400 kV	NAUBATPUR-BALIA	2	134	265	0.0	4.7	-4.7
11	400 kV	BIHARSHARIFF-BALIA	2	256	371	0.0	1.8	-1.8
12	400 kV	MOTIHARI-GORAKHPUR	2	0	594	0.0	7.5	-7.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	49	509	0.0	7.3	-7.3
14	220 kV	SAHUPURI-KARMANASA	1	32	0	0.0	1.3	-1.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	90.3	-89.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1075	0.0	12.3	-12.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	110	1242	0.0	14.2	-14.2
3	765 kV	JHARSUGUDA-DURG	2	0	1243	0.0	23.1	-23.1
4	400 kV	JHARSUGUDA-RAIGARH	4	57	516	0.0	4.5	-4.5
5	400 kV	RANCHI-SIPAT	2	23	379	0.0	4.4	-4.4
6	400 kV	JEYPORE-JACDALPUR	2	451	64	5.8	0.0	5.8
7	220 kV	BUDHIPADAR-RAIGARH	1	0	158	0.0	2.2	-2.2
8	220 kV	BUDHIPADAR-KORBA	2	99	50	0.8	0.0	0.8
ER-WR						6.5	60.8	-54.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	622	0.0	13.1	-13.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1614	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2576	0.0	47.5	-47.5
4	400 kV	TALCHER/IC	2	396	384	4.2	0.0	4.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	2	0	0.0	0.0	0.0
ER-SR						0.0	100.3	-100.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	179	156	0.9	0.6	0.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	355	115	2.7	0.0	2.7
3	220 kV	ALIPURDUAR-SALAKATI	2	80	0	0.9	0.0	0.9
ER-NER						4.4	0.6	3.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3560	0.0	44.1	-44.1
2	HVDC	VINDHYACHAL B/B	-	0	106	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	27.2	-27.2
4	765 kV	GWALIOR-AGRA	2	61	1631	0.0	20.9	-20.9
5	765 kV	GWALIOR-PHAGI	2	575	2138	0.6	29.0	-28.4
6	765 kV	JABALPUR-ORAI	2	0	1072	0.0	28.3	-28.3
7	765 kV	GWALIOR-ORAI	1	1058	0	8.3	0.0	8.3
8	765 kV	SATNA-ORAI	1	0	966	0.0	8.1	-8.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2201	26	17.4	0.0	17.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	1892	0.0	30.4	-30.4
11	400 kV	ZERDA-KANKROLI	1	369	0	3.4	0.0	3.4
12	400 kV	ZERDA -BHINMAL	1	255	0	2.4	0.0	2.4
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	21.0	0.0	21.0
14	400 kV	RAPP-SHUJALPUR	2	619	327	3.1	1.9	1.2
15	400 kV	NEEMUCH-Chittorgarh	2	664	375	3.1	2.3	0.8
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	97	0	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	66	13	0.6	0.0	0.6
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						61.1	198.4	-137.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	310	0.0	6.2	-6.2
2	HVDC	RAIGARH-PUGALUR	2	0	3006	0.0	63.8	-63.8
3	765 kV	SOLAPUR-RAICHUR	2	390	1273	1.1	10.3	-9.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2039	0.0	28.5	-28.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2389	0.0	36.6	-36.6
6	400 kV	KOLHAPUR-KUDGI	2	1430	0	23.0	0.0	23.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	117	0.0	2.2	-2.2
WR-SR						26.4	145.4	-119.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	184	-177	-8	-0.19	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	325	-162	101	2.43	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-370	-244	-282	-6.76	
	NER	132kV GELEPHU-SALAKATI	-61	0	-52	-1.24	
	NER	132kV MOTANGA-RANGIA	-22	0	-8	-0.18	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-33	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	44	0	20	0.49	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	632	188	335	8.05	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-890	-650	-799	-19.17	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1338	-815	-1056	-25.34	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	106	0	-87	-2.08	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	4.93	0.00	0.00	1.33	0.00	0.00	6.57
Nepal	0.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.07
Bangladesh	20.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.07	0.31	4.93	0.00	0.00	1.33	0.00	0.00	26.64

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	1.64	0.00	0.00	8.46	0.00	0.00	10.10
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	1.64	0.00	0.00	8.46	0.00	0.00	10.10

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-4.93	0.00	0.00	-1.33	0.00	0.00	-6.57
Nepal	-0.07	0.00	1.64	0.00	0.00	8.46	0.00	0.00	10.03
Bangladesh	-20.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.07	-0.31	-3.29	0.00	0.00	7.13	0.00	0.00	-16.54

