



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 23.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 22.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 22-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 22.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 23-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61670	66767	46101	23012	2778	200328
Peak Shortage (MW)	0	232	0	97	0	329
Energy Met (MU)	1293	1548	1161	465	50	4518
Hydro Gen (MU)	134	52	92	22	11	310
Wind Gen (MU)	8	62	68	-	-	138
Solar Gen (MU)*	136.58	155.49	140.21	2.33	1.06	436
Energy Shortage (MU)	0.48	0.75	0.00	0.15	0.00	1.38
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69382	78095	60542	24120	2838	230405
Time Of Maximum Demand Met	11:15	10:30	11:55	17:40	17:22	10:16

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.31	0.58	7.72	8.61	75.00	16.39

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9007	0	161.0	72.0	-1.3	724	0.00
	Haryana	9101	0	168.2	111.7	-0.8	344	0.00
	Rajasthan	17947	0	332.6	122.3	4.0	1264	0.00
	Delhi	5073	0	85.9	79.3	0.6	458	0.00
	UP	20885	0	391.7	93.5	-1.7	521	0.00
	Uttarakhand	2455	0	44.7	34.4	0.6	113	0.41
	HP	2147	0	37.4	30.0	-0.8	94	0.00
	J&K(UT) & Ladakh(UT)	3118	0	63.8	60.8	-2.8	78	0.07
	Chandigarh	247	0	4.1	4.0	0.1	40	0.00
	Railways_NR ISTS	181	0	3.7	3.7	0.0	74	0.00
WR	Chhattisgarh	5136	0	102.6	40.2	-2.0	445	0.00
	Gujarat	23922	0	446.7	186.7	-2.5	981	0.00
	MP	19368	0	347.8	235.8	0.0	1123	0.75
	Maharashtra	27520	0	568.6	167.9	-4.7	1012	0.00
	Goa	688	0	13.0	10.6	1.9	40	0.00
	DNHDDPDCL	1345	0	29.8	29.9	-0.1	72	0.00
	AMNSIL	870	0	19.3	12.1	0.2	250	0.00
	BALCO	594	0	14.1	14.2	-0.1	26	0.00
	RIL JAMNAGAR	264	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	11095	0	208.6	47.0	0.1	404	0.00
SR	Telangana	14226	0	244.6	108.0	-1.1	588	0.00
	Karnataka	16364	0	291.9	119.3	-0.4	737	0.00
	Kerala	4294	0	77.1	55.7	-0.1	248	0.00
	Tamil Nadu	16570	0	330.3	189.5	-2.3	1136	0.00
	Puducherry	410	0	8.5	7.9	-0.3	34	0.00
	Bihar	5950	0	107.5	102.5	-1.1	408	0.00
ER	DVC	3198	0	67.5	-37.2	-1.0	375	0.00
	Jharkhand	2083	0	39.4	30.1	-3.2	222	0.15
	Odisha	5124	0	95.0	9.0	-4.0	497	0.00
	West Bengal	7718	0	154.1	23.1	-0.9	338	0.00
	Sikkim	111	0	1.7	1.7	0.0	15	0.00
	Railways_ER ISTS	25	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	191	0	3.3	3.1	0.1	19	0.00
	Assam	1594	0	27.9	21.6	0.1	168	0.00
	Manipur	244	0	3.8	3.7	0.1	43	0.00
	Meghalaya	342	0	6.2	5.2	-0.1	73	0.00
	Mizoram	157	0	2.4	2.1	-0.1	15	0.00
	Nagaland	168	0	2.8	2.7	0.0	14	0.00
	Tripura	236	0	4.1	4.8	0.1	59	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-11.1	0.2	-22.9	-23.1
Day Peak (MW)	-910.5	-372.9	-1042.0	-1440.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	243.1	-215.8	161.0	-198.6	10.3	0.0
Actual(MU)	251.8	-218.9	144.6	-199.8	8.8	-13.4
O/D/U/D(MU)	8.8	-3.1	-16.4	-1.2	-1.5	-13.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6747	13279	7628	4435	114	32203	49
State Sector	8719	10830	10034	3227	205	33014	51
Total	15466	24108	17662	7662	319	65217	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	769	1509	648	737	14	3678	74
Lignite	26	17	63	0	0	107	2
Hydro	134	52	93	22	11	311	6
Nuclear	32	53	47	0	0	131	3
Gas, Naptha & Diesel	16	41	4	0	22	83	2
RES (Wind, Solar, Biomass & Others)	170	220	236	5	1	632	13
Total	1146	1892	1091	764	48	4941	100

Share of RES in total generation (%)	14.81	11.62	21.64	0.68	2.22	12.93
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.24	17.16	34.39	3.53	24.93	21.87

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.041

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	230405	10:16	0
Non-Solar hr	210460	18:30	285

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 23-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	0	1387	0.0	21.9	-21.9
4	765 kV	SASARAM-FATEHPUR	1	0	528	0.0	5.0	-5.0
5	765 kV	GAYA-BALIA	1	0	762	0.0	14.0	-14.0
6	400 kV	PUSAULI-VARANASI	1	30	94	0.0	0.5	-0.5
7	400 kV	PUSAULI-ALLAHABAD	1	0	125	0.0	1.9	-1.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	283	707	0.0	6.8	-6.8
9	400 kV	PATNA-BALIA	2	0	1081	0.0	18.6	-18.6
10	400 kV	NAUBATPUR-BALIA	2	0	490	0.0	5.6	-5.6
11	400 kV	BIHARSHARIFE-BALIA	2	318	302	0.0	1.4	-1.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	626	0.0	9.9	-9.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	549	0.0	8.3	-8.3
14	220 kV	SAHUPURI-KARMANASA	1	3	53	0.0	1.2	-1.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.1	-0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	28	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	28	0.0	0.0	0.0
ER-NR						0.6	97.6	-97.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	246	1415	0.0	16.3	-16.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	720	1052	0.0	2.6	-2.6
3	765 kV	JHARSUGUDA-DURG	2	0	1291	0.0	22.9	-22.9
4	400 kV	JHARSUGUDA-RAIGARH	4	299	124	2.3	0.0	2.3
5	400 kV	RANCHI-SIPAT	2	161	340	0.0	1.3	-1.3
6	400 kV	JEYPORE-JAGDALPUR	2	524	296	0.4	0.0	0.4
7	220 kV	BUDHIPADAR-RAIGARH	1	0	148	0.0	2.1	-2.1
8	220 kV	BUDHIPADAR-KORBA	2	25	83	0.0	0.8	-0.8
ER-WR						2.7	46.0	-43.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	725	0.0	3.1	-3.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1336	0.0	34.2	-34.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2988	0.0	48.5	-48.5
4	400 kV	TALCHER-I/C	2	424	823	0.0	1.3	-1.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	85.8	-85.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	113	415	0.2	5.3	-5.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	238	467	0.0	5.1	-5.1
3	220 kV	ALIPURDUAR-SALAKATI	2	64	71	0.0	0.5	-0.5
ER-NER						0.2	10.8	-10.6
Import/Export of <null> (With <null>)								
No Records Found								
NER-NR						0.0	0.0	0.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2504	0.0	46.2	-46.2
2	HVDC	VINDHYACHAL B/B	-	924	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1272	0.0	22.6	-22.6
4	765 kV	GWALIOR-AGRA	2	143	1764	0.0	23.3	-23.2
5	765 kV	GWALIOR-PHAGI	2	122	2264	0.0	32.9	-32.9
6	765 kV	JABALPUR-ORAI	2	0	1106	0.0	36.8	-36.8
7	765 kV	GWALIOR-ORAI	1	1148	0	20.9	0.0	20.9
8	765 kV	SATNA-ORAI	1	0	1218	0.0	24.0	-24.0
9	765 kV	BANASKANTHA-CHITORGARH	2	2041	890	17.3	1.6	15.7
10	765 kV	VINDHYACHAL-VARANASI	2	0	2220	0.0	31.7	-31.7
11	400 kV	ZERDA-KANKROLI	1	331	121	2.2	0.2	2.1
12	400 kV	ZERDA-BHINMAL	1	229	84	2.1	0.1	2.0
13	400 kV	VINDHYACHAL -RIHAND	1	477	0	10.8	0.0	10.8
14	400 kV	RAPP-SHUJALPUR	2	299	395	0.9	3.3	-2.4
15	400 kV	NEEMUCH-Chittorgarh	2	554	391	2.3	3.0	-0.8
16	220 kV	BHANPURA-RANPUR	1	0	115	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	159	4	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	121	16	0.9	0.0	0.8
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						64.8	229.2	-164.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	20.2	-20.2
2	HVDC	RAIGARH-PUGALUR	2	0	3011	0.0	47.5	-47.5
3	765 kV	SOLAPUR-RAICHUR	2	1629	1705	5.0	7.4	-2.4
4	765 kV	WARDHA-NIZAMABAD	2	148	2285	0.1	20.7	-20.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2725	0.0	31.3	-31.3
6	400 kV	KOLHAPUR-KUDGI	2	1781	0	22.4	0.0	22.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	117	2.1	0.0	2.1
WR-SR						29.6	127.1	-97.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 L.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-217	36	-97	-2.32		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) L.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	285	-234	4	0.10		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) L.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-339	-261	-304	-7.29		
	NER	132kV GELEPHU-SALAKATI	-55	-35	-47	-1.13		
	NER	132kV MOTANGA-RANGIA	-26	-10	-20	-0.49		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-66	0	-9	-0.22		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-66	0	-10	-0.25		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
BANGLADESH	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-243	221	29	0.70		
	ER	BHERAMARA B/B HVDC (B'DESH)	-923	-633	-853	-20.48		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1440	-827	-964	-23.15		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-120	0	-100	-2.40		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 23-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.31	12.44	0.00	0.00	0.00	0.00	0.00	12.75	
Nepal	0.38	0.00	0.00	0.00	0.00	0.00	1.01	0.00	0.00	1.39
Bangladesh	21.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.22
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.60	0.31	12.44	0.00	0.00	0.00	1.01	0.00	0.00	35.36

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	2.26	0.00	0.00	2.26
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	2.26	0.00	0.00	2.26

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-12.44	0.00	0.00	0.00	0.00	0.00	-12.75
Nepal	-0.38	0.00	0.00	0.00	0.00	1.25	0.00	0.00	0.87
Bangladesh	-21.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.22
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.60	-0.31	-12.44	0.00	0.00	1.25	0.00	0.00	-33.10

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+H)	(K)
0:00	50.00	146557	4848	6868	0	7340	1614	126940	3477	139689	151087	-1272
0:15	50.00	146567	4855	6841	0	7044	1645	127430	3461	139726	151276	-1320
0:30	49.90	145610	4859	6715	0	7265	1636	126162	3457	138895	150094	-1293
0:45	49.90	145227	4855	6493	0	7286	1624	126047	3451	138734	149756	-1333
1:00	49.95	144749	4847	6331	0	7271	1662	125799	3435	138418	149345	-1326
1:15	49.95	143792	4857	6129	0	7083	1638	125351	3438	137663	148496	-1337
1:30	49.95	142906	4863	5954	0	7115	1665	124521	3498	136952	147616	-1348
1:45	49.95	142806	4861	5813	0	6956	1648	124732	3492	136993	147502	-1348
2:00	50.00	141599	4857	5690	0	6908	1626	123857	3439	135909	146377	-1319
2:15	49.95	141865	4850	5629	0	6801	1625	124074	3460	136236	146439	-1241
2:30	50.00	141404	4863	5575	0	6691	1629	123906	3469	135829	146133	-1247
2:45	49.95	141724	4858	5483	0	6665	1653	124424	3484	136241	146567	-1284
3:00	50.05	141281	4857	5421	0	6182	1688	124389	3522	135860	146059	-1322
3:15	50.00	142010	4854	5406	0	6148	1702	125393	3476	136604	146979	-1396
3:30	49.95	143185	4861	5455	0	6133	1760	126477	3479	137730	148165	-1322
3:45	50.00	143848	4860	5445	0	6062	1775	127177	3473	138403	148792	-1293
4:00	50.00	144291	4860	5525	0	6185	1755	127427	3463	138766	149215	-1353
4:15	50.00	146914	4863	5528	0	6739	1879	129507	3478	141386	151994	-1328
4:30	50.00	148891	4863	5456	0	6769	1794	131524	3430	143435	153836	-1346
4:45	50.05	150709	4844	5266	0	6962	1855	132976	3460	145443	155363	-1406
5:00	50.05	151852	4849	5203	65	7274	2023	134075	3445	146584	156934	-1412
5:15	50.00	156674	4858	5100	68	8015	2379	138085	3479	151506	161984	-1436
5:30	50.05	161131	4862	5087	59	9368	2659	141305	3531	155985	166871	-1419
5:45	49.95	166352	4859	5040	62	10239	3023	145216	3517	161250	171956	-1491
6:00	50.00	170479	4848	5010	58	11426	3618	147409	3508	165411	175877	-1153
6:15	50.05	177405	4855	4954	80	14465	3855	150782	3535	172371	182526	-728
6:30	50.05	184914	4849	4969	82	18193	3736	154525	3459	179863	189813	-607
6:45	49.90	191354	4853	5003	163	21323	4071	157592	3507	186188	196512	-708
7:00	50.00	198151	4849	5025	560	24483	4010	160630	3466	192566	203023	-834
7:15	49.90	204001	4851	4970	1541	26954	4989	161961	3475	197490	208741	-808
7:30	49.95	207084	4853	5000	2913	27434	5496	162805	3459	199171	211960	-770
7:45	50.00	210245	4845	5069	5112	27550	5466	163273	3514	200064	214829	-931
8:00	50.05	209640	4866	5006	8277	24665	5361	162292	3476	196357	213943	-886
8:15	49.90	214244	4843	5093	12246	23931	5377	163327	3478	196905	218295	-913
8:30	50.00	217558	4851	4969	17130	22348	5373	163425	3413	195459	221509	-875
8:45	49.90	219251	4855	4700	21930	19397	5393	163537	3489	192621	223301	-1010
9:00	50.00	221138	4841	4473	26317	17165	5357	163077	3473	190348	224703	-950
9:15	49.90	225975	4829	4432	30948	16168	5417	163632	3529	190595	228955	-972
9:30	50.05	227705	4846	4500	35296	15564	5382	161822	3436	187909	230846	-1163
9:45	50.05	228845	4850	4571	39218	13769	5335	160834	3422	185056	231999	-1237
10:00	50.10	229851	4845	4632	44807	12618	4707	158314	3499	180412	233422	-1844
10:15	50.10	230256	4839	4947	48303	11155	4105	157391	3478	177006	234218	-2185
10:30	50.10	230108	4856	5143	51618	9682	3313	155711	3438	173347	233761	-2125
10:45	50.10	229164	4849	5310	54220	8529	3105	153299	3480	169634	232792	-2116
11:00	50.09	229501	4849	5331	56710	8204	3037	150622	3605	167460	232358	-2126
11:15	50.04	227978	4841	5258	58853	7898	2814	147164	3589	163867	230417	-2140
11:30	50.04	227638	4843	5073	60489	7271	2783	145908	3580	162076	229947	-2267
11:45	50.20	227958	4837	4874	62309	6806	2629	143896	3587	160775	228938	-2228
12:00	50.19	225335	4839	4754	62946	6943	2549	140251	3543	157635	225825	-2255
12:15	49.99	223020	4829	4741	63548	6726	2521	137062	3582	154731	223009	-2251
12:30	49.99	221130	4831	4601	63322	6965	2410	135335	3566	153207	221030	-2220
12:45	49.89	219103	4836	4603	65565	6998	2422	133699	3523	148935	221646	-2228
13:00	49.94	216398	4820	4501	65701	6952	2408	131453	3546	146196	219381	-2206
13:15	49.94	212852	4833	4532	65289	6908	2384	128548	3416	143031	215910	-2259
13:30	49.99	212107	4831	4312	65107	6872	2381	127725	3524	142688	214752	-2285
13:45	49.94	212014	4830	4214	63410	6827	2402	129233	3529	144390	214445	-2271
14:00	49.99	211780	4812	4188	61851	6936	2390	130721	3537	145741	214435	-2305
14:15	49.94	212172	4818	4150	59998	6769	2406	132867	3544	148024	214552	-2316
14:30	49.89	212546	4807	4037	58055	6995	2405	135366	3582	150454	215247	-2268
14:45	49.94	212790	4825	4058	55028	7283	2411	138077	3479	153704	215161	-2208
15:00	50.04	212590	4815	3975	52588	7579	2375	140566	3519	156027	215417	-2182
15:15	49.99	211503	4820	3874	49175	7694	2420	142626	3500	158454	214109	-2218
15:30	50.05	211316	4820	3869	45352	8284	2517	145730	3474	162095	214046	-2224
15:45	50.00	211157	4827	3856	40789	10013	2891	148006	3528	166512	213910	-2215
16:00	49.90	209970	4808	3830	35687	11058	3344	150666	3525	170453	212918	-1991
16:15	49.95	207438	4810	3827	30099	11104	4062	152459	3485	173512	209846	-1257
16:30	49.85	208146	4805	3814	24016	13243	4745	156473	3543	180316	210639	-1047
16:45	49.90	208492	4817	3760	17905	16417	5465	159697	3541	186827	211602	-1043
17:00	50.05	208471	4833	3833	12094	20397	5730	160929	3632	192544	211448	-1035
17:15	50.05	205893	4809	3758	7218	23770	5717	160107	3539	194917	208918	-1044
17:30	50.00	207827	4812	3628	3765	27340	5835	162107	3492	200434	210979	-1033
17:45	49.90	209388	4813	3770	1639	23931	5867	163364	3512	203979	212356	-1052
18:00	50.00	209722	4801	3999	664	29616	6027	163829	3528	205059	212464	-1042
18:15	50.00	209525	4840	4364	355	29789	6373	162994	3545	204806	212260	-1023
18:30	50.00	210460	4826	4692	255	30157	6392	163467	3547	205513	213336	-1034
18:45	50.00	207869	4819	5073	146	29960	6340	160691	3537	202650	210566	-1002
19:00	50.05	205658	4835	5505	153	28718	5279	160069	3597	200000	208156	-984
19:15	50.05	205156	4833	5917	147	26830	4878	161767	3581	199092	207953	-994
19:30	50.05	202594	4821	6370	0	23976	4907	161770	3526	196224	205370	-1006
19:45	50.10	199302	4838	6812	0	22186	4591	160089	3554	192490	202070	-962
20:00	50.10	195541	4837	7142	0	20264	3459	159107	3567	188399	198376	-975
20:15	50.05	192351	4839	7324	0	17734	2906	158767	3654	185027	195224	-863
20:30	50.00	189618	4837	7682	0	15988	2682	157776	3607	181936	192572	-876
20:45	50.05	186606	4838	7995	0	13629	2417	156913	3665	178611	189457	-867
21:00	50.05	183494	4842	8213	0	12101	2327	155461	3629	175281	186573	-841
21:15	50.00	180186	4833	8321	0	11821	2325	152123	3616	171865	183039	-941
21:30	50.00	176726	4836	8478	0	10669	2309	150223	3591	168248	180106	-986
21:45	50.00	173941	4855	8610	0	10165	2329	148166	3528	165331	177653	-1588
22:00	49.99	169739	4847	8772	0	8911	2387	145242	3503	160967	173662	-1575
22:15	49.94	168971	4849	8863	0	8878	2359	144120	3587	160108	172656	-1654
22:30	50.00	167476	4836	9061	0	8591	2365	142734	3640	158415	171227	-1668
22:45	50.00	165686										