



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 03.06.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 02.06.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 2-जून-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 02.06.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 03-Jun-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	68676	62730	48831	28372	3059	211668
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1546	1455	1112	648	55	4816
Hydro Gen (MU)	278	28	103	58	40	508
Wind Gen (MU)	49	249	195	-	-	493
Solar Gen (MU)*	201.58	141.21	135.94	4.33	0.54	484
Energy Shortage (MU)	0.00	0.00	0.00	0.42	0.00	0.42
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72083	63852	52322	29743	3221	216597
Time Of Maximum Demand Met	22:41	19:41	15:11	23:41	19:25	22:37

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.081	0.00	0.54	8.16	8.70	67.25	24.05

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10940	0	232.7	138.4	-5.3	391	0.00
	Haryana	9360	0	192.5	151.8	-0.4	345	0.00
	Rajasthan	14972	0	308.2	112.4	-8.5	735	0.00
	Delhi	5728	0	119.0	109.9	-4.5	69	0.00
	UP	27813	0	543.0	245.7	1.7	881	0.00
	Uttarakhand	2346	0	48.1	30.3	2.3	372	0.00
	HP	1812	0	38.2	13.3	0.1	649	0.00
	J&K(UT) & Ladakh(UT)	2585	0	54.3	30.0	-1.1	183	0.00
	Chandigarh	313	0	6.3	6.2	0.1	39	0.00
	Railways NR ISTS	245	0	4.3	3.9	0.4	77	0.00
WR	Chhattisgarh	5100	0	111.7	54.1	-0.5	309	0.00
	Gujarat	22129	0	465.1	179.1	-10.9	957	0.00
	MP	11784	0	258.9	140.3	-1.0	598	0.00
	Maharashtra	24863	0	541.3	180.5	-3.2	774	0.00
	Goa	599	0	13.2	13.0	-0.2	76	0.00
	DNHDDPDCL	1327	0	30.1	30.2	-0.1	54	0.00
	AMNSIL	858	0	17.7	8.2	0.1	300	0.00
	BALCO	533	0	12.7	12.7	0.0	480	0.00
	RIL JAMNAGAR	199	0	3.8	3.8	0.0	0	0.00
	Andhra Pradesh	10460	0	220.9	47.8	0.1	1769	0.00
SR	Telangana	9411	0	196.2	97.0	0.9	818	0.00
	Karnataka	11157	0	221.8	93.3	1.7	1460	0.00
	Kerala	4299	0	83.6	40.5	0.4	694	0.00
	Tamil Nadu	18536	0	379.4	170.7	-3.4	691	0.00
	Puducherry	523	0	10.6	10.2	0.0	45	0.00
	Bihar	6721	0	147.0	137.4	-1.3	453	0.42
ER	DVC	3279	0	70.5	-30.1	-0.2	301	0.00
	Jharkhand	2163	0	45.4	36.3	1.1	211	0.00
	Odisha	7043	0	144.7	83.7	1.2	794	0.00
	West Bengal	11620	0	238.7	110.9	-0.1	455	0.00
	Sikkim	79	0	1.3	1.3	-0.1	36	0.00
	Railways ER ISTS	23	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	164	0	3.1	2.9	-0.2	14	0.00
	Assam	1979	0	35.3	28.6	0.2	243	0.00
	Manipur	158	0	2.2	2.3	-0.1	32	0.00
	Meghalaya	324	0	5.2	-0.3	-0.4	46	0.00
	Mizoram	100	0	1.9	1.5	-0.4	17	0.00
	Nagaland	156	0	2.7	2.8	-0.1	15	0.00
	Tripura	305	0	4.7	4.1	-0.1	29	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	35.6	1.7	-23.3	-25.2
Day Peak (MW)	1941.9	266.4	-988.0	-1912.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	334.9	-330.9	15.5	-10.2	-9.3	0.0
Actual(MU)	323.8	-320.0	22.8	-13.2	-15.3	-1.9
O/D/U/D(MU)	-11.1	10.9	7.3	-3.0	-5.9	-1.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6104	9183	4858	2870	335	23350	41
State Sector	8299	12096	11205	1449	179	33228	59
Total	14403	21279	16063	4319	514	56578	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	703	1387	548	675	13	3325	64
Lignite	26	19	49	0	0	94	2
Hydro	278	28	103	58	40	508	10
Nuclear	32	59	71	0	0	163	3
Gas, Naptha & Diesel	20	18	4	0	20	62	1
RES (Wind, Solar, Biomass & Others)	259	391	361	6	1	1018	20
Total	1318	1902	1137	739	73	5169	100

Share of RES in total generation (%)	19.66	20.57	31.75	0.82	0.74	19.69
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	43.20	25.15	47.12	8.72	55.30	32.66

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.071

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	213500	15:01	43
Non-Solar hr	216597	22:37	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 03-Jun-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI-BB	-	0	47	0.0	1.9	-1.9
3	765 kV	GAYA-VARANASI	2	1202	586	2.4	0.0	2.4
4	765 kV	SASARAM-FATEHPUR	1	421	279	0.1	0.0	0.1
5	765 kV	GAYA-BALIA	1	0	720	0.0	9.9	-9.9
6	400 kV	PUSAULI-VARANASI	1	0	183	0.0	2.4	-2.4
7	400 kV	PUSAULI-ALLAHABAD	1	107	26	0.7	0.0	0.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	368	862	0.0	8.2	-8.2
9	400 kV	PATNA-BALIA	2	201	803	0.0	10.0	-10.0
10	400 kV	NAUBATPUR-BALIA	2	183	509	0.0	2.6	-2.6
11	400 kV	BIHARSHARIFF-BALIA	2	425	305	0.2	0.0	0.2
12	400 kV	MOTIHARI-GORAKHPUR	2	141	498	0.0	6.0	-6.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	181	154	0.0	0.7	-0.7
14	220 kV	SAHUPURI-KARAMNASHA	1	0	111	0.0	2.2	-2.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASHA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASHA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	4.1	-39.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	774	481	3.6	0.0	3.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2497	0	33.5	0.0	33.5
3	765 kV	JHARSUGUDA-DURG	2	443	377	1.1	0.0	-1.1
4	400 kV	JHARSUGUDA-RAIGARH	4	729	0	7.9	0.0	7.9
5	400 kV	RANCHI-SIPAT	2	623	0	7.6	0.0	7.6
6	220 kV	BUDHIPADAR-RAIGARH	1	107	52	0.6	0.0	0.6
7	220 kV	BUDHIPADAR-KORBA	2	255	0	3.3	0.0	3.3
						ER-WR	56.5	55.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	356	0	4.2	0.0	4.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1765	0.0	43.0	-43.0
3	765 kV	ANGUL-SRIKAKULAM	2	62	2383	0.0	32.8	-32.8
4	400 kV	TALCHER-I/C	2	595	979	0.0	4.0	-4.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	4.2	-71.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	300	96	3.3	0.1	3.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	191	354	0.0	0.8	-0.8
3	220 kV	ALIPURDUAR-SALAKATI	2	56	54	0.3	0.0	0.3
						ER-NER	3.5	2.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	504	0.0	12.1	-12.1
						NER-NR	0.0	-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4522	0.0	87.2	-87.2
2	HVDC	VINDHYACHAL B/B	-	574	6	3.1	0.0	3.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	2156	0.0	33.4	-33.4
5	765 kV	GWALIOR-PHAGI	2	1224	1351	6.6	14.1	-7.5
6	765 kV	JABALPUR-ORAI	2	0	1059	0.0	30.1	-30.1
7	765 kV	GWALIOR-ORAI	1	694	34	9.1	0.0	9.1
8	765 kV	SATNA-ORAI	1	0	1006	0.0	17.4	-17.4
9	765 kV	BANASKANTHA-CHITORGARH	2	511	2011	0.6	15.7	-15.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3328	0.0	54.0	-54.0
11	400 kV	ZERDA-KANKROLI	1	189	167	0.7	0.4	0.3
12	400 kV	ZERDA-BHINMAL	1	0	304	0.0	3.2	-3.2
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	402	343	2.3	2.3	0.1
15	400 kV	NEEMUCH-Chittorgarh	2	320	367	1.3	2.5	-1.2
16	220 kV	BHANPURA-RANPUR	1	0	159	0.0	3.1	-3.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	79	29	0.6	0.1	0.5
19	220 kV	MALANPUR-AURAIYA	1	58	38	0.3	0.2	0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	24.7	-277.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1002	0	0.0	14.8	-14.8
2	HVDC	RAIGARH-PUGALUR	2	0	1502	0.0	21.9	-21.9
3	765 kV	SOLAPUR-RAICHUR	2	2006	568	17.4	0.8	16.6
4	765 kV	WARDHA-NIZAMABAD	2	595	1921	0.6	18.4	-17.9
5	765 kV	WARORA-WARANGAL(NEW)	2	471	2210	0.4	22.6	-22.2
6	400 kV	KOLHAPUR-KUDGI	2	1924	0	27.0	0.0	27.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	103	2.1	0.0	2.1
						WR-SR	47.4	-31.2

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1028	762	965	23.16
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	746	300	467	11.21
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	60	-38	14	0.34
	NER	132kV GELEPHU-SALAKATI	39	8	21	0.51
	NER	132kV MOTANGA-RANGIA	45	5	17	0.41
	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.79
NEPAL	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-1.36
	ER	NEPAL IMPORT (FROM BIHAR)	-184	0	-34	-0.83
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	522	-176	195	4.69
	BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-950	-901	-939
ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1912	-603	-1048	-25.16
NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-38	0	-33	-0.80

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 03-Jun-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.91	0.00	0.00	0.00	0.00	2.52	0.00	0.00	3.43
Bangladesh	23.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.27	0.00	0.00	0.00	0.00	2.52	0.00	0.00	26.79

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	32.78	0.00	0.89	0.00	0.00	0.06	0.00	0.00	33.73
Nepal	4.27	0.00	0.00	0.00	0.00	2.04	0.00	0.00	6.31
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	37.05	0.00	0.89	0.00	0.00	2.10	0.00	0.00	40.04

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	32.78	0.00	0.89	0.00	0.00	0.06	0.00	0.00	33.73
Nepal	3.36	0.00	0.00	0.00	0.00	-0.49	0.00	0.00	2.87
Bangladesh	-23.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	12.78	0.00	0.89	0.00	0.00	-0.43	0.00	0.00	13.24

