



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 15-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 14.05.2024.

महोदय/Dear Sir,

आई०ई०जी०सी०-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 14-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 14-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 15-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	68633	60995	48015	27324	3389	208356
Peak Shortage (MW)	99	0	0	191	0	290
Energy Met (MU)	1567	1462	1146	607	66	4848
Hydro Gen (MU)	269	49	31	25	14	388
Wind Gen (MU)	36	83	30	-	-	149
Solar Gen (MU)*	166.06	93.54	116.71	4.15	1.36	382
Energy Shortage (MU)	2.93	0.00	0.00	1.64	0.00	4.57
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	70471	67182	53710	28578	3509	220332
Time Of Maximum Demand Met	14:51	15:08	12:20	22:48	18:56	14:48

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.025	0.00	0.00	2.05	2.05	79.08	18.88

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10771	0	222.2	90.5	0.9	368	0.00
	Haryana	9678	0	212.4	155.7	-3.6	265	0.00
	Rajasthan	14852	0	310.7	97.9	0.3	373	2.72
	Delhi	6176	0	127.7	108.1	-9.6	222	0.00
	UP	26149	0	545.9	240.2	-0.1	523	0.00
	Uttarakhand	2478	0	52.7	30.1	-3.5	72	0.00
	HP	1576	0	32.5	5.3	0.2	87	0.01
	J&K(UT) & Ladakh(UT)	2506	99	52.9	28.7	1.7	252	0.20
	Chandigarh	315	0	6.2	6.4	-0.2	21	0.00
WR	Railways_NR ISTS	204	0	4.2	3.9	0.2	76	0.00
	Chhattisgarh	5176	0	116.4	56.2	-0.6	432	0.00
	Gujarat	20836	0	425.1	138.1	-10.8	1047	0.00
	MP	12318	0	264.6	128.2	-4.6	976	0.00
	Maharashtra	25935	0	578.1	187.2	3.3	1561	0.00
	Goa	778	0	17.2	15.2	1.7	51	0.00
	DNHDDPDCL	1277	0	29.7	29.8	-0.1	46	0.00
	AMNSIL	899	0	18.2	8.7	-0.1	292	0.00
	BALCO	524	0	12.5	12.5	0.0	7	0.00
SR	Andhra Pradesh	10932	0	217.8	63.4	-1.1	697	0.00
	Telangana	9342	0	192.4	64.4	-0.8	566	0.00
	Karnataka	12367	0	245.3	118.6	-4.9	787	0.00
	Kerala	4325	0	91.0	74.3	1.4	380	0.00
	Tamil Nadu	17766	0	388.7	253.5	-0.6	683	0.00
	Puducherry	481	0	10.6	10.6	-0.6	59	0.00
ER	Bihar	6866	349	133.7	123.0	-1.3	585	1.38
	DVC	3452	0	73.8	-32.6	1.0	348	0.00
	Jharkhand	2113	0	44.3	30.9	0.1	328	0.26
	Odisha	6242	0	130.6	46.3	0.1	531	0.00
	West Bengal	10950	0	223.3	73.4	-1.1	205	0.00
	Sikkim	102	0	1.6	1.4	0.2	62	0.00
	Railways_ER ISTS	12	0	0.1	0.1	0.0	2	0.00
NER	Arunachal Pradesh	155	0	2.8	2.8	-0.1	40	0.00
	Assam	2242	0	42.9	35.3	0.9	199	0.00
	Manipur	227	0	3.2	3.1	0.2	37	0.00
	Meghalaya	314	0	5.6	3.9	0.1	53	0.00
	Mizoram	129	0	2.1	1.7	-0.2	19	0.00
	Nagaland	176	0	2.9	3.0	0.0	12	0.00
	Tripura	351	0	6.6	6.2	0.4	83	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.3	-11.3	-22.7	-17.5
Day Peak (MW)	-354.0	-610.0	-1052.0	-1142.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	246.2	-376.4	162.0	-47.9	16.1	0.0
Actual(MU)	239.7	-413.6	178.1	-30.1	18.8	-7.2
O/D/U/D(MU)	-6.5	-37.2	16.1	17.8	2.6	-7.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	1799	4598	3752	3616	351	14117	42
State Sector	5343	7616	3975	2204	110	19247	58
Total	7142	12214	7727	5820	461	33364	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	837	1637	720	696	14	3904	74
Lignite	22	18	57	0	0	97	2
Hydro	269	49	31	25	14	388	7
Nuclear	31	38	51	0	0	119	2
Gas, Naptha & Diesel	54	98	7	0	24	184	3
RES (Wind, Solar, Biomass & Others)	210	178	179	6	1	575	11
Total	1423	2019	1044	727	53	5266	100

Share of RES in total generation (%)	14.78	8.84	17.14	0.76	2.60	10.91
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.81	13.13	24.97	4.25	29.44	20.55

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.048

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	220332	14:48	0
Non-Solar hr	213872	23:09	1877

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 15-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	876	378	3.1	0.0	3.1
4	765 kV	SASARAM-FATEHPUR	1	318	300	0.0	1.6	-1.6
5	765 kV	GAYA-BALIA	1	0	662	0.0	11.0	-11.0
6	400 kV	PUSAULI-VARANASI	1	9	75	0.0	0.8	-0.8
7	400 kV	PUSAULI -ALLAHABAD	1	77	5	0.8	0.0	0.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	488	339	1.0	0.0	1.0
9	400 kV	PATNA-BALIA	2	0	527	0.0	7.4	-7.4
10	400 kV	NAUBATPUR-BALIA	2	138	168	0.0	1.7	-1.7
11	400 kV	BIHARSHARIFF-BALIA	2	467	12	4.1	0.0	4.1
12	400 kV	MOTIHARI-GORAKHPUR	2	167	316	0.0	2.6	-2.6
13	400 kV	BIHARSHARIFF-VARANASI	2	233	3	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	53	65	0.0	0.0	0.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						9.6	25.2	-15.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1659	0	27.7	0.0	27.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1650	0	22.0	0.0	22.0
3	765 kV	JHARSUGUDA-DURG	2	0	995	0.0	17.4	-17.4
4	400 kV	JHARSUGUDA-RAIGARH	4	233	178	0.3	0.0	0.3
5	400 kV	RANCHI-SIPAT	2	582	0	8.2	0.0	8.2
6	220 kV	BUDHIPADAR-RAIGARH	1	36	61	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-KORBA	2	115	100	1.0	0.0	1.0
ER-WR						59.3	18.4	40.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	486	0.0	11.6	-11.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1195	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2267	0.0	47.8	-47.8
4	400 kV	TALCHER-I/C	2	571	0	7.0	0.0	7.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	88.3	-88.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	72	151	0.0	1.1	-1.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	282	360	0.0	1.1	-1.1
3	220 kV	ALIPURDUAR-SALAKATI	2	19	100	0.0	0.7	-0.7
ER-NER						0.0	2.8	-2.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	655	0	15.9	0.0	15.9
NER-NR						15.9	0.0	15.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5052	0.0	95.9	-95.9
2	HVDC	VINDHYACHAL B/B	-	198	0	3.3	0.0	3.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1659	0.0	29.8	-29.8
4	765 kV	GWALIOR-AGRA	2	0	2330	0.0	35.6	-35.6
5	765 kV	GWALIOR-PHAGI	2	620	1086	2.0	13.0	-11.0
6	765 kV	JABALPUR-ORAI	2	0	981	0.0	25.5	-25.5
7	765 kV	GWALIOR-ORAI	1	545	0	8.7	0.0	8.7
8	765 kV	SATNA-ORAI	1	0	1064	0.0	20.9	-20.9
9	765 kV	BANASKANTHA-CHITORGARH	2	1147	800	10.6	2.2	8.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	3501	0.0	69.6	-69.6
11	400 kV	ZERDA-KANKROLI	1	265	124	3.0	0.1	2.9
12	400 kV	ZERDA -BHINMAL	1	265	123	3.0	0.1	2.9
13	400 kV	VINDHYACHAL -RIHAND	1	963	0	22.1	0.0	22.1
14	400 kV	RAPP-SHUJALPUR	2	390	421	2.3	2.1	0.2
15	400 kV	NEEMUCH-Chittorgarh	2	401	402	2.2	3.0	-0.8
16	220 kV	BHANPURA-RANPUR	1	0	135	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.5	-2.5
18	220 kV	MEHGAON-AURAIYA	1	42	12	0.4	0.0	0.3
19	220 kV	MALANPUR-AURAIYA	1	20	31	0.1	0.2	-0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						57.6	303.1	-245.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	305	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	3003	0.0	38.9	-38.9
3	765 kV	SOLAPUR-RAICHUR	2	178	1493	0.0	21.8	-21.7
4	765 kV	WARDHA-NIZAMABAD	2	0	1744	0.0	33.7	-33.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2042	0.0	41.0	-41.0
6	400 kV	KOLHAPUR-KUDGI	2	1011	0	10.8	0.0	10.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	88	1.8	0.0	1.8
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.7	0.0	2.7
WR-SR						15.4	142.5	-127.2

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	238	-82	58	1.40
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-287	137	-69	-1.65
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-216	-57	-133	-3.20
	NER	132kV GELEPHU-SALAKATI	-20	4	-13	-0.31
	NER	132kV MOTANGA-RANGIA	23	-22	19	0.45
NEPAL	NR	NEPAL IMPORT (FROM UP)	-77	0	-45	-1.08
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-77	0	-52	-1.25
	ER	NEPAL IMPORT (FROM BIHAR)	-290	0	-132	-3.18
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-320	-230	-241	-5.78
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-927	-635	-838	-20.11
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1142	-330	-731	-17.54
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-125	0	-108	-2.60

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	3.07	0.00	0.00	1.42	0.00	0.00	4.49
Nepal	0.35	0.00	4.06	0.00	0.00	0.73	0.00	0.00	5.14
Bangladesh	20.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.21
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.56	0.00	7.13	0.00	0.00	2.15	0.00	0.00	29.84

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.35
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.35

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.35	0.00	-3.07	0.00	0.00	-1.42	0.00	0.00	-4.14
Nepal	-0.35	0.00	-4.06	0.00	0.00	-0.73	0.00	0.00	-5.14
Bangladesh	-20.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.21
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.21	0.00	-7.13	0.00	0.00	-2.15	0.00	0.00	-29.49